

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月28日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.71	6.14	43.03	2.85	14.34	12.36	1.46	70200.41
1	1.74	3.29	49.23	2.71	14.12	12.48	1.47	69246.23
2	1.08	4.23	60.03	2.50	14.64	12.68	1.47	67217.45
3	1.13	3.16	64.71	1.86	16.23	12.10	1.47	70767.36
4	1.53	6.21	48.49	2.40	14.90	12.48	1.47	68974.25
5	2.90	5.52	63.46	2.85	14.40	12.20	1.46	67546.42
6	3.08	3.48	65.30	2.60	15.15	12.19	1.46	70952.49
7	2.67	3.53	55.22	2.67	14.77	12.24	1.42	70300.58
8	2.49	3.35	56.90	2.76	14.36	12.21	1.45	70662.99
9	2.86	3.01	59.06	2.50	14.96	11.85	1.42	73077.57
10	3.80	3.14	54.45	2.87	14.52	12.09	1.45	71103.97
11	5.92	3.82	51.03	3.37	13.61	12.18	1.42	70971.83
12	6.31	6.85	55.31	3.80	12.91	12.65	1.45	67842.95
13	6.58	4.10	59.16	3.43	13.65	12.44	1.46	69159.55
14	10.27	9.14	47.56	4.57	12.79	12.49	1.46	69239.81
15	9.58	6.71	51.00	4.40	13.11	12.32	1.44	70523.05
16	9.26	2.57	46.01	4.20	12.75	12.68	1.41	68350.52
17	7.00	1.78	60.82	3.17	14.11	12.50	1.45	68715.77
18	5.81	3.35	51.56	3.75	12.91	12.57	1.43	68995.65
19	5.31	2.59	55.58	3.73	13.21	12.65	1.41	68413.24
20	9.83	2.55	62.04	3.58	13.66	12.48	1.40	69229.89
21	6.80	3.55	56.36	3.88	13.37	12.75	1.38	66856.03
22	8.67	2.09	52.96	2.95	14.64	12.28	1.40	70410.84
23	3.86	1.75	60.45	2.65	14.84	12.41	1.44	68718.48
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.09	4.00	55.41	3.17	14.08	12.39	1.44	69478.22
最大值	10.27	9.14	65.30	4.57	16.23	12.75	1.49	73077.57
發生時間	14	14	6	14	3	21		9
最小值	1.08	1.75	43.03	1.86	12.75	11.85	1.38	66856.03
發生時間	2	23	0	3	16	9		21
零點偏移(率)	-0.04 %	-0.04 %	-0.03 %	0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	2.45 %	0.26 %	-1.14 %	0.23 %		0.18	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月28日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.59	4.46	51.55	1.86	16.37	10.94	1.33	81358.01
1	4.56	3.66	60.55	1.86	16.67	11.17	1.34	81422.45
2	4.78	3.81	52.92	1.92	16.38	11.33	1.33	79365.23
3	1.74	4.92	58.13	1.32	18.14	10.99	1.33	80400.92
4	2.95	3.86	56.04	1.83	16.98	11.00	1.33	81644.56
5	6.67	5.20	64.93	2.19	17.43	10.65	1.33	85097.41
6	8.09	4.68	51.43	2.29	16.02	10.97	1.43	83326.23
7	5.34	3.80	66.72	1.91	15.93	11.35	1.45	80107.46
8	5.19	7.49	49.04	1.66	17.53	10.35	1.43	87149.25
9	4.23	4.91	49.34	1.68	16.86	10.46	1.40	86019.36
10	2.91	3.36	56.04	1.65	16.11	10.63	1.41	81143.07
11	0.17	3.73	50.72	1.55	15.45	10.66	1.40	79577.79
12	0.06	3.83	56.45	1.60	14.73	10.76	1.40	78804.16
13	8.63	17.02	59.30	6.28	12.30	11.09	1.38	77797.60
14	5.97	2.93	46.87	2.88	14.72	10.41	1.38	81391.93
15	3.32	4.61	59.24	1.96	15.13	10.52	1.42	84221.31
16	7.86	6.81	51.42	2.42	15.57	10.59	1.41	80340.85
17	6.20	2.33	45.17	1.95	17.06	10.06	1.37	79170.87
18	7.13	3.28	46.94	2.15	16.66	10.14	1.39	79128.73
19	9.45	1.79	55.50	2.38	16.25	10.61	1.43	80622.95
20	9.24	2.38	52.70	2.50	16.28	10.54	1.41	80196.17
21	9.72	1.76	57.00	2.01	17.18	10.37	1.38	81743.52
22	6.74	2.09	52.14	1.89	16.98	10.49	1.38	80012.62
23	7.26	2.01	56.79	1.65	17.75	10.57	1.38	82782.38
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.53	4.36	54.46	2.14	16.27	10.69	1.38	81367.70
最大值	9.72	17.02	66.72	6.28	18.14	11.35	1.46	87149.25
發生時間	21	13	7	13	3	7		8
最小值	0.06	1.76	45.17	1.32	12.30	10.06	1.33	77797.60
發生時間	12	21	17	3	13	17		13
零點偏移(率)	-0.01 %	0.00 %	-0.03 %	-0.03 %		-0.06	0.00	0.00 %
全幅偏移(率)	0.96 %	0.73 %	-0.49 %	0.39 %		0.17	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月28日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.76	3.61	60.69	0.86	16.89	10.86	1.75	82024.88
1	0.98	3.39	60.40	0.83	16.85	10.74	1.75	83085.05
2	2.08	3.51	57.62	0.90	17.03	10.59	1.75	83547.85
3	0.86	3.64	58.47	0.94	16.96	10.86	1.75	82027.59
4	1.60	4.37	58.57	0.90	17.16	10.62	1.76	84321.65
5	1.35	3.59	60.12	0.94	16.90	10.70	1.77	84591.81
6	0.93	4.82	59.72	1.07	15.95	10.90	1.77	83331.45
7	1.78	4.99	59.40	1.81	14.70	10.91	1.78	86569.73
8	2.52	3.54	66.66	1.55	15.82	10.90	1.79	83179.69
9	3.07	5.56	59.24	1.61	15.21	10.69	1.80	85091.82
10	3.40	11.57	59.76	2.16	14.32	11.07	1.81	83011.59
11	0.42	3.26	68.13	1.86	14.40	11.31	1.81	81537.91
12	0.65	3.33	61.42	1.54	15.09	10.80	1.82	85232.69
13	6.15	8.27	67.04	3.48	12.65	11.40	1.82	82137.30
14	11.14	15.49	55.84	3.72	12.82	11.15	1.80	81652.82
15	7.17	5.48	59.91	2.95	12.73	11.39	1.81	79710.17
16	7.89	3.79	59.09	2.66	13.29	11.32	1.80	79679.67
17	5.62	3.64	58.97	2.26	13.98	11.15	1.80	79967.54
18	7.66	3.19	59.49	2.49	13.85	11.15	1.79	78928.35
19	5.40	4.26	60.21	4.65	13.42	11.32	1.77	78138.10
20	4.64	5.10	55.91	2.35	14.77	10.98	1.78	78561.52
21	5.95	1.84	64.32	1.76	15.27	10.95	1.77	81044.58
22	4.83	2.38	60.82	1.65	15.51	11.06	1.77	81354.57
23	2.87	1.77	62.95	1.49	15.47	11.18	1.78	80778.64
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.78	4.77	60.61	1.93	15.04	11.00	1.78	82062.79
最大值	11.14	15.49	68.13	4.65	17.16	11.40	1.84	86569.73
發生時間	14	14	11	19	4	13		7
最小值	0.42	1.77	55.84	0.83	12.65	10.59	1.75	78138.10
發生時間	11	23	14	1	13	2		19
零點偏移(率)	-0.02 %	-0.03 %	-0.03 %	-0.02 %		0.01	0.00	0.00 %
全幅偏移(率)	1.01 %	0.52 %	-0.86 %	0.27 %		0.20	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								