

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年11月03日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	13.35	13.06	56.66	3.12	19.02	9.63	1.46	88681.16
1	12.45	11.68	57.47	3.06	20.35	9.28	1.46	86323.54
2	11.13	13.39	48.26	3.01	20.25	9.09	1.44	82182.46
3	10.84	15.29	41.17	2.83	21.62	9.80	1.43	71726.02
4	12.14	13.88	41.14	3.30	21.35	9.89	1.45	67934.74
5	9.25	13.65	33.94	2.85	21.00	9.69	1.43	66276.37
6	11.36	10.86	33.92	2.36	19.99	7.86	1.45	82944.76
7	7.91	11.62	52.96	2.87	19.19	8.93	1.44	83556.63
8	14.18	11.75	50.44	3.91	19.08	8.84	1.44	80603.47
9	11.19	11.14	45.57	3.34	19.44	8.47	1.45	82634.77
10	15.10	10.75	52.76	3.80	18.95	8.74	1.43	81516.36
11	10.35	11.70	46.51	4.55	18.75	8.67	1.44	82669.37
12	11.14	11.82	52.93	2.75	18.31	9.12	1.44	78910.56
13	12.20	11.82	56.95	2.76	18.87	9.21	1.43	78633.43
14	10.88	10.49	52.78	2.99	19.40	8.73	1.43	81584.59
15	11.72	10.89	47.37	2.78	17.76	8.91	1.43	79163.25
16	12.77	11.61	54.58	2.85	17.32	9.08	1.43	80851.40
17	13.86	12.16	62.87	3.05	16.65	9.78	1.44	83069.48
18	11.31	12.34	60.95	2.74	18.72	9.28	1.43	85426.74
19	11.04	10.78	54.52	2.82	18.77	9.47	1.43	86537.03
20	12.14	11.68	57.57	2.76	19.05	9.29	1.44	87700.17
21	13.29	12.24	62.06	2.77	18.48	9.52	1.43	83970.71
22	11.27	12.37	51.84	2.73	19.94	8.96	1.44	87597.50
23	13.20	11.26	55.57	2.63	20.10	8.93	1.45	88047.52
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	11.84	12.01	51.28	3.03	19.27	9.13	1.44	81605.92
最 大 值	15.10	15.29	62.87	4.55	21.62	9.89	1.48	88681.16
發生時間	10	3	17	11	3	4		0
最 小 值	7.91	10.49	33.92	2.36	16.65	7.86	1.43	66276.37
發生時間	7	14	6	6	17	6		5
零點偏移(率)	-0.09 %	-0.00 %	-0.01 %	0.00 %		-0.01	-0.01	0.00 %
全幅偏移(率)	-0.42 %	0.21 %	0.87 %	-0.60 %		0.34	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								