

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月21日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.76	11.79	54.25	0.98	19.62	11.05	1.38	80554.92
1	8.06	13.06	55.07	1.86	18.79	12.09	1.38	72822.47
2	8.33	14.61	66.14	1.83	16.94	13.26	1.39	65251.78
3	9.81	12.50	43.11	1.16	19.70	11.37	1.36	78506.37
4	9.78	12.92	36.75	1.25	20.18	10.68	1.36	83547.11
5	10.40	11.50	47.38	1.18	20.80	10.36	1.34	86794.26
6	9.21	11.94	53.47	1.32	20.29	10.60	1.34	83698.22
7	9.69	11.38	45.58	1.52	19.72	10.38	1.31	86150.49
8	9.25	12.17	62.92	1.31	19.72	11.19	1.34	79488.97
9	9.10	12.38	50.65	1.63	19.20	10.65	1.35	83946.94
10	9.79	11.38	64.88	1.92	18.54	10.86	1.33	82776.33
11	10.07	11.80	47.26	2.14	17.37	11.34	1.35	79865.13
12	9.00	11.82	57.47	1.74	17.66	11.38	1.34	79260.56
13	9.52	11.55	54.59	2.46	17.13	11.19	1.34	81429.01
14	10.01	12.19	63.57	2.08	16.25	11.86	1.34	76726.27
15	8.84	12.23	59.45	1.25	18.15	11.37	1.34	79207.76
16	9.52	12.58	45.25	2.01	18.04	10.85	1.34	83291.09
17	9.44	12.01	41.07	1.70	17.40	11.29	1.34	78598.87
18	9.36	11.79	55.54	1.45	18.35	11.22	1.34	80315.08
19	10.01	12.69	56.64	1.53	19.90	10.23	1.34	86053.83
20	9.81	12.25	39.82	1.95	17.45	10.82	1.34	83783.79
21	7.86	12.25	52.44	1.19	17.58	11.64	1.35	74936.85
22	9.79	12.15	46.31	1.54	18.86	10.84	1.35	82185.18
23	10.09	13.41	42.91	0.95	20.79	10.14	1.34	86182.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.40	12.26	51.77	1.58	18.68	11.11	1.35	80640.59
最大值	10.40	14.61	66.14	2.46	20.80	13.26	1.39	86794.26
發生時間	5	2	2	13	5	2		5
最小值	7.86	11.38	36.75	0.95	16.25	10.14	1.31	65251.78
發生時間	21	7	4	23	14	23		2
零點偏移(率)	-0.05 %	-0.02 %	-0.01 %	-0.02 %		-0.06	-0.01	0.40 %
全幅偏移(率)	-1.81 %	-0.75 %	-0.92 %	-1.60 %		-0.08	0.10	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月21日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.07	12.18	46.88	0.36	19.76	10.20	1.05	83108.17
1	10.43	12.93	48.43	0.86	21.84	9.55	1.05	84680.38
2	8.62	12.93	45.60	0.55	20.15	10.02	1.04	78783.82
3	9.90	12.10	55.01	0.76	20.18	9.98	1.03	82658.12
4	9.01	11.82	56.53	0.68	19.58	10.02	1.02	80583.59
5	9.83	12.37	52.57	0.91	19.85	9.99	1.02	79063.39
6	10.33	11.73	45.52	0.56	19.92	9.91	1.02	81613.97
7	8.03	12.05	45.43	0.54	20.44	9.63	1.02	82157.18
8	10.67	12.00	57.89	0.79	20.02	9.75	1.04	82298.27
9	9.80	12.37	53.07	1.00	19.68	9.74	1.05	81014.84
10	9.94	12.45	58.30	0.83	19.44	9.90	1.04	81366.97
11	9.23	11.73	64.30	0.96	18.24	10.20	1.03	80861.77
12	10.96	13.48	64.08	1.87	16.83	10.57	1.04	78306.86
13	9.33	13.11	59.18	1.61	16.41	10.58	1.04	77533.30
14	11.96	14.30	60.78	2.55	14.90	10.90	1.04	76785.06
15	10.48	12.49	60.57	1.64	16.38	10.67	1.02	76731.01
16	8.90	10.32	48.84	0.87	19.32	9.76	1.03	81084.75
17	9.24	12.26	53.13	1.21	17.52	10.64	1.03	80401.78
18	9.44	11.63	47.11	0.92	18.12	10.15	1.02	78074.38
19	10.62	11.99	42.63	0.42	19.79	9.83	1.02	80410.89
20	8.68	12.62	47.47	0.64	18.91	10.20	1.02	82483.59
21	8.92	12.89	62.02	0.89	18.49	11.13	1.05	73870.24
22	9.75	13.19	51.23	1.16	19.70	9.57	1.04	86849.84
23	10.01	12.50	40.84	0.67	19.83	9.12	1.02	83935.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.67	12.39	52.81	0.97	18.97	10.08	1.03	80610.74
最大值	11.96	14.30	64.30	2.55	21.84	11.13	1.06	86849.84
發生時間	14	14	11	14	1	21		22
最小值	8.03	10.32	40.84	0.36	14.90	9.12	1.02	73870.24
發生時間	7	16	23	0	14	23		21
零點偏移(率)	-0.08 %	0.01 %	-0.03 %	-0.01 %		-0.09	-0.01	0.10 %
全幅偏移(率)	-0.08 %	-0.22 %	-0.24 %	-0.33 %		-0.11	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月21日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.04	12.07	58.52	2.01	18.89	10.46	1.41	73771.37
1	9.84	12.51	41.59	1.87	20.28	9.50	1.41	80093.14
2	8.80	12.96	60.12	1.72	17.83	10.51	1.41	71725.87
3	9.76	13.63	64.92	2.16	17.78	11.03	1.41	70524.47
4	8.91	13.55	51.05	2.15	18.06	10.64	1.42	74848.50
5	9.45	13.18	59.84	2.08	17.92	10.69	1.43	72874.16
6	10.34	13.17	56.66	2.29	17.34	10.68	1.41	72934.26
7	9.51	11.55	47.37	2.19	18.59	10.04	1.47	78466.48
8	9.59	11.84	50.88	2.00	18.38	10.36	1.47	74116.81
9	9.75	11.72	58.88	2.04	18.63	10.21	1.47	76363.49
10	9.08	13.14	60.29	2.52	19.29	9.81	1.45	79576.95
11	9.02	11.51	60.81	1.92	18.70	9.93	1.45	76938.33
12	10.60	11.69	59.12	1.85	18.04	10.03	1.45	75532.43
13	8.66	12.15	58.93	1.74	18.34	10.02	1.44	74557.84
14	10.05	13.33	54.61	2.13	17.49	9.59	1.43	76355.29
15	9.02	12.53	69.17	1.86	17.17	10.91	1.43	70858.10
16	6.66	9.48	46.88	1.39	17.84	10.37	1.45	74057.41
17	7.75	11.75	36.42	0.78	18.28	10.24	1.44	75279.33
18	9.17	12.50	33.52	0.90	18.85	9.70	1.42	76853.23
19	10.25	12.06	34.86	0.85	18.35	9.28	1.42	76968.43
20	9.92	11.57	51.36	1.29	18.86	9.58	1.43	74633.89
21	6.44	9.66	49.53	0.72	19.68	9.07	1.43	76892.90
22	8.80	10.58	47.51	0.63	18.75	9.31	1.43	74005.95
23	5.59	10.55	52.55	0.63	18.76	9.84	1.43	69702.13
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.04	12.03	52.72	1.66	18.42	10.08	1.43	74913.78
最大值	10.60	13.63	69.17	2.52	20.28	11.03	1.48	80093.14
發生時間	12	3	15	10	1	3		1
最小值	5.59	9.48	33.52	0.63	17.17	9.07	1.41	69702.13
發生時間	23	16	18	22	15	21		23
零點偏移(率)	-0.07 %	-0.01 %	-0.01 %	-0.01 %		-0.12	-0.01	0.00 %
全幅偏移(率)	-1.25 %	-0.44 %	1.12 %	0.41 %		0.01	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								