

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月31日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.65	11.91	47.12	1.60	18.59	11.25	1.31	77463.45
1	9.61	12.28	35.22	2.46	17.84	11.05	1.30	81125.53
2	7.83	12.68	43.37	2.23	18.90	11.12	1.30	78748.17
3	9.47	12.20	50.47	2.33	18.21	10.84	1.30	82525.43
4	8.46	12.60	50.68	1.83	17.87	11.06	1.30	80162.63
5	9.94	12.88	35.11	3.57	16.73	11.06	1.29	80231.63
6	9.56	12.62	44.74	2.24	18.89	10.68	1.29	84121.48
7	7.88	12.53	45.45	3.34	16.19	11.10	1.30	81939.27
8	9.63	12.61	41.28	1.67	16.89	11.25	1.30	80311.55
9	9.37	12.60	48.03	1.45	17.82	11.22	1.30	79772.61
10	9.20	12.47	51.49	1.09	19.61	10.79	1.30	82706.60
11	9.59	12.63	38.65	1.56	17.41	11.05	1.29	82446.20
12	10.71	13.05	50.19	1.96	15.73	11.49	1.29	80456.23
13	9.37	13.07	58.26	1.84	14.94	11.67	1.29	80047.07
14	9.22	12.63	58.47	1.14	18.10	11.12	1.28	81943.18
15	8.68	11.91	52.57	2.12	17.87	11.10	1.28	81611.05
16	9.74	11.51	43.53	1.91	19.05	10.81	1.29	83212.40
17	8.84	11.49	53.70	2.95	16.95	10.69	1.29	84936.38
18	10.18	10.77	50.41	3.23	16.64	10.89	1.29	83395.54
19	9.08	10.70	47.77	3.05	17.17	10.71	1.29	84021.84
20	9.87	10.80	38.58	2.28	18.27	10.61	1.29	84918.75
21	10.50	11.97	40.87	2.65	18.99	10.34	1.29	86711.88
22	8.20	11.52	47.64	3.17	17.07	11.31	1.27	80307.21
23	9.86	11.18	43.41	2.20	19.23	10.63	1.27	84192.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.31	12.11	46.54	2.24	17.71	10.99	1.29	81971.18
最大值	10.71	13.07	58.47	3.57	19.61	11.67	1.32	86711.88
發生時間	12	13	14	5	10	13		21
最小值	7.83	10.70	35.11	1.09	14.94	10.34	1.27	77463.45
發生時間	2	19	5	10	13	21		0
零點偏移(率)	-0.02 %	-0.00 %	-0.02 %	-0.01 %		-0.06	-0.01	0.30 %
全幅偏移(率)	-0.21 %	-0.38 %	-0.11 %	-0.28 %		0.38	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月31日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.74	10.99	53.76	0.46	19.21	11.36	0.83	71216.78
1	8.73	25.85	58.74	0.66	20.35	10.90	0.83	75194.04
2	10.29	11.49	56.68	0.62	18.78	11.60	0.83	71048.51
3	11.51	9.41	50.47	0.78	19.17	10.85	0.82	77647.89
4	9.44	9.86	55.81	0.55	18.86	11.34	0.81	73071.04
5	10.37	11.49	53.17	0.60	19.38	11.02	0.81	75722.78
6	9.67	11.25	41.53	1.55	18.50	10.92	0.81	78299.54
7	9.38	10.19	49.88	0.75	18.70	11.16	0.82	76488.41
8	10.87	9.32	54.13	1.02	18.42	11.31	0.84	73141.39
9	9.80	8.82	50.07	0.81	18.31	11.46	0.85	69777.21
10	8.63	9.01	48.18	0.63	18.33	11.38	0.83	68915.06
11	9.65	9.53	49.66	1.11	18.22	11.34	0.84	69364.66
12	8.42	10.60	48.29	1.00	18.56	11.50	0.84	68217.17
13	10.74	10.15	49.63	1.26	18.09	11.24	0.84	72875.66
14	10.08	9.22	49.67	1.27	18.06	11.39	0.83	72286.58
15	10.39	8.46	53.27	1.10	18.12	11.43	0.83	71292.17
16	11.76	27.05	63.45	1.31	17.95	11.29	0.83	73471.34
17	13.51	9.14	54.32	0.44	19.69	10.37	0.83	82119.65
18	10.55	10.40	63.34	0.86	19.06	11.06	0.83	76286.28
19	11.15	14.69	59.36	0.54	19.11	11.09	0.83	77547.05
20	10.44	8.56	52.84	0.83	18.03	10.78	0.84	78946.81
21	10.41	9.57	58.98	0.59	18.80	10.94	0.84	75520.07
22	10.38	24.79	57.13	0.61	19.30	11.09	0.84	67844.18
23	9.19	11.28	55.05	0.57	18.75	11.07	0.84	69269.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.21	12.13	53.64	0.83	18.74	11.16	0.83	73565.16
最大值	13.51	27.05	63.45	1.55	20.35	11.60	0.86	82119.65
發生時間	17	16	16	6	1	2		17
最小值	8.42	8.46	41.53	0.44	17.95	10.37	0.81	67844.18
發生時間	12	15	6	17	16	17		22
零點偏移(率)	-0.12 %	-0.01 %	-0.05 %	-0.00 %		-0.10	-0.06	0.00 %
全幅偏移(率)	-0.81 %	0.50 %	0.74 %	0.24 %		-0.18	0.31	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月31日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.78	12.01	60.84	3.01	18.99	10.56	1.34	75043.74
1	8.32	12.07	51.70	2.83	17.55	10.64	1.36	74472.62
2	8.44	12.11	52.01	3.06	16.38	10.57	1.35	73611.51
3	8.57	11.69	52.77	2.87	17.32	10.32	1.33	77168.02
4	8.24	11.00	49.76	3.11	15.92	10.68	1.31	75162.14
5	10.37	11.29	43.71	0.95	18.18	9.32	1.31	78693.21
6	9.32	10.91	59.56	0.44	17.17	9.74	1.33	77145.79
7	7.51	9.66	41.78	2.71	16.57	9.99	1.37	74744.73
8	7.66	11.92	53.42	1.67	16.05	10.45	1.41	76929.60
9	9.93	11.68	63.02	1.65	16.90	10.49	1.41	78616.42
10	8.91	11.62	62.90	1.59	17.46	10.37	1.38	79819.06
11	9.67	11.71	52.29	1.54	16.58	10.48	1.40	74921.08
12	8.65	11.61	48.85	1.51	17.24	9.77	1.35	74164.85
13	9.81	11.11	43.07	1.28	19.78	8.27	1.33	73836.45
14	9.39	10.30	42.36	0.92	21.62	8.14	1.38	74577.46
15	9.47	10.78	55.11	2.26	18.70	9.24	1.37	75001.38
16	8.81	10.76	56.49	3.08	19.28	9.18	1.36	78388.28
17	9.78	10.90	58.56	3.28	19.05	9.37	1.35	78404.38
18	9.94	11.18	58.79	3.37	18.53	9.39	1.37	77659.97
19	8.67	10.99	55.26	3.21	19.23	9.42	1.41	77899.07
20	9.59	11.01	54.10	3.02	19.84	9.18	1.41	79393.23
21	10.35	11.28	54.26	3.09	19.81	9.06	1.40	80068.20
22	8.97	11.09	49.75	3.26	17.32	9.51	1.36	73331.47
23	9.07	10.76	48.51	2.05	17.96	9.19	1.36	72262.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.05	11.23	52.87	2.32	18.06	9.72	1.37	76304.79
最大值	10.37	12.11	63.02	3.37	21.62	10.68	1.43	80068.20
發生時間	5	2	9	18	14	4		21
最小值	7.51	9.66	41.78	0.44	15.92	8.14	1.31	72262.36
發生時間	7	7	7	6	4	14		23
零點偏移(率)	-0.05 %	-0.03 %	-0.07 %	-0.00 %		-0.10	-0.01	0.10 %
全幅偏移(率)	-0.71 %	0.12 %	-0.31 %	0.42 %		0.20	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								