

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年01月27日

報表日期: 114年01月27日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.73	2.78	63.89	2.35	14.35	12.36	1.29	76926.72
1	9.41	2.35	59.91	2.22	15.91	11.73	1.29	80917.93
2	11.78	5.30	53.04	2.63	15.54	11.68	1.29	81260.34
3	10.12	4.44	40.98	3.44	13.82	12.06	1.27	78144.42
4	9.46	4.38	43.71	3.06	13.81	12.23	1.24	76129.79
5	17.47	5.29	36.53	2.41	14.58	11.91	1.28	78079.66
6	8.07	4.08	44.86	1.46	15.34	11.97	1.29	79560.55
7	9.03	5.14	49.38	2.02	14.35	12.28	1.29	77685.94
8	8.62	4.37	43.20	1.86	14.93	11.91	1.29	80139.09
9	7.64	5.98	65.55	1.58	14.39	12.65	1.29	74110.44
10	4.81	4.78	51.48	1.17	14.19	12.62	1.29	73846.70
11	9.14	4.91	41.05	1.66	15.11	11.72	1.29	81264.76
12	7.97	3.34	38.82	1.71	14.54	11.91	1.29	80556.40
13	6.24	1.90	44.82	1.74	13.98	12.00	1.29	80042.81
14	9.32	2.10	46.93	1.57	14.83	11.59	1.29	83617.91
15	8.46	3.14	48.15	2.37	14.01	11.80	1.30	82348.62
16	10.61	2.14	46.40	1.97	15.18	11.56	1.30	83307.50
17	8.70	2.73	54.65	1.41	15.65	11.56	1.29	82402.56
18	11.38	4.50	48.68	1.96	14.80	11.63	1.29	82333.22
19	10.81	4.44	48.05	1.55	15.31	11.41	1.30	84321.23
20	8.42	4.71	46.92	1.62	15.02	11.50	1.32	83592.99
21	8.75	4.58	50.24	1.47	14.71	11.70	1.34	81816.84
22	8.69	3.83	47.05	2.73	13.27	11.82	1.34	82463.52
23	13.04	2.54	46.07	2.97	13.71	11.72	1.32	83108.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.44	3.91	48.35	2.04	14.64	11.89	1.29	80332.42
最 大 值	17.47	5.98	65.55	3.44	15.91	12.65	1.34	84321.23
發生時間	5	9	9	3	1	9		19
最 小 值	4.81	1.90	36.53	1.17	13.27	11.41	1.23	73846.70
發生時間	10	13	5	10	22	19		10
零點偏移(率)	-0.12 %	-0.01 %	0.00 %	-0.00 %		-0.03		0.30 %
全幅偏移(率)	0.00 %	-0.02 %	0.52 %	-0.05 %		-0.20		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年01月27日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.33	2.68	60.54	2.63	12.82	11.64	1.15	81235.30
1	5.79	1.60	44.37	2.94	13.42	11.53	1.17	81778.16
2	7.43	2.74	43.00	3.33	11.42	11.78	1.18	80670.39
3	7.39	2.28	45.56	2.87	11.10	11.90	1.16	80219.49
4	3.67	1.87	57.24	1.53	13.65	12.02	1.12	77007.25
5	4.43	1.68	61.27	1.82	15.95	10.42	1.10	88659.85
6	12.42	5.53	34.14	2.34	13.51	11.43	1.10	82336.12
7	9.40	6.84	46.60	2.02	13.18	11.72	1.10	80139.57
8	10.10	3.98	40.33	2.46	12.83	11.58	1.10	80412.45
9	14.01	3.62	38.17	2.50	12.84	11.38	1.10	81451.22
10	6.11	1.50	41.19	2.34	13.51	11.32	1.10	81765.50
11	2.15	1.78	43.41	1.47	13.73	11.51	1.10	81856.09
12	4.26	4.55	41.57	3.00	12.73	11.31	1.10	83950.84
13	6.97	3.48	58.38	2.69	12.55	11.45	1.10	82016.66
14	11.30	2.08	59.22	4.36	12.20	11.59	1.12	82182.32
15	7.58	2.11	58.05	2.93	11.88	11.65	1.13	80059.72
16	2.24	4.77	42.81	1.47	13.78	10.98	1.11	79526.81
17	7.97	1.96	55.36	2.65	12.52	11.19	1.10	84421.80
18	9.89	3.15	55.38	2.68	12.43	11.20	1.10	81385.55
19	4.93	3.35	44.88	1.99	12.55	11.25	1.10	80382.27
20	4.03	7.19	42.72	2.02	12.30	11.32	1.12	79955.03
21	4.88	3.50	52.77	2.09	12.30	11.50	1.14	80897.94
22	9.49	3.46	50.14	2.52	12.06	11.38	1.16	82972.44
23	9.49	3.07	54.83	2.04	12.17	11.45	1.18	82970.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.18	3.28	48.83	2.45	12.81	11.44	1.12	81593.88
最 大 值	14.01	7.19	61.27	4.36	15.95	12.02	1.18	88659.85
發生時間	9	20	5	14	5	4		5
最 小 值	2.15	1.50	34.14	1.47	11.10	10.42	1.10	77007.25
發生時間	11	10	6	11	3	5		4
零點偏移(率)	-0.02 %	-0.03 %	-0.02 %	0.00 %		-0.01		0.10 %
全幅偏移(率)	0.12 %	0.32 %	-0.20 %	0.17 %		-0.05		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 114年01月27日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.91	2.12	52.78	2.77	11.62	11.68	1.48	74932.70
1	8.99	5.89	50.77	2.37	12.56	11.65	1.48	76241.82
2	9.27	2.70	52.14	2.51	11.76	11.58	1.50	75846.56
3	8.08	1.54	54.07	2.30	11.86	11.68	1.50	76427.24
4	9.71	1.33	53.70	2.46	11.69	11.71	1.51	78827.85
5	8.45	2.47	60.82	1.86	13.18	11.56	1.48	76995.62
6	11.86	2.26	59.78	2.54	13.91	10.95	1.48	81383.37
7	8.90	6.26	41.11	1.70	12.15	11.47	1.49	70019.11
8	12.04	2.18	49.32	1.94	11.88	11.78	1.52	76481.64
9	9.53	2.54	51.11	1.93	11.69	11.78	1.52	77071.05
10	12.90	3.10	50.53	1.96	11.82	11.77	1.52	77694.07
11	10.63	5.64	54.38	1.82	12.13	11.70	1.52	77697.33
12	10.83	2.45	55.57	2.53	11.54	11.78	1.52	77663.04
13	8.28	1.84	53.57	2.28	11.84	11.79	1.52	77674.59
14	8.41	3.12	52.89	1.99	12.53	11.64	1.55	78010.04
15	9.75	2.10	50.78	1.92	12.25	11.62	1.54	77848.40
16	12.69	2.93	51.56	1.74	11.86	11.58	1.52	78334.96
17	13.16	3.36	56.55	1.79	12.48	11.49	1.52	78395.99
18	13.72	2.99	54.36	1.76	12.80	11.43	1.50	79316.30
19	5.57	4.05	58.73	0.91	13.62	11.22	1.49	80408.98
20	14.08	2.75	56.21	1.19	13.32	11.01	1.52	82001.78
21	16.51	2.64	53.85	1.52	13.35	11.08	1.52	82084.51
22	13.29	3.93	50.23	1.89	11.98	11.46	1.52	80045.44
23	13.39	4.29	53.02	1.57	13.05	11.28	1.52	80316.96
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.87	3.10	53.24	1.97	12.37	11.53	1.51	77988.31
最 大 值	16.51	6.26	60.82	2.77	13.91	11.79	1.57	82084.51
發生時間	21	7	5	0	6	13		21
最 小 值	5.57	1.33	41.11	0.91	11.54	10.95	1.48	70019.11
發生時間	19	4	7	19	12	6		7
零點偏移(率)	-0.01 %	0.00 %	-0.17 %	-0.00 %		-0.01		0.20 %
全幅偏移(率)	-0.39 %	0.03 %	0.43 %	0.12 %		-0.08		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								