

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月10日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.48	12.91	64.95	0.41	18.82	12.11	1.05	67797.43
1	4.49	10.30	62.13	0.25	21.71	10.23	1.05	79491.71
2	9.61	11.09	46.99	0.77	19.71	10.55	1.05	78894.69
3	7.30	10.34	54.42	0.45	19.25	11.18	1.05	74463.49
4	4.30	10.18	59.15	0.40	19.54	11.18	1.05	71357.62
5	5.08	9.38	52.10	0.21	20.46	10.86	1.07	70064.95
6	1.89	9.65	55.27	0.27	20.34	10.76	1.07	69116.96
7	6.18	8.61	53.75	0.34	20.52	10.71	1.07	70839.16
8	7.20	5.84	50.15	0.44	19.83	10.76	1.06	76896.49
9	5.92	5.96	56.95	0.37	20.29	10.83	1.06	75638.74
10	5.88	6.04	49.45	0.49	19.82	11.12	1.06	73753.08
11	4.38	6.23	57.11	0.32	19.45	11.29	1.05	71213.60
12	6.83	6.07	70.55	0.25	20.17	10.83	1.07	75613.53
13	9.12	6.36	41.62	0.38	19.93	10.67	1.05	77166.01
14	9.54	5.57	41.41	0.32	20.26	10.91	1.07	75773.20
15	10.09	6.76	24.04	0.48	20.76	10.16	1.07	81701.42
16	7.48	4.00	42.12	1.13	17.68	11.45	1.08	74853.24
17	6.31	5.96	48.33	1.01	18.86	11.36	1.09	74780.33
18	2.49	7.94	63.51	0.74	18.38	11.88	1.07	71263.19
19	3.83	9.75	60.30	0.58	18.42	11.95	1.09	70576.32
20	8.75	5.77	34.60	0.89	18.12	11.16	1.05	76360.32
21	8.21	7.73	44.07	1.12	17.91	11.17	1.05	76405.67
22	7.96	8.10	45.89	0.88	17.51	11.44	1.05	75121.84
23	8.74	8.04	48.39	0.82	17.97	11.35	1.04	74846.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.38	7.86	51.14	0.56	19.40	11.08	1.06	74332.91
最大值	10.09	12.91	70.55	1.13	21.71	12.11	1.19	81701.42
發生時間	15	0	12	16	1	0		15
最小值	1.48	4.00	24.04	0.21	17.51	10.16	1.02	67797.43
發生時間	0	16	15	5	22	15		0
零點偏移(率)	-0.07 %	0.00 %	-0.04 %	0.00 %		-0.14		0.00 %
全幅偏移(率)	0.00 %	0.36 %	-0.05 %	0.64 %		0.01		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月10日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.12	7.12	61.18	1.43	17.11	10.69	0.99	82369.12
1	4.39	6.36	57.87	1.75	17.72	10.52	0.99	82452.44
2	3.97	4.27	60.53	1.16	18.09	10.20	0.99	85113.79
3	7.86	4.06	59.57	1.25	18.61	9.82	0.99	87654.86
4	5.02	5.12	55.09	1.63	17.41	10.48	0.99	83498.75
5	4.65	4.62	47.99	1.64	18.08	10.06	0.99	85685.82
6	3.11	2.31	50.44	1.41	19.04	9.60	0.99	85454.40
7	2.89	3.56	55.04	1.23	18.48	10.20	0.99	83753.42
8	6.80	3.94	48.28	1.53	18.85	9.69	0.99	87343.33
9	5.76	4.85	44.12	1.78	17.91	10.01	1.02	85456.49
10	6.29	2.51	51.29	1.37	18.31	9.81	1.03	86434.56
11	5.51	3.92	54.14	1.20	18.72	9.67	1.02	87030.66
12	2.05	5.81	44.13	2.15	17.05	10.39	1.01	83313.79
13	1.33	4.71	54.12	2.19	17.60	10.27	1.02	84350.13
14	8.86	1.67	55.21	2.52	17.23	10.36	1.01	83989.24
15	7.68	3.72	51.46	2.26	17.30	10.20	1.01	85034.39
16	4.16	6.20	53.48	1.99	17.74	9.87	0.99	87748.98
17	5.21	5.88	56.37	2.01	16.73	10.37	0.98	84177.44
18	11.39	8.86	49.97	2.70	17.06	10.12	0.99	85985.34
19	9.50	4.39	55.96	2.10	17.13	9.92	1.00	87297.30
20	8.73	2.80	53.63	2.68	16.15	10.26	1.02	85688.86
21	10.37	7.63	59.94	1.89	16.51	10.19	1.02	86165.00
22	7.86	12.74	53.29	1.66	16.59	10.36	1.00	84736.26
23	8.54	5.84	59.48	1.90	16.48	10.40	1.00	84423.78
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.13	5.12	53.86	1.81	17.58	10.14	1.00	85214.92
最大值	11.39	12.74	61.18	2.70	19.04	10.69	1.04	87748.98
發生時間	18	22	0	18	6	0		16
最小值	1.33	1.67	44.12	1.16	16.15	9.60	0.98	82369.12
發生時間	13	14	9	2	20	6		0
零點偏移(率)	0.00 %	-0.01 %	-0.01 %	0.00 %		0.03		-0.20 %
全幅偏移(率)	0.02 %	-0.50 %	-0.04 %	0.25 %		-0.05		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月10日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.12	6.68	60.17	1.32	16.09	11.14	1.01	78820.39
1	7.22	20.30	52.69	1.20	18.34	10.45	1.01	84263.72
2	5.55	3.22	58.47	1.53	15.43	11.08	1.00	75899.15
3	7.50	3.64	54.49	1.64	16.38	10.55	0.99	77557.39
4	7.89	4.84	46.96	1.76	15.19	10.97	1.00	77070.05
5	7.14	3.64	54.74	2.08	14.86	11.07	1.02	78376.42
6	7.92	5.71	58.00	2.11	14.70	11.25	1.02	76145.19
7	6.13	3.01	51.36	1.66	15.63	11.44	0.99	77688.89
8	6.16	8.58	46.75	1.34	16.79	10.50	0.99	75611.84
9	4.88	5.29	56.23	1.31	17.05	10.61	0.99	76709.03
10	6.58	4.98	36.42	1.26	18.21	9.67	0.98	79824.07
11	5.97	3.71	38.56	1.13	16.84	10.21	1.00	74386.76
12	2.00	3.01	46.39	0.68	17.48	10.46	1.00	71063.58
13	0.17	7.59	39.01	2.87	17.75	9.80	0.97	79799.94
14	2.15	10.19	42.68	1.26	15.92	10.32	0.97	74426.15
15	7.90	4.80	35.75	2.20	14.49	10.45	0.94	70590.38
16	7.44	3.13	53.53	2.14	14.60	11.06	0.97	75914.16
17	8.77	4.80	54.41	1.94	14.85	11.08	0.97	76823.67
18	4.31	4.69	52.69	1.11	16.91	10.63	0.97	79098.23
19	6.83	9.72	46.14	1.43	16.64	10.49	0.97	81964.29
20	10.67	8.97	47.04	2.06	15.98	10.40	0.97	80104.95
21	7.77	11.92	47.20	2.03	15.03	10.58	0.97	77492.92
22	8.54	3.68	52.29	2.25	14.36	11.08	0.97	76917.01
23	10.85	14.82	54.55	3.07	13.92	11.42	0.99	75219.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.60	6.70	49.44	1.72	15.98	10.70	0.98	77156.99
最大值	10.85	20.30	60.17	3.07	18.34	11.44	1.02	84263.72
發生時間	23	1	0	23	1	7		1
最小值	0.17	3.01	35.75	0.68	13.92	9.67	0.93	70590.38
發生時間	13	7	15	12	23	10		15
零點偏移(率)	-0.01 %	-0.04 %	-0.10 %	-0.03 %		0.02		0.00 %
全幅偏移(率)	0.04 %	0.50 %	-0.55 %	0.21 %		0.21		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								