

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月07日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.41	12.03	47.44	1.50	16.11	11.66	1.25	78754.01
1	8.19	12.63	56.52	1.98	15.79	12.15	1.26	73794.91
2	8.26	12.93	57.76	1.94	17.04	12.23	1.25	71972.80
3	12.94	11.68	44.99	1.99	16.84	11.23	1.26	80564.64
4	11.88	11.67	57.06	2.42	15.42	11.47	1.26	79199.98
5	13.35	11.56	45.08	2.20	15.27	11.71	1.30	76867.84
6	8.33	12.00	44.30	1.85	14.95	11.93	1.30	75480.39
7	11.46	11.60	39.92	1.55	16.21	11.51	1.30	79751.70
8	8.64	12.00	41.99	1.50	15.73	11.49	1.30	79660.73
9	7.21	13.34	64.33	1.14	15.85	11.76	1.31	76338.83
10	12.08	13.08	62.00	1.56	16.22	11.45	1.33	79501.02
11	7.54	13.37	47.24	1.05	16.42	11.79	1.31	77684.36
12	8.68	13.46	61.65	1.05	17.08	11.80	1.28	78484.18
13	10.60	13.30	46.07	1.60	16.00	11.57	1.28	80796.29
14	9.29	13.31	47.50	1.61	16.13	11.71	1.27	78129.41
15	7.95	12.79	65.19	1.33	17.00	11.93	1.29	75283.41
16	10.84	12.06	55.48	2.41	16.46	11.15	1.30	82567.67
17	10.04	12.41	51.24	3.14	14.85	11.59	1.31	79715.45
18	7.04	12.56	56.88	1.24	17.04	11.90	1.30	77223.75
19	12.70	13.36	59.12	1.39	17.41	11.67	1.29	79013.61
20	9.47	13.85	61.44	1.45	17.04	11.98	1.29	76000.68
21	7.45	13.22	52.39	0.94	18.40	11.22	1.29	81970.92
22	9.62	13.72	50.34	1.35	17.47	11.39	1.29	80487.26
23	10.23	13.25	45.96	1.41	17.34	11.16	1.29	82169.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.67	12.72	52.58	1.65	16.42	11.64	1.29	78392.23
最大值	13.35	13.85	65.19	3.14	18.40	12.23	1.53	82567.67
發生時間	5	20	15	17	21	2		16
最小值	7.04	11.56	39.92	0.94	14.85	11.15	1.25	71972.80
發生時間	18	5	7	21	17	16		2
零點偏移(率)	-0.08 %	0.00 %	-0.03 %	-0.01 %		-0.05	-0.01	0.40 %
全幅偏移(率)	0.20 %	-1.06 %	-1.26 %	-0.07 %		0.10	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月07日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.26	12.46	49.61	1.79	17.86	10.93	0.97	76195.36
1	9.33	12.55	56.82	1.43	18.84	10.93	0.97	78220.91
2	10.61	11.82	45.16	3.30	17.48	10.47	0.97	81709.10
3	8.61	11.92	51.73	2.05	17.36	10.58	0.97	81078.34
4	8.99	12.06	45.59	2.26	17.35	10.28	0.99	78502.56
5	8.52	11.65	41.39	1.79	17.93	9.94	0.97	77941.79
6	15.69	9.51	38.17	3.51	16.34	10.29	0.97	77743.92
7	8.47	9.30	50.53	2.27	16.54	10.62	0.98	77103.02
8	6.88	12.04	44.74	1.68	18.22	10.23	0.98	79600.24
9	10.32	12.68	58.09	1.83	17.47	10.31	0.98	77546.19
10	9.96	12.57	60.63	2.15	16.48	10.25	0.98	77913.41
11	10.13	12.61	59.13	2.09	16.41	10.36	0.98	78766.25
12	9.51	13.29	59.16	3.08	15.44	10.93	0.99	78521.13
13	6.81	13.73	57.32	2.95	15.08	11.10	0.98	76086.58
14	11.54	12.94	45.46	3.04	17.28	10.22	0.97	77736.34
15	9.87	12.78	53.73	2.23	17.55	10.94	0.96	74295.71
16	9.55	12.51	51.98	2.75	15.34	10.96	0.98	80048.88
17	6.64	12.64	56.75	2.86	13.73	11.08	1.01	78220.75
18	10.86	12.05	59.37	1.60	16.87	10.86	1.02	78722.50
19	8.22	11.40	49.39	1.56	19.44	9.61	1.02	83278.63
20	10.11	11.34	47.48	1.66	18.18	10.09	1.02	80392.84
21	7.85	11.88	51.86	1.87	16.90	10.57	1.02	79540.25
22	8.88	11.91	51.74	1.14	18.10	10.45	1.02	81173.99
23	9.60	11.93	47.00	1.11	19.53	10.16	1.02	77960.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.34	12.07	51.37	2.17	17.16	10.51	0.99	78679.15
最大值	15.69	13.73	60.63	3.51	19.53	11.10	1.02	83278.63
發生時間	6	13	10	6	23	13		19
最小值	6.64	9.30	38.17	1.11	13.73	9.61	0.94	74295.71
發生時間	17	7	6	23	17	19		15
零點偏移(率)	-0.06 %	-0.01 %	-0.07 %	-0.01 %		-0.03	-0.01	0.00 %
全幅偏移(率)	-1.80 %	-1.28 %	-0.33 %	-0.23 %		0.13	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月07日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.87	11.74	59.85	3.28	18.48	10.22	1.40	76217.09
1	4.14	12.29	63.94	3.04	18.66	10.71	1.40	72272.74
2	4.13	11.44	53.14	2.94	18.29	9.94	1.40	77675.05
3	6.46	12.53	48.52	3.28	16.38	9.69	1.39	80182.97
4	7.19	12.53	62.05	3.34	15.40	10.89	1.39	73125.00
5	8.06	12.42	59.97	3.08	16.10	10.50	1.40	77004.56
6	8.64	11.70	59.60	3.06	15.70	10.61	1.41	76280.08
7	5.86	13.29	51.72	3.50	14.91	10.64	1.38	70852.91
8	7.84	12.00	52.25	2.42	15.94	10.55	1.39	75054.80
9	10.90	11.61	55.36	1.75	16.12	10.36	1.38	75374.18
10	9.92	11.85	53.46	1.77	15.33	10.28	1.37	74538.42
11	8.65	11.88	56.85	1.62	15.51	10.52	1.40	75430.10
12	8.68	11.86	52.61	1.67	15.39	10.56	1.40	74908.87
13	9.90	14.46	50.74	2.37	13.06	10.58	1.39	72913.05
14	9.83	12.21	48.80	2.19	14.59	10.25	1.39	73267.82
15	7.64	11.67	54.39	3.01	18.19	9.92	1.37	74596.29
16	7.76	11.90	51.57	2.80	17.16	9.98	1.36	74573.85
17	8.26	12.87	55.67	3.37	13.45	10.25	1.36	73897.94
18	10.11	11.08	46.46	2.52	17.66	9.53	1.37	73517.77
19	9.70	11.12	44.17	2.22	17.48	9.28	1.36	75413.57
20	7.56	11.08	53.71	2.06	16.03	9.70	1.36	73222.42
21	9.85	11.15	53.89	2.15	17.20	9.45	1.36	74819.82
22	7.67	11.79	57.40	2.93	16.96	9.70	1.36	76853.67
23	7.32	11.29	60.85	3.11	18.41	9.61	1.38	76825.45
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.08	11.99	54.46	2.64	16.35	10.15	1.38	74950.77
最大值	10.90	14.46	63.94	3.50	18.66	10.89	1.41	80182.97
發生時間	9	13	1	7	1	4		3
最小值	4.13	11.08	44.17	1.62	13.06	9.28	1.36	70852.91
發生時間	2	18	19	11	13	19		7
零點偏移(率)	-0.01 %	-0.04 %	-0.01 %	0.00 %		-0.05	-0.01	0.00 %
全幅偏移(率)	0.90 %	-0.71 %	-0.21 %	-0.04 %		0.15	0.04	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								