

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月28日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.40	9.75	50.24	1.07	16.43	11.77	1.01	70630.21
1	5.39	8.88	57.60	1.07	17.46	12.04	1.01	68832.12
2	5.71	5.44	48.34	0.94	19.68	10.75	1.02	76831.47
3	5.07	5.14	46.65	1.40	16.67	11.55	1.03	73488.41
4	3.16	7.26	44.39	0.84	18.25	11.35	1.00	73520.20
5	7.70	7.19	37.35	1.85	15.69	12.09	1.01	71791.18
6	8.30	8.48	43.90	1.33	17.09	11.63	1.02	72797.61
7	8.96	8.12	42.40	1.42	17.04	11.62	1.02	72774.55
8	8.26	6.24	49.92	1.09	17.74	11.84	1.05	70530.50
9	8.93	6.16	43.90	0.98	18.18	11.47	1.05	72933.55
10	7.80	7.07	47.64	0.73	19.03	11.18	1.03	74623.39
11	9.24	5.67	50.49	1.21	17.09	11.51	1.05	73032.91
12	8.69	9.94	41.55	1.01	17.82	11.61	1.06	71953.18
13	6.61	11.64	40.16	0.87	18.16	11.56	1.04	72322.91
14	3.72	7.13	45.47	0.76	18.86	11.22	1.03	73828.60
15	5.71	6.92	50.74	1.01	18.06	11.82	1.05	70742.99
16	5.02	6.73	58.91	0.71	18.67	11.54	1.05	72352.29
17	2.96	7.11	47.96	0.69	18.83	10.94	1.03	76399.82
18	3.93	10.06	46.29	0.97	18.30	11.46	1.02	73060.37
19	5.32	9.57	49.21	0.70	18.55	11.31	1.03	74660.00
20	6.41	12.08	55.24	0.77	19.04	11.36	1.05	73670.99
21	6.11	11.65	56.30	0.52	19.54	11.05	1.05	75269.85
22	6.86	11.53	54.53	0.51	19.42	11.24	1.05	74344.66
23	7.68	12.59	48.77	0.75	19.44	11.27	1.05	73567.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.46	8.43	48.25	0.97	18.13	11.47	1.03	73081.62
最大值	9.24	12.59	58.91	1.85	19.68	12.09	1.08	76831.47
發生時間	11	23	16	5	2	5		2
最小值	2.96	5.14	37.35	0.51	15.69	10.75	0.99	68832.12
發生時間	17	3	5	22	5	2		1
零點偏移(率)	0.00 %	-0.01 %	-0.01 %	-0.00 %		-0.04		0.00 %
全幅偏移(率)	0.02 %	0.71 %	0.18 %	0.10 %		0.08		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月28日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.26	9.84	51.27	0.60	19.14	9.74	1.02	87095.85
1	6.11	6.96	63.68	0.74	19.35	10.15	1.01	84573.76
2	6.77	4.75	53.68	1.39	17.55	10.20	1.01	86115.12
3	1.68	6.89	54.68	1.41	16.52	10.45	1.02	85301.39
4	13.54	7.24	46.64	2.60	15.66	10.46	1.02	85826.52
5	8.95	4.05	52.63	2.84	15.15	10.75	1.02	84314.10
6	5.18	5.78	61.19	1.64	14.96	10.89	1.01	86358.58
7	5.22	6.97	49.80	1.86	15.17	10.86	1.02	83784.61
8	6.96	4.24	54.61	1.48	16.92	10.54	1.01	84134.82
9	8.83	8.38	47.96	0.92	18.66	9.62	1.02	88678.67
10	8.50	11.61	50.56	1.73	15.98	11.33	1.02	77740.53
11	10.05	5.44	49.07	1.63	16.47	10.98	1.03	80634.87
12	6.82	1.99	52.57	1.22	17.51	10.35	1.02	84386.48
13	9.05	8.11	44.74	2.05	16.47	10.30	1.02	85958.34
14	8.85	3.38	49.05	1.98	15.33	10.89	1.01	82753.59
15	8.30	13.47	41.78	1.95	14.93	10.98	1.01	82351.77
16	1.84	1.24	59.82	1.29	15.46	11.42	1.07	78096.92
17	4.60	4.95	56.56	1.18	17.46	9.74	1.04	89852.93
18	3.70	4.90	52.25	1.69	16.93	10.20	1.00	86661.77
19	1.36	7.45	47.09	1.59	17.98	9.91	1.00	87600.25
20	4.02	6.61	51.93	2.09	16.39	10.08	1.00	87951.13
21	2.89	6.13	51.26	1.07	18.43	10.17	1.00	85129.81
22	3.76	6.55	47.15	1.32	18.38	9.79	0.99	87747.67
23	3.66	4.71	50.22	1.73	17.71	10.33	0.99	84879.44
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.16	6.32	51.67	1.58	16.85	10.42	1.01	84913.71
最大值	13.54	13.47	63.68	2.84	19.35	11.42	1.13	89852.93
發生時間	4	15	1	5	1	16		17
最小值	1.36	1.24	41.78	0.60	14.93	9.62	0.99	77740.53
發生時間	19	16	15	0	15	9		10
零點偏移(率)	0.00 %	-0.00 %	-0.09 %	-0.00 %		0.01		-0.20 %
全幅偏移(率)	0.04 %	0.59 %	-0.40 %	0.21 %		-0.01		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月28日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.89	3.14	51.94	1.35	16.51	9.47	0.91	76678.15
1	9.76	4.35	51.57	1.65	16.28	9.92	0.92	80835.02
2	10.16	5.66	50.69	1.78	17.75	10.26	0.92	81914.14
3	6.45	5.45	57.14	2.38	14.62	10.96	0.94	77098.73
4	8.89	5.93	47.19	1.47	17.83	10.31	0.94	81395.41
5	9.86	8.45	35.91	2.93	15.52	10.05	0.94	80064.66
6	6.24	10.49	37.37	2.53	14.01	10.77	0.93	72593.17
7	8.21	8.32	44.81	2.13	15.38	10.17	0.92	76469.68
8	10.13	0.62	42.62	2.58	14.56	10.20	0.96	78208.24
9	4.07	2.74	54.03	1.27	16.39	10.23	0.92	73879.14
10	7.88	3.99	51.82	1.75	15.89	10.46	0.95	76490.46
11	2.40	5.90	49.06	1.21	15.45	11.20	0.97	72020.16
12	6.24	8.58	39.86	1.87	14.64	10.80	0.92	73631.21
13	4.54	6.77	54.91	1.58	14.67	11.26	0.90	69872.95
14	1.35	2.37	60.52	1.03	15.73	10.45	0.91	75458.35
15	1.72	4.90	55.94	1.60	14.24	11.03	0.93	70502.46
16	0.52	5.79	57.93	1.00	15.44	10.86	0.98	76938.92
17	1.15	6.52	59.53	0.83	16.55	10.10	0.97	80947.39
18	2.87	4.49	53.27	1.58	14.73	10.49	0.92	78530.62
19	4.71	5.53	56.69	0.99	16.23	10.46	0.96	80213.23
20	6.63	12.30	50.47	1.37	15.26	10.67	0.97	78966.37
21	6.40	7.29	51.38	1.48	15.18	10.81	0.96	76279.67
22	7.26	10.28	47.90	1.19	15.98	10.55	0.97	82662.35
23	6.97	5.11	61.57	1.18	15.78	11.26	0.97	75192.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.85	6.04	51.01	1.61	15.61	10.53	0.94	76951.79
最大值	10.16	12.30	61.57	2.93	17.83	11.26	1.09	82662.35
發生時間	2	20	23	5	4	13		22
最小值	0.52	0.62	35.91	0.83	14.01	9.47	0.89	69872.95
發生時間	16	8	5	17	6	0		13
零點偏移(率)	-0.02 %	0.00 %	-0.10 %	0.00 %		0.00		0.00 %
全幅偏移(率)	0.01 %	0.20 %	-0.64 %	0.25 %		0.41		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								