

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月16日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.09	13.19	61.71	3.10	19.03	11.50	1.23	78146.08
1	9.29	11.66	32.10	3.45	21.26	9.99	1.23	88196.56
2	11.51	12.15	52.17	2.71	20.14	9.94	1.24	89751.83
3	8.16	11.82	46.14	3.32	17.73	10.48	1.23	88004.78
4	10.17	12.45	52.76	2.52	17.00	11.24	1.23	82662.47
5	8.84	13.07	60.54	2.22	17.45	11.42	1.25	82560.03
6	9.66	13.36	61.38	2.22	16.35	11.78	1.25	78333.54
7	12.32	13.29	59.15	2.31	17.02	11.69	1.25	78714.95
8	7.17	12.66	54.93	2.03	17.37	10.96	1.25	84573.16
9	11.88	12.99	54.12	2.48	16.73	11.44	1.24	80861.42
10	5.05	13.02	55.26	1.99	16.11	11.52	1.25	80926.39
11	11.12	13.63	59.41	2.68	15.61	11.74	1.24	79310.42
12	7.65	13.40	63.54	2.00	16.55	11.70	1.24	78563.82
13	9.94	12.83	57.30	1.92	18.21	10.98	1.24	83225.97
14	9.26	14.06	54.33	2.55	16.03	11.63	1.25	79114.90
15	9.01	13.46	49.65	2.41	16.51	11.53	1.24	79459.91
16	11.81	12.52	56.37	2.88	17.74	11.21	1.22	82021.10
17	6.31	12.49	55.19	1.75	17.70	11.15	1.23	82591.11
18	9.64	12.49	59.77	1.87	18.07	11.12	1.25	81977.38
19	9.99	12.48	60.22	2.05	17.98	10.96	1.24	83677.25
20	11.13	13.20	52.78	3.95	17.34	11.15	1.24	82343.69
21	12.10	12.54	57.01	1.90	18.36	10.71	1.23	84872.02
22	5.48	12.26	60.99	1.25	19.51	10.53	1.23	85310.03
23	8.84	12.55	63.62	2.93	19.03	10.87	1.23	83298.21
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.27	12.82	55.85	2.44	17.70	11.14	1.24	82437.38
最大值	12.32	14.06	63.62	3.95	21.26	11.78	1.25	89751.83
發生時間	7	14	23	20	1	6		2
最小值	5.05	11.66	32.10	1.25	15.61	9.94	1.20	78146.08
發生時間	10	1	1	22	11	2		0
零點偏移(率)	-0.22 %	-0.01 %	-0.31 %	-0.01 %		-0.03	-0.01	0.10 %
全幅偏移(率)	-0.16 %	-0.70 %	-0.03 %	-0.47 %		0.08	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月16日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.86	12.31	41.64	0.94	21.30	9.82	0.97	87433.78
1	4.15	12.01	42.14	1.49	20.80	9.76	0.94	88809.40
2	14.12	12.42	37.78	2.32	18.31	10.57	0.96	85184.33
3	5.54	12.00	53.83	1.36	18.26	10.62	0.94	85601.18
4	11.37	12.03	47.63	2.55	17.38	10.75	0.95	85069.20
5	11.02	12.21	38.18	2.06	17.61	10.79	0.96	84243.00
6	4.95	12.54	43.77	1.00	18.09	11.10	0.91	83676.35
7	9.05	12.58	51.00	1.35	18.26	10.86	0.91	82980.88
8	9.04	12.31	51.44	2.09	18.50	10.69	0.93	84520.40
9	12.03	12.71	53.54	2.70	18.30	10.69	0.92	84298.60
10	9.89	12.04	55.74	2.34	19.38	10.44	0.93	85351.39
11	8.11	12.18	50.56	1.55	18.85	10.55	0.93	84576.52
12	9.07	12.20	53.22	1.26	19.12	10.56	0.95	83740.64
13	7.39	12.61	44.16	1.19	19.11	10.67	0.93	83141.68
14	11.21	12.42	50.03	1.76	19.02	10.72	0.92	83117.89
15	5.43	12.52	56.48	2.39	17.32	11.15	0.93	85586.47
16	10.99	12.15	48.54	2.01	17.78	10.68	0.94	84850.95
17	5.09	11.94	54.81	1.43	18.89	10.41	0.94	86081.98
18	15.16	12.57	51.47	1.90	19.30	10.19	0.93	87063.74
19	14.80	12.94	58.77	3.06	17.16	10.88	0.92	83539.33
20	11.02	12.38	58.81	1.48	17.73	10.95	0.90	82124.03
21	5.99	12.29	55.69	0.60	19.53	10.49	0.90	84448.22
22	7.55	11.85	59.94	0.39	20.44	10.14	0.91	86212.97
23	9.41	11.87	52.32	0.47	20.46	10.16	0.92	86453.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.18	12.30	50.48	1.65	18.79	10.57	0.93	84921.11
最大值	15.16	12.94	59.94	3.06	21.30	11.15	0.99	88809.40
發生時間	18	19	22	19	0	15		1
最小值	4.15	11.85	37.78	0.39	17.16	9.76	0.90	82124.03
發生時間	1	22	2	22	19	1		20
零點偏移(率)	-0.06 %	0.01 %	-0.11 %	-0.01 %		-0.05	-0.01	-0.20 %
全幅偏移(率)	0.14 %	0.05 %	0.14 %	0.14 %		-0.03	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月16日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.03	11.33	51.76	3.12	20.57	9.37	1.27	71940.30
1	2.74	11.94	39.65	2.95	22.80	8.51	1.27	78602.64
2	2.78	11.54	42.12	2.01	21.49	8.60	1.27	77677.49
3	6.31	10.68	48.69	0.70	19.14	9.09	1.27	75861.80
4	3.92	10.69	47.47	0.64	19.01	8.95	1.27	76502.56
5	6.67	10.61	49.95	0.66	18.62	9.20	1.26	74603.63
6	8.03	10.97	47.74	0.70	18.79	9.00	1.26	75787.74
7	8.99	11.26	43.47	3.23	19.71	8.92	1.27	77123.29
8	7.89	10.97	45.09	2.86	18.86	9.01	1.30	75777.06
9	8.30	11.08	51.78	2.86	18.94	9.21	1.30	74632.61
10	8.31	11.37	50.16	2.89	18.06	9.25	1.27	74899.39
11	8.57	11.23	50.76	2.96	17.61	9.36	1.29	73735.98
12	9.36	10.90	56.70	3.21	18.63	9.20	1.28	74878.35
13	2.35	11.04	59.84	2.47	17.79	9.64	1.27	72104.31
14	3.14	12.16	51.14	2.61	18.03	9.65	1.26	70401.35
15	4.66	11.13	47.80	2.61	18.05	9.16	1.26	74925.81
16	10.24	11.02	56.59	3.28	18.55	9.25	1.30	75065.99
17	8.00	11.09	60.47	2.88	18.57	9.49	1.27	73579.90
18	7.02	11.25	59.26	2.79	18.45	9.74	1.27	71401.13
19	2.87	10.75	47.45	2.51	18.93	9.00	1.30	73253.80
20	4.82	10.94	51.07	2.71	18.69	9.09	1.31	76159.02
21	6.29	11.60	66.15	3.40	17.96	10.08	1.31	72337.42
22	3.14	11.54	48.45	2.83	20.29	9.74	1.30	69380.21
23	3.00	11.30	56.58	2.56	20.89	9.19	1.28	72656.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.81	11.18	51.26	2.48	19.10	9.24	1.28	74303.67
最大值	10.24	12.16	66.15	3.40	22.80	10.08	1.32	78602.64
發生時間	16	14	21	21	1	21		1
最小值	2.03	10.61	39.65	0.64	17.61	8.51	1.25	69380.21
發生時間	0	5	1	4	11	1		22
零點偏移(率)	-0.10 %	-0.00 %	-0.19 %	-0.01 %		-0.04	-0.01	-0.20 %
全幅偏移(率)	0.17 %	-1.61 %	0.71 %	-0.16 %		0.11	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								