

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月18日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.32	11.81	47.31	1.36	19.33	11.01	1.23	74652.19
1	6.29	11.66	56.22	1.13	20.04	10.87	1.23	74420.15
2	6.28	12.04	51.14	1.60	19.74	10.86	1.23	75232.98
3	6.51	12.00	49.72	2.38	17.23	11.48	1.23	72768.71
4	6.63	11.85	55.14	2.62	17.40	11.37	1.23	73552.65
5	6.15	13.14	56.92	3.06	17.21	11.58	1.25	77537.59
6	6.53	13.02	54.72	2.85	16.94	11.53	1.25	72897.78
7	6.19	12.79	56.82	1.95	19.30	10.72	1.25	76625.55
8	6.28	12.63	58.42	2.38	17.60	11.08	1.25	74978.87
9	6.39	12.77	60.86	2.17	17.73	11.26	1.25	73159.06
10	6.33	12.65	59.86	2.45	18.02	11.13	1.27	74566.22
11	6.21	12.43	58.63	1.31	19.58	10.75	1.26	75866.63
12	6.26	12.50	61.85	2.25	18.39	10.95	1.25	75131.34
13	6.41	12.97	58.06	3.50	16.36	11.37	1.25	73830.95
14	6.93	13.53	57.71	4.45	15.35	11.71	1.25	72396.19
15	6.92	13.58	54.98	4.13	15.38	11.91	1.25	70523.32
16	6.47	12.36	55.83	2.24	16.82	11.48	1.25	73231.62
17	6.61	11.84	51.33	2.31	15.95	11.63	1.25	72927.57
18	7.94	12.30	54.93	1.77	18.85	10.83	1.24	76365.69
19	6.65	11.89	57.94	1.85	17.47	11.33	1.25	74499.37
20	7.48	12.51	59.33	2.66	15.72	11.47	1.25	74626.13
21	6.91	11.39	58.77	1.71	18.88	10.83	1.25	76871.88
22	6.67	11.48	55.60	1.44	18.43	11.05	1.25	75060.30
23	6.72	11.71	51.90	1.61	18.73	11.04	1.25	74642.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.59	12.37	56.00	2.30	17.77	11.22	1.25	74431.89
最大值	7.94	13.58	61.85	4.45	20.04	11.91	1.28	77537.59
發生時間	18	15	12	14	1	15		5
最小值	6.15	11.39	47.31	1.13	15.35	10.72	1.22	70523.32
發生時間	5	21	0	1	14	7		15
零點偏移(率)	-0.09 %	-0.00 %	-0.02 %	-0.00 %		-0.09	-0.01	0.20 %
全幅偏移(率)	1.34 %	0.27 %	0.16 %	0.05 %		-0.04	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月18日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.27	12.48	46.42	0.75	18.29	10.97	0.97	78637.60
1	6.77	13.56	60.82	1.02	18.16	11.57	0.98	74818.67
2	6.32	12.45	62.81	1.33	17.98	10.99	0.97	82660.80
3	6.18	12.32	49.04	1.12	17.95	10.79	0.98	80292.15
4	6.14	12.67	46.41	1.55	18.17	10.43	0.97	79927.98
5	6.21	12.77	47.63	1.83	17.49	11.00	0.98	78681.44
6	7.20	11.21	43.68	1.20	17.28	10.89	0.97	80282.88
7	7.44	11.17	39.34	1.71	17.51	10.69	0.97	79549.36
8	7.31	11.44	50.89	1.99	16.79	10.95	0.97	79134.05
9	6.94	11.02	43.66	2.01	17.48	10.30	0.95	79268.35
10	6.83	10.65	40.65	1.81	17.20	10.19	0.94	77862.91
11	6.87	10.66	42.35	1.90	16.52	10.27	0.95	75826.98
12	6.86	10.75	41.27	1.55	16.93	10.13	0.95	76948.61
13	6.95	10.76	40.93	1.51	16.33	10.38	0.94	74851.20
14	6.86	11.16	46.60	1.70	17.78	9.87	0.94	76981.50
15	6.79	10.31	46.16	1.12	17.89	9.92	0.94	76811.21
16	6.99	11.20	46.73	1.27	16.66	10.49	0.95	78825.84
17	7.00	11.73	44.20	1.33	16.56	10.57	0.94	79115.87
18	6.89	11.51	51.96	0.50	17.76	10.24	0.94	77757.84
19	6.80	11.32	44.90	0.58	18.16	9.99	0.96	80422.70
20	7.13	12.13	39.13	1.50	16.25	10.78	0.96	79123.21
21	7.24	12.04	55.80	0.94	17.30	10.75	0.94	82221.98
22	7.10	11.76	62.52	0.42	18.27	10.40	0.94	80654.57
23	7.13	11.85	52.27	0.61	18.58	10.40	0.94	76093.17
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.84	11.62	47.76	1.30	17.47	10.54	0.96	78614.62
最大值	7.44	13.56	62.81	2.01	18.58	11.57	1.00	82660.80
發生時間	7	1	2	9	23	1		2
最小值	6.14	10.31	39.13	0.42	16.25	9.87	0.94	74818.67
發生時間	4	15	20	22	20	14		1
零點偏移(率)	-0.09 %	-0.01 %	-0.04 %	0.00 %		-0.09	-0.01	0.00 %
全幅偏移(率)	2.19 %	-0.60 %	0.60 %	0.07 %		-0.01	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月18日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.35	11.76	57.08	3.12	16.95	10.43	1.34	72565.42
1	3.84	11.60	55.62	2.95	18.63	10.11	1.35	73068.54
2	3.24	11.69	58.60	3.22	18.87	10.16	1.35	74600.43
3	5.40	11.79	58.41	3.36	17.46	9.89	1.34	72834.42
4	5.81	12.14	58.20	3.47	16.92	10.09	1.35	72209.74
5	4.66	11.68	55.03	3.22	18.53	9.98	1.36	73834.38
6	5.11	11.50	53.62	3.26	18.72	9.90	1.36	75319.16
7	3.25	10.69	56.22	3.63	18.44	10.13	1.35	78017.79
8	3.93	10.42	55.75	3.14	18.01	10.05	1.34	73933.48
9	3.42	11.52	47.74	3.21	18.63	9.29	1.36	72223.84
10	3.66	11.00	43.32	3.04	19.02	8.88	1.38	70452.44
11	3.42	9.94	43.25	2.90	19.43	8.90	1.35	70514.56
12	3.27	10.35	39.33	2.81	19.55	8.59	1.36	70835.33
13	3.29	11.61	35.14	2.85	19.89	8.30	1.36	70548.23
14	3.87	10.95	37.32	2.96	18.68	8.85	1.36	71496.96
15	4.03	10.83	42.42	2.89	19.19	8.96	1.35	71027.13
16	6.18	11.52	47.88	2.78	19.17	9.03	1.33	74393.97
17	6.76	10.91	58.83	2.08	18.28	9.64	1.33	73871.91
18	6.69	10.89	55.56	2.07	18.41	9.59	1.32	73328.00
19	6.81	11.42	55.46	2.06	17.77	9.76	1.34	72897.10
20	6.79	11.33	59.31	2.04	16.95	9.93	1.36	72787.25
21	6.37	11.61	56.77	2.07	17.59	9.97	1.36	75040.29
22	6.00	11.15	60.21	2.13	16.26	10.49	1.36	74343.66
23	6.42	11.96	56.29	2.08	18.45	10.48	1.36	74809.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.86	11.26	51.97	2.81	18.32	9.64	1.35	73123.08
最大值	6.81	12.14	60.21	3.63	19.89	10.49	1.39	78017.79
發生時間	19	4	22	7	13	22		7
最小值	3.24	9.94	35.14	2.04	16.26	8.30	1.31	70452.44
發生時間	2	11	13	20	22	13		10
零點偏移(率)	-0.02 %	-0.00 %	-0.01 %	-0.01 %		-0.12	-0.01	-0.10 %
全幅偏移(率)	1.80 %	0.03 %	-0.21 %	0.14 %		0.20	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								