

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月15日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.10	11.14	58.97	2.58	15.84	11.97	1.23	69912.65
1	5.60	10.49	63.14	2.61	16.83	11.96	1.23	69556.26
2	3.40	10.44	64.33	2.94	14.95	12.13	1.25	69391.47
3	6.12	10.27	56.61	2.90	15.61	11.90	1.25	70574.99
4	3.15	8.47	66.49	2.85	14.92	12.25	1.25	68507.40
5	0.17	10.86	64.96	2.75	15.75	12.42	1.25	64495.08
6	1.85	10.14	54.48	3.05	14.93	11.85	1.25	71757.05
7	2.80	10.37	64.95	3.52	14.34	11.88	1.25	71947.87
8	4.73	14.76	62.27	3.90	13.78	12.20	1.25	69831.61
9	9.58	11.07	61.59	4.83	13.79	12.20	1.24	68860.72
10	8.32	11.49	51.70	5.12	14.21	12.08	1.25	68886.40
11	2.65	11.46	67.72	3.18	14.39	11.98	1.25	68008.24
12	5.42	11.83	59.39	4.18	13.10	12.18	1.23	69307.73
13	5.21	13.80	52.88	3.19	14.01	12.29	1.24	68521.17
14	12.34	12.28	56.52	2.69	12.66	12.50	1.25	66326.78
15	6.84	10.06	63.49	2.31	13.34	12.37	1.25	66781.77
16	8.82	9.79	54.57	2.02	14.40	11.96	1.25	71131.55
17	8.12	10.33	58.49	1.80	15.23	11.64	1.24	73122.96
18	7.22	10.37	45.43	1.99	13.90	12.07	1.24	70445.63
19	6.43	5.18	61.91	1.82	14.24	12.03	1.25	70727.53
20	7.13	6.89	55.40	2.02	13.89	12.03	1.25	71593.54
21	8.27	12.64	45.47	2.95	13.95	11.77	1.25	72829.17
22	5.94	9.64	50.89	3.63	12.15	12.66	1.25	67004.19
23	5.79	6.44	51.42	3.29	13.30	12.51	1.25	67608.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.92	10.43	58.04	3.01	14.31	12.12	1.25	69463.74
最 大 值	12.34	14.76	67.72	5.12	16.83	12.66	1.26	73122.96
發生時間	14	8	11	10	1	22		17
最 小 值	0.17	5.18	45.43	1.80	12.15	11.64	1.23	64495.08
發生時間	5	19	18	17	22	17		5
零點偏移(率)	-0.07 %	-0.01 %	-0.01 %	0.00 %		-0.02		0.10 %
全幅偏移(率)	0.00 %	-0.02 %	-0.06 %	0.00 %		0.43		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

