

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月16日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.52	6.85	54.90	0.72	16.13	11.90	0.97	79483.77
1	0.58	8.35	58.08	0.58	18.67	11.57	0.98	80523.20
2	8.27	8.36	37.35	1.14	17.22	11.01	0.94	86642.85
3	9.25	8.21	43.46	1.70	16.00	11.69	0.95	82396.31
4	9.50	7.14	47.83	1.72	15.05	11.96	0.97	80535.70
5	7.83	7.10	60.33	0.69	17.03	11.57	0.99	80197.84
6	9.41	6.49	53.24	1.39	15.80	11.60	1.02	83349.57
7	8.55	7.53	47.31	1.61	14.85	12.26	1.02	78177.50
8	5.83	3.49	51.74	0.63	16.92	11.66	1.02	81724.09
9	7.65	3.69	39.78	0.66	17.02	11.39	1.02	83775.31
10	6.40	3.65	35.33	0.92	16.47	11.77	1.02	81224.42
11	3.77	3.38	43.26	0.67	16.61	12.01	1.02	79286.76
12	7.53	3.48	39.21	0.97	16.56	11.28	1.01	85468.53
13	8.62	4.24	33.71	1.41	16.31	11.77	0.98	81162.43
14	8.83	3.62	28.86	1.32	15.69	11.66	0.97	82855.17
15	7.47	3.55	34.75	1.44	15.38	12.15	0.97	78976.73
16	9.11	3.46	52.52	1.23	16.13	11.54	0.99	83701.76
17	8.76	3.93	54.47	0.75	16.49	11.70	1.01	81849.37
18	3.27	3.78	53.02	0.45	17.91	11.56	1.04	81718.37
19	6.29	4.27	42.59	1.51	16.90	11.37	1.02	84163.00
20	7.94	5.77	46.62	2.25	15.13	11.81	1.02	81774.13
21	7.80	7.41	54.28	1.67	15.54	12.13	1.01	78437.13
22	9.29	3.62	49.19	1.38	15.48	11.49	0.97	84200.69
23	6.20	3.85	58.33	1.10	15.51	12.29	0.97	77316.40
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.19	5.22	46.67	1.16	16.28	11.71	0.99	81622.54
最 大 值	9.50	8.36	60.33	2.25	18.67	12.29	1.08	86642.85
發生時間	4	2	5	20	1	23		2
最 小 值	0.58	3.38	28.86	0.45	14.85	11.01	0.94	77316.40
發生時間	1	11	14	18	7	2		23
零點偏移(率)	-0.01 %	-0.00 %	-0.02 %	-0.00 %		-0.03		0.10 %
全幅偏移(率)	0.02 %	-0.09 %	0.08 %	0.20 %		-0.09		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

