

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月16日

| 項目 | #1-HCl_C | #1-CO_C | #1-NOx_C | #1-SO2_C | #1-H2O | #1-O2_C | #1-OPAC | #1-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 8.73 | 4.32 | 63.91 | 0.17 | 21.86 | 11.37 | 1.40 | 73720.98 |
| 1 | 9.71 | 3.18 | 60.24 | 0.19 | 22.78 | 11.15 | 1.39 | 74248.54 |
| 2 | 8.78 | 4.14 | 47.04 | 0.60 | 21.39 | 10.66 | 1.39 | 79203.44 |
| 3 | 2.34 | 14.12 | 70.03 | 1.68 | 17.29 | 13.84 | 1.61 | 58428.92 |
| 4 | 8.29 | 1.38 | 46.05 | 0.44 | 22.43 | 10.82 | 1.41 | 78065.89 |
| 5 | 11.25 | 2.23 | 67.03 | 0.06 | 23.20 | 10.32 | 1.41 | 86743.11 |
| 6 | 6.17 | 5.71 | 66.72 | 0.74 | 20.96 | 12.26 | 1.44 | 67778.99 |
| 7 | 0.94 | 9.95 | 55.40 | 1.08 | 20.21 | 12.61 | 1.51 | 65900.89 |
| 8 | 4.66 | 1.39 | 64.18 | 1.02 | 20.68 | 12.32 | 1.41 | 67894.10 |
| 9 | 9.10 | 1.90 | 40.56 | 0.22 | 23.18 | 10.39 | 1.41 | 80073.23 |
| 10 | 9.68 | 3.00 | 43.93 | 0.24 | 22.57 | 10.29 | 1.41 | 80874.05 |
| 11 | 8.51 | 3.60 | 46.52 | 1.08 | 19.33 | 11.74 | 1.43 | 73216.58 |
| 12 | 10.23 | 1.67 | 51.25 | 0.21 | 22.87 | 10.46 | 1.46 | 80654.76 |
| 13 | 9.70 | 0.97 | 44.90 | 0.71 | 21.10 | 10.78 | 1.46 | 78737.39 |
| 14 | 16.22 | 6.02 | 42.06 | 1.42 | 19.91 | 11.29 | 1.46 | 77889.70 |
| 15 | 14.69 | 2.05 | 51.31 | 1.20 | 20.10 | 11.31 | 1.46 | 76834.55 |
| 16 | 12.88 | 2.52 | 52.56 | 1.20 | 19.69 | 11.21 | 1.43 | 77881.50 |
| 17 | 8.88 | 0.93 | 58.12 | 0.82 | 20.69 | 11.21 | 1.43 | 76613.25 |
| 18 | 9.83 | 10.08 | 63.34 | 0.83 | 20.34 | 11.62 | 1.46 | 73866.20 |
| 19 | 9.97 | 5.75 | 63.15 | 0.76 | 20.82 | 11.60 | 1.45 | 73957.32 |
| 20 | 11.20 | 3.29 | 60.59 | 0.98 | 20.66 | 11.42 | 1.46 | 74163.52 |
| 21 | 14.99 | 8.29 | 51.71 | 4.12 | 17.78 | 11.97 | 1.46 | 73880.20 |
| 22 | 6.24 | 2.53 | 65.91 | 1.70 | 20.04 | 11.59 | 1.46 | 75377.24 |
| 23 | 9.58 | 2.70 | 55.76 | 1.07 | 20.75 | 11.19 | 1.47 | 77573.39 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 9.27 | 4.24 | 55.51 | 0.94 | 20.86 | 11.39 | 1.45 | 75149.07 |
| 最大值 | 16.22 | 14.12 | 70.03 | 4.12 | 23.20 | 13.84 | 1.92 | 86743.11 |
| 發生時間 | 14 | 3 | 3 | 21 | 5 | 3 | | 5 |
| 最小值 | 0.94 | 0.93 | 40.56 | 0.06 | 17.29 | 10.29 | 1.37 | 58428.92 |
| 發生時間 | 7 | 17 | 9 | 5 | 3 | 10 | | 3 |
| 零點偏移(率) | -0.04 % | -0.00 % | -0.06 % | -0.00 % | | 0.02 | 0.00 | 0.00 % |
| 全幅偏移(率) | -0.18 % | 0.50 % | -0.43 % | 0.43 % | | 0.14 | 0.00 | 0.30 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月16日

| 項目 | #2-HCl_C | #2-CO_C | #2-NOx_C | #2-SO2_C | #2-H2O | #2-O2_C | #2-OPAC | #2-FLOW_C |
|---------|----------|---------|----------|----------|---------|---------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 10.07 | 2.05 | 57.78 | 2.26 | 16.90 | 10.93 | 1.42 | 63613.29 |
| 1 | 10.17 | 2.04 | 56.08 | 2.17 | 18.59 | 10.50 | 1.44 | 65411.35 |
| 2 | 10.57 | 1.66 | 62.99 | 2.25 | 17.67 | 11.01 | 1.44 | 62874.25 |
| 3 | 9.16 | 0.95 | 57.52 | 1.74 | 18.77 | 10.63 | 1.43 | 64088.17 |
| 4 | 11.00 | 1.05 | 58.96 | 1.58 | 19.66 | 10.28 | 1.43 | 67111.86 |
| 5 | 9.09 | 1.16 | 53.86 | 1.52 | 19.38 | 10.31 | 1.44 | 66390.47 |
| 6 | 9.44 | 5.37 | 58.32 | 1.37 | 19.25 | 10.24 | 1.43 | 66915.86 |
| 7 | 8.52 | 0.48 | 61.02 | 1.21 | 19.63 | 10.48 | 1.43 | 65658.64 |
| 8 | 6.38 | 2.37 | 68.38 | 1.19 | 19.98 | 10.62 | 1.42 | 64238.48 |
| 9 | 校正 | 校正 | 校正 | 校正 | 替代 | 校正 | 1.42 | 74702.64 |
| 10 | 13.68 | 11.20 | 57.68 | 12.78 | 17.12 | 10.67 | 1.43 | 65787.41 |
| 11 | 13.42 | 10.25 | 50.39 | 6.74 | 14.71 | 12.21 | 1.41 | 57453.48 |
| 12 | 16.67 | 5.28 | 53.44 | 5.76 | 14.68 | 11.60 | 1.41 | 62711.96 |
| 13 | 8.97 | 7.55 | 54.70 | 7.54 | 13.26 | 12.14 | 1.39 | 60936.60 |
| 14 | 5.04 | 7.96 | 50.35 | 2.51 | 13.80 | 12.07 | 1.38 | 61973.31 |
| 15 | 14.75 | 10.14 | 60.34 | 2.16 | 15.51 | 11.74 | 1.38 | 61225.54 |
| 16 | 11.66 | 3.40 | 57.06 | 2.28 | 16.53 | 11.31 | 1.39 | 65287.00 |
| 17 | 11.87 | 1.40 | 62.22 | 1.55 | 17.44 | 10.94 | 1.40 | 66123.28 |
| 18 | 10.59 | 3.22 | 66.09 | 1.58 | 17.67 | 10.96 | 1.39 | 65399.69 |
| 19 | 12.89 | 4.76 | 60.91 | 1.75 | 18.02 | 10.75 | 1.38 | 65800.79 |
| 20 | 11.87 | 4.93 | 67.46 | 5.57 | 14.69 | 11.48 | 1.38 | 62215.12 |
| 21 | 15.19 | 4.84 | 55.30 | 2.36 | 17.13 | 11.01 | 1.38 | 63089.97 |
| 22 | 13.18 | 6.51 | 54.19 | 1.96 | 16.38 | 10.95 | 1.38 | 63325.89 |
| 23 | 11.01 | 3.78 | 59.07 | 1.90 | 16.69 | 10.96 | 1.38 | 62717.12 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 23 | 23 | 23 | 23 | 23 | 23 | 24 | 24 |
| 平均值 | 11.10 | 4.45 | 58.44 | 3.12 | 17.11 | 11.03 | 1.41 | 64377.17 |
| 最大值 | 16.67 | 11.20 | 68.38 | 12.78 | 19.98 | 12.21 | 1.54 | 74702.64 |
| 發生時間 | 12 | 10 | 8 | 10 | 8 | 11 | | 9 |
| 最小值 | 5.04 | 0.48 | 50.35 | 1.19 | 13.26 | 10.24 | 1.37 | 57453.48 |
| 發生時間 | 14 | 7 | 14 | 8 | 13 | 6 | | 11 |
| 零點偏移(率) | -0.07 % | 0.00 % | -0.02 % | -0.02 % | | -0.13 | 0.00 | 0.00 % |
| 全幅偏移(率) | 0.02 % | 1.14 % | 0.73 % | 0.33 % | | 0.04 | 0.00 | 0.20 % |
| 有效比率 | 95.83 % | 95.83 % | 95.83 % | 95.83 % | 95.83 % | 95.83 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月16日

| 項目 | #3-HCl_C | #3-CO_C | #3-NOx_C | #3-SO2_C | #3-H2O | #3-O2_C | #3-OPAC | #3-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 7.83 | 4.19 | 56.54 | 1.68 | 16.35 | 10.93 | 1.33 | 83137.28 |
| 1 | 8.28 | 2.33 | 56.33 | 1.95 | 16.34 | 11.18 | 1.36 | 83235.67 |
| 2 | 6.95 | 1.63 | 60.14 | 1.90 | 16.00 | 11.25 | 1.35 | 82607.30 |
| 3 | 4.44 | 3.40 | 61.97 | 1.62 | 16.33 | 11.52 | 1.35 | 78788.48 |
| 4 | 4.49 | 4.94 | 34.84 | 2.66 | 17.80 | 10.91 | 1.36 | 86343.35 |
| 5 | 8.45 | 0.87 | 47.32 | 3.31 | 17.16 | 10.43 | 1.35 | 87063.23 |
| 6 | 7.84 | 2.18 | 53.51 | 1.50 | 18.05 | 10.32 | 1.34 | 88324.82 |
| 7 | 6.50 | 3.13 | 59.19 | 1.86 | 17.68 | 10.38 | 1.32 | 98351.33 |
| 8 | 5.69 | 1.87 | 59.95 | 1.87 | 17.93 | 10.86 | 1.33 | 85767.80 |
| 9 | 9.32 | 15.60 | 42.94 | 4.10 | 18.76 | 9.13 | 1.30 | 88757.85 |
| 10 | 9.42 | 6.10 | 57.63 | 2.72 | 15.77 | 10.53 | 1.31 | 85723.70 |
| 11 | 10.55 | 2.69 | 52.80 | 2.62 | 17.53 | 9.55 | 1.31 | 90152.37 |
| 12 | 10.53 | 5.41 | 54.36 | 3.06 | 14.22 | 10.87 | 1.31 | 84687.45 |
| 13 | 9.07 | 6.59 | 54.91 | 3.00 | 14.45 | 10.92 | 1.31 | 84300.36 |
| 14 | 11.37 | 1.58 | 57.75 | 2.70 | 15.24 | 10.70 | 1.30 | 84558.43 |
| 15 | 9.89 | 12.97 | 50.67 | 3.72 | 14.99 | 10.67 | 1.30 | 84342.47 |
| 16 | 12.17 | 4.02 | 56.85 | 3.23 | 14.59 | 10.99 | 1.30 | 83087.20 |
| 17 | 10.25 | 0.73 | 58.09 | 2.68 | 14.97 | 11.15 | 1.30 | 82091.02 |
| 18 | 9.27 | 3.61 | 58.16 | 2.32 | 16.03 | 10.99 | 1.32 | 81516.21 |
| 19 | 11.69 | 7.94 | 53.39 | 2.89 | 14.99 | 10.88 | 1.31 | 85073.92 |
| 20 | 10.12 | 3.36 | 58.40 | 3.19 | 14.71 | 10.98 | 1.30 | 81287.21 |
| 21 | 11.28 | 3.75 | 57.11 | 2.49 | 17.04 | 10.47 | 1.30 | 83184.41 |
| 22 | 9.84 | 8.12 | 54.87 | 2.33 | 16.87 | 10.21 | 1.30 | 87367.28 |
| 23 | 10.02 | 2.69 | 59.68 | 2.41 | 15.81 | 10.69 | 1.31 | 86727.55 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 8.97 | 4.57 | 54.89 | 2.58 | 16.23 | 10.69 | 1.32 | 85269.86 |
| 最大值 | 12.17 | 15.60 | 61.97 | 4.10 | 18.76 | 11.52 | 1.37 | 98351.33 |
| 發生時間 | 16 | 9 | 3 | 9 | 9 | 3 | | 7 |
| 最小值 | 4.44 | 0.73 | 34.84 | 1.50 | 14.22 | 9.13 | 1.26 | 78788.48 |
| 發生時間 | 3 | 17 | 4 | 6 | 12 | 9 | | 3 |
| 零點偏移(率) | -0.13 % | -0.01 % | -0.02 % | -0.00 % | | -0.02 | 0.00 | 0.00 % |
| 全幅偏移(率) | 1.48 % | 0.61 % | -0.30 % | 0.25 % | | 0.22 | -0.03 | 0.20 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |