

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月18日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.76	5.38	50.97	1.05	16.87	11.33	1.05	76490.86
1	8.77	5.95	46.87	2.12	16.02	11.69	1.05	74563.02
2	9.11	5.41	57.13	1.73	17.31	11.53	1.05	74616.46
3	6.18	7.03	55.64	1.76	15.95	11.96	1.05	72093.76
4	6.29	5.87	58.82	0.74	17.45	11.49	1.05	75009.58
5	8.78	6.74	52.14	1.24	17.71	11.20	1.05	76993.56
6	8.35	5.40	55.75	0.95	17.23	11.53	1.05	74066.22
7	8.34	5.27	54.52	0.73	18.71	10.97	1.05	76842.20
8	2.16	5.56	56.20	0.40	19.00	10.93	1.09	77178.22
9	9.56	5.55	47.65	0.99	19.14	10.65	1.07	79766.74
10	7.92	6.90	45.68	1.07	18.34	10.96	1.08	78037.02
11	8.75	7.31	52.54	1.34	17.96	11.18	1.10	76435.02
12	7.25	6.91	48.96	0.98	18.45	10.96	1.10	77445.76
13	9.03	7.57	50.39	1.34	17.43	11.53	1.07	74302.26
14	8.42	7.96	48.73	1.87	17.70	11.37	1.07	74905.38
15	7.17	7.54	44.18	1.55	16.86	11.45	1.11	75548.71
16	8.81	6.96	44.51	1.57	16.79	11.37	1.08	75849.56
17	9.13	7.91	49.76	1.40	17.61	11.17	1.05	77922.49
18	4.63	6.76	48.93	0.97	17.46	11.30	1.05	76000.60
19	7.01	7.68	50.88	0.92	17.87	11.18	1.07	77087.22
20	12.05	10.67	52.07	0.98	18.17	11.17	1.10	76416.86
21	8.25	11.74	51.19	0.89	17.24	11.43	1.10	75448.80
22	8.92	8.17	54.18	0.82	18.17	11.25	1.10	76229.75
23	9.02	7.52	54.14	0.72	18.06	11.23	1.10	76478.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.07	7.07	51.33	1.17	17.65	11.28	1.07	76072.02
最大值	12.05	11.74	58.82	2.12	19.14	11.96	1.12	79766.74
發生時間	20	21	4	1	9	3		9
最小值	2.16	5.27	44.18	0.40	15.95	10.65	1.05	72093.76
發生時間	8	7	15	8	3	9		3
零點偏移(率)	-0.07 %	0.00 %	-0.01 %	0.00 %		0.00		0.00 %
全幅偏移(率)	0.01 %	-0.36 %	-0.63 %	0.15 %		0.16		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月18日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.59	4.76	59.10	2.25	15.83	10.75	1.05	82958.66
1	1.00	3.83	62.05	3.03	15.51	10.80	1.05	83280.75
2	3.78	3.98	60.95	2.35	16.97	10.85	1.06	81227.99
3	6.99	5.07	64.16	3.02	15.27	10.95	1.05	82200.02
4	6.72	3.78	67.67	2.40	15.65	10.79	1.05	83190.95
5	4.97	3.31	60.42	2.37	15.91	10.68	1.05	83368.29
6	5.84	7.94	52.66	3.36	15.78	10.61	1.05	80125.68
7	3.11	3.45	59.45	2.00	16.78	10.23	1.05	86027.97
8	4.25	5.52	53.31	2.61	16.78	10.12	1.05	87084.92
9	4.08	7.83	56.23	3.27	14.40	10.69	1.03	84838.86
10	3.73	3.27	59.42	2.67	15.53	10.50	1.05	85603.05
11	7.87	11.73	56.82	3.34	15.17	10.47	1.03	86299.66
12	8.37	8.61	60.95	2.85	15.84	10.39	1.00	86328.20
13	7.71	2.21	58.16	2.84	16.54	10.39	0.99	85386.74
14	8.67	2.58	59.42	3.19	14.99	10.59	1.01	85342.75
15	7.76	3.30	60.01	3.24	13.40	11.06	1.04	82570.94
16	8.82	8.41	55.82	3.36	14.42	10.67	1.02	84242.20
17	8.39	3.14	59.50	2.54	15.75	10.47	1.02	85683.46
18	4.22	3.80	52.41	1.62	17.75	10.29	1.00	84900.69
19	5.67	3.23	51.10	1.83	17.55	9.92	0.99	87615.60
20	8.53	5.34	53.82	2.04	17.43	9.83	1.00	88629.89
21	8.69	3.39	57.80	2.45	15.72	10.58	1.03	84451.37
22	9.77	3.20	48.56	1.27	18.06	9.63	1.05	89901.94
23	8.83	2.93	60.58	1.78	17.26	9.91	1.05	87892.11
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.31	4.78	57.93	2.57	16.01	10.47	1.03	84964.70
最大值	9.77	11.73	67.67	3.36	18.06	11.06	1.13	89901.94
發生時間	22	11	4	6	22	15		22
最小值	1.00	2.21	48.56	1.27	13.40	9.63	0.99	80125.68
發生時間	1	13	22	22	15	22		6
零點偏移(率)	-0.07 %	-0.02 %	-0.09 %	-0.01 %		0.08		0.00 %
全幅偏移(率)	-0.99 %	-0.04 %	-0.60 %	-0.04 %		0.20		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月18日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.12	3.34	47.61	2.91	13.86	11.19	0.99	74842.66
1	8.59	4.69	50.40	2.44	13.52	11.27	1.00	74559.70
2	4.01	1.07	56.30	1.60	15.47	11.63	1.02	73413.63
3	4.84	2.26	57.89	1.67	14.90	11.33	1.02	76202.93
4	5.12	2.51	69.94	1.88	14.37	12.25	1.00	68396.14
5	3.21	2.64	44.74	1.54	15.04	11.14	1.01	78772.82
6	4.60	7.84	50.92	1.56	15.40	10.99	1.00	80568.57
7	3.23	6.04	44.86	1.27	15.45	10.78	1.03	81733.38
8	4.16	5.09	51.28	1.29	15.14	11.06	1.05	78791.46
9	7.69	4.78	52.27	1.29	15.44	10.94	1.03	79677.03
10	6.01	5.82	47.93	1.41	15.20	11.04	1.02	78600.84
11	7.17	8.95	51.74	1.07	15.90	10.79	1.02	80666.64
12	8.67	4.63	51.80	1.58	14.43	11.23	1.01	77185.35
13	8.37	3.99	52.22	1.93	14.54	11.16	1.00	78074.51
14	4.90	6.46	54.54	1.85	14.01	11.25	1.01	78057.65
15	8.41	9.94	48.68	2.73	12.69	11.25	1.01	74885.06
16	8.06	3.52	47.53	2.48	12.93	11.36	0.99	75498.84
17	7.37	3.66	48.14	2.12	13.61	11.04	0.99	75631.01
18	2.36	2.12	44.38	1.19	14.55	10.88	0.99	76220.59
19	1.26	3.01	57.22	0.98	15.05	11.07	1.01	78009.60
20	1.65	8.49	47.30	1.60	14.13	11.17	1.02	77324.96
21	1.44	5.82	47.45	1.51	13.93	11.10	1.02	75423.60
22	1.77	5.36	50.12	1.44	14.18	10.94	1.01	76979.12
23	2.17	5.20	50.26	1.04	15.14	10.81	1.02	77640.60
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.13	4.88	51.06	1.68	14.54	11.15	1.01	76964.86
最大值	8.67	9.94	69.94	2.91	15.90	12.25	1.07	81733.38
發生時間	12	15	4	0	11	4		7
最小值	1.26	1.07	44.38	0.98	12.69	10.78	0.98	68396.14
發生時間	19	2	18	19	15	7		4
零點偏移(率)	0.00 %	-0.01 %	-0.38 %	-0.03 %		0.05		0.00 %
全幅偏移(率)	0.02 %	-0.77 %	-0.50 %	0.09 %		0.18		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								