

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月23日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.73	12.35	50.98	1.08	20.80	10.23	1.25	86224.26
1	10.38	13.36	52.59	2.28	20.80	10.85	1.25	81340.36
2	7.44	12.35	54.01	2.95	19.04	10.64	1.23	84895.63
3	9.78	12.56	58.60	2.91	18.12	11.00	1.25	82782.94
4	10.66	13.00	58.45	3.03	17.49	11.28	1.24	81180.98
5	5.52	12.57	49.63	1.47	17.79	11.07	1.23	79592.72
6	8.98	12.44	58.98	2.08	18.09	10.92	1.25	83318.90
7	8.50	12.75	55.15	2.77	16.96	11.31	1.24	81376.64
8	13.49	12.83	57.79	3.67	17.19	11.33	1.24	81475.15
9	7.30	12.71	58.63	2.97	17.79	11.14	1.25	81774.03
10	9.35	12.63	55.22	3.00	18.30	10.88	1.24	83351.18
11	8.94	12.53	58.82	3.32	17.28	11.08	1.23	82842.79
12	11.77	13.04	54.41	4.27	15.70	11.49	1.20	81002.67
13	6.88	13.45	54.94	3.59	16.73	11.36	1.24	81317.30
14	8.51	13.03	55.02	3.53	16.43	11.51	1.22	80575.60
15	5.97	12.98	56.31	2.83	17.25	11.38	1.22	80518.74
16	11.09	13.25	52.86	3.68	17.84	10.89	1.23	83691.13
17	8.56	12.73	51.87	3.60	17.55	11.19	1.23	82164.19
18	7.39	13.19	53.57	3.27	17.00	11.49	1.23	79781.23
19	10.46	12.65	62.75	3.06	19.40	10.90	1.24	82588.59
20	9.85	12.37	35.10	2.99	18.37	10.75	1.24	84463.24
21	14.67	11.32	35.08	3.89	16.80	11.08	1.25	82863.16
22	8.73	12.86	35.93	1.97	17.47	11.04	1.23	83384.23
23	11.93	12.69	40.07	1.57	17.99	11.13	1.23	82322.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.45	12.73	52.36	2.91	17.84	11.08	1.24	82284.52
最大值	14.67	13.45	62.75	4.27	20.80	11.51	1.25	86224.26
發生時間	21	13	19	12	0	14		0
最小值	5.52	11.32	35.08	1.08	15.70	10.23	1.20	79592.72
發生時間	5	21	21	0	12	0		5
零點偏移(率)	-0.06 %	-0.00 %	-0.18 %	-0.03 %		-0.01	-0.01	0.10 %
全幅偏移(率)	0.95 %	0.28 %	-0.21 %	0.21 %		-0.18	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月23日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.90	14.48	60.50	0.65	19.22	12.30	1.04	69924.34
1	7.76	12.21	44.14	0.87	21.65	9.67	1.04	88306.32
2	5.51	12.29	47.48	1.29	19.48	10.63	1.04	83442.01
3	4.56	13.47	52.46	1.46	18.75	10.84	1.04	82132.80
4	8.42	12.37	51.33	0.86	20.44	10.57	1.04	82904.03
5	3.41	12.18	47.00	1.63	19.89	10.27	1.03	85671.56
6	3.04	12.91	45.94	2.23	17.68	11.38	1.02	86421.28
7	7.87	12.25	52.96	1.67	18.73	10.74	1.04	83301.78
8	5.35	12.25	50.16	1.73	18.55	10.80	1.04	82766.08
9	8.50	12.10	54.49	1.42	19.40	10.41	1.04	84459.43
10	10.74	12.18	59.56	2.15	18.46	10.75	1.04	82917.40
11	19.22	12.44	54.51	5.02	16.75	11.10	1.04	81980.75
12	3.96	12.53	53.96	1.11	16.90	11.21	1.02	80421.78
13	7.31	12.42	54.65	1.12	17.81	11.02	1.02	81453.70
14	9.35	13.02	59.98	1.21	17.74	11.09	1.02	81114.21
15	8.56	12.30	54.46	1.45	17.56	10.94	1.03	82357.30
16	13.52	12.43	49.18	3.06	18.14	10.82	1.03	82195.97
17	8.20	12.15	47.99	1.87	19.15	10.62	1.02	82811.53
18	7.41	12.68	53.00	1.16	20.00	10.44	1.04	83321.57
19	11.03	12.04	54.28	1.66	19.62	10.41	1.04	84341.61
20	12.52	10.32	50.86	3.05	17.62	10.84	1.03	82570.17
21	4.29	13.50	54.17	1.13	16.98	11.53	1.02	78067.20
22	18.48	13.31	48.05	0.79	19.32	10.36	1.02	85230.68
23	6.62	12.08	53.22	0.38	20.91	10.18	1.02	84723.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.27	12.50	52.26	1.62	18.78	10.79	1.03	82618.20
最大值	19.22	14.48	60.50	5.02	21.65	12.30	1.06	88306.32
發生時間	11	0	0	11	1	0		1
最小值	2.90	10.32	44.14	0.38	16.75	9.67	1.02	69924.34
發生時間	0	20	1	23	11	1		0
零點偏移(率)	-0.11 %	0.00 %	-0.03 %	-0.00 %		-0.04	-0.01	-0.10 %
全幅偏移(率)	-0.53 %	-1.91 %	1.02 %	0.44 %		-0.08	-0.06	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月23日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.11	11.49	51.08	1.49	21.60	8.17	1.28	82918.01
1	6.15	12.30	46.34	2.76	19.99	9.29	1.32	76504.06
2	8.01	11.57	49.25	3.29	20.03	9.07	1.33	77564.80
3	4.96	11.86	47.52	2.83	18.85	9.50	1.32	75194.64
4	5.46	11.96	47.78	2.80	18.79	9.42	1.32	76245.33
5	3.13	11.33	49.25	2.74	19.02	9.33	1.31	77210.76
6	7.99	11.54	51.35	3.09	18.81	9.26	1.31	77390.04
7	7.19	11.52	40.47	2.10	19.87	8.45	1.34	79018.76
8	9.03	11.22	57.57	1.52	18.18	9.70	1.30	77771.60
9	6.21	11.61	63.59	1.49	19.31	9.90	1.35	78659.22
10	8.66	11.24	61.19	1.54	18.14	9.98	1.30	77840.00
11	6.87	11.13	62.86	1.44	18.40	9.84	1.31	78160.22
12	11.59	11.02	65.61	1.56	18.07	9.77	1.32	78210.63
13	6.21	11.19	59.66	1.37	17.31	10.03	1.31	77014.22
14	8.31	11.70	61.09	1.40	16.87	10.39	1.32	74204.80
15	5.12	10.99	58.90	1.30	18.46	9.59	1.30	74431.64
16	4.91	12.00	53.02	1.62	18.52	9.51	1.29	74642.83
17	5.12	10.99	51.14	1.49	18.90	9.51	1.27	73110.44
18	5.12	11.11	61.02	1.41	19.39	9.65	1.31	73521.25
19	4.16	11.26	60.79	1.44	20.02	9.63	1.34	75368.81
20	3.90	11.15	55.70	1.30	18.85	9.73	1.32	74098.86
21	9.22	11.13	57.64	1.53	17.71	9.54	1.31	73801.82
22	11.37	10.82	59.11	1.75	19.49	9.26	1.30	74954.37
23	6.30	10.95	53.77	1.49	19.50	9.27	1.27	74014.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.71	11.38	55.24	1.86	18.92	9.49	1.31	76327.17
最大值	11.59	12.30	65.61	3.29	21.60	10.39	1.36	82918.01
發生時間	12	1	12	2	0	14		0
最小值	3.13	10.82	40.47	1.30	16.87	8.17	1.27	73110.44
發生時間	5	22	7	15	14	0		17
零點偏移(率)	-0.08 %	0.00 %	-0.08 %	-0.01 %		-0.05	-0.01	-0.20 %
全幅偏移(率)	-0.62 %	0.39 %	0.49 %	0.41 %		0.30	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								