

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年08月21日

報表日期: 115年08月21日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.56	11.26	48.70	1.81	18.53	10.91	1.23	74519.86
1	10.20	11.22	46.74	1.65	19.96	10.66	1.22	75000.51
2	9.38	11.13	47.32	2.30	19.22	10.67	1.23	76349.24
3	9.11	11.77	62.86	1.80	19.63	11.21	1.23	72808.60
4	8.75	11.38	50.71	1.91	18.85	10.76	1.23	75954.68
5	5.91	12.21	51.54	0.93	20.64	10.34	1.21	75543.72
6	9.57	11.97	59.40	1.20	20.51	10.23	1.19	77428.28
7	10.86	12.29	55.89	1.64	19.23	10.66	1.19	75584.87
8	7.81	11.24	55.54	1.11	19.25	10.77	1.18	74496.60
9	9.68	11.36	58.48	1.39	18.70	10.96	1.19	73918.47
10	10.41	11.29	54.62	1.48	18.48	10.77	1.18	74684.96
11	9.04	11.31	56.28	1.33	19.00	10.89	1.19	73413.92
12	10.26	11.45	50.89	1.51	18.88	10.93	1.18	74343.93
13	12.67	11.64	52.91	2.06	17.45	11.29	1.18	73102.34
14	7.74	11.80	55.43	1.39	18.46	11.07	1.18	74353.70
15	10.18	11.72	61.68	1.83	19.01	11.11	1.17	73466.42
16	9.51	12.11	51.13	2.89	17.75	11.22	1.17	74052.44
17	9.59	11.58	60.14	2.44	18.15	11.20	1.18	73203.19
18	9.14	11.43	64.69	2.53	18.11	11.14	1.18	73880.50
19	8.11	12.03	60.08	1.59	18.99	11.49	1.18	70544.88
20	10.97	11.61	50.54	2.31	18.55	11.12	1.18	73078.61
21	9.84	11.98	50.63	2.91	16.80	11.48	1.18	71648.97
22	10.06	12.09	60.43	3.85	16.50	11.68	1.18	70659.57
23	7.97	11.94	55.87	3.04	17.23	11.52	1.19	71793.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.39	11.66	55.10	1.95	18.66	11.00	1.19	73909.68
最 大 值	12.67	12.29	64.69	3.85	20.64	11.68	1.24	77428.28
發生時間	13	7	18	22	5	22		6
最 小 值	5.91	11.13	46.74	0.93	16.50	10.23	1.15	70544.88
發生時間	5	2	1	5	22	6		19
零點偏移(率)	-0.04 %	0.01 %	-0.01 %	0.01 %		0.00	-0.01	0.20 %
全幅偏移(率)	-0.90 %	0.39 %	0.47 %	1.19 %		-0.13	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月21日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	6.61	12.09	55.40	2.40	19.97	9.78	1.27	77895.81
1	7.12	12.27	54.85	2.04	21.21	9.74	1.27	76522.10
2	11.75	11.78	60.82	3.06	18.51	10.01	1.28	76672.38
3	4.80	11.74	63.47	2.44	19.05	10.35	1.28	77559.44
4	9.33	11.56	61.12	2.69	20.05	10.03	1.27	78250.52
5	8.19	11.55	56.57	2.51	19.00	10.03	1.27	78531.43
6	8.66	11.55	58.69	2.63	18.89	10.13	1.27	77543.22
7	12.58	11.96	47.71	2.75	20.20	10.22	1.28	73976.42
8	6.48	11.38	53.99	1.56	21.00	9.61	1.28	78496.70
9	10.05	11.66	52.52	1.79	19.15	10.01	1.27	77349.43
10	8.20	11.61	55.00	1.62	18.99	10.15	1.29	76579.10
11	7.91	11.91	56.74	1.49	18.45	10.37	1.27	74794.49
12	5.17	11.46	57.10	1.50	19.80	9.90	1.24	75192.73
13	4.99	11.53	58.93	1.57	19.89	9.94	1.28	75753.03
14	8.26	12.62	56.97	1.61	19.49	9.82	1.28	76368.29
15	8.05	12.44	56.89	2.00	19.46	10.02	1.27	78119.38
16	6.93	12.35	59.27	2.32	16.66	10.91	1.26	71575.24
17	5.57	12.29	58.68	2.61	17.52	10.60	1.27	73745.51
18	8.73	12.39	60.23	2.53	18.31	10.11	1.28	75673.55
19	9.50	12.59	57.93	2.50	18.82	9.94	1.29	76736.89
20	10.31	12.77	54.23	2.53	17.82	10.29	1.31	74237.50
21	7.60	12.97	58.95	2.24	17.97	10.36	1.31	74219.32
22	9.75	12.77	54.55	2.30	18.37	10.23	1.29	75065.85
23	12.16	13.08	56.06	2.42	18.20	10.25	1.27	74880.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.28	12.10	56.94	2.21	19.03	10.12	1.28	76072.45
最 大 值	12.58	13.08	63.47	3.06	21.21	10.91	1.31	78531.43
發生時間	7	23	3	2	1	16		5
最 小 值	4.80	11.38	47.71	1.49	16.66	9.61	1.23	71575.24
發生時間	3	8	7	11	16	8		16
零點偏移(率)	-0.09 %	0.00 %	-0.06 %	-0.02 %		-0.06	-0.01	-0.20 %
全幅偏移(率)	0.63 %	0.51 %	1.35 %	1.33 %		0.22	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								