

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年09月06日

報表日期: 115年09月06日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.72	13.04	59.91	2.26	17.12	11.50	1.18	71321.09
1	4.97	12.80	59.97	1.59	19.62	10.96	1.18	73154.38
2	9.85	12.68	54.38	2.56	18.30	11.03	1.18	73829.93
3	9.41	12.55	57.94	2.08	18.84	10.89	1.18	74816.67
4	10.52	12.68	59.89	2.37	18.18	11.10	1.18	73815.02
5	11.27	12.65	56.66	2.41	17.95	11.10	1.18	72994.02
6	9.56	12.66	60.10	1.97	19.17	10.81	1.18	75075.77
7	8.81	12.64	58.03	1.97	18.94	10.94	1.17	74115.26
8	10.33	12.75	52.73	2.32	17.68	11.20	1.14	73315.20
9	10.47	13.32	62.13	2.65	16.65	11.68	1.15	71035.68
10	9.12	13.04	65.86	2.50	17.54	11.32	1.15	72510.49
11	11.95	12.65	55.81	2.31	18.37	11.07	1.15	72989.50
12	9.22	13.06	63.09	2.12	18.70	11.32	1.15	71723.35
13	12.82	12.46	61.66	2.62	19.64	10.60	1.16	76247.76
14	8.14	12.51	57.31	1.91	19.28	10.83	1.16	74926.13
15	9.19	12.77	62.81	1.97	19.22	11.04	1.16	73689.94
16	10.34	12.24	57.44	2.22	20.33	10.28	1.15	77890.92
17	8.91	11.69	64.52	1.85	20.10	10.70	1.16	73258.60
18	8.36	11.14	50.04	1.60	19.61	10.48	1.18	72493.23
19	10.03	11.24	52.89	1.77	19.26	10.72	1.18	71285.45
20	9.37	11.23	53.97	1.38	20.48	10.57	1.18	70344.32
21	4.09	15.18	65.19	1.54	18.65	12.92	1.27	56040.35
22	0.09	11.98	50.57	0.89	20.22	10.88	1.24	68974.25
23	0.19	11.70	57.57	0.48	21.37	10.26	1.19	71392.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.45	12.53	58.35	1.97	18.97	11.01	1.17	72385.01
最 大 值	12.82	15.18	65.86	2.65	21.37	12.92	1.62	77890.92
發生時間	13	21	10	9	23	21		16
最 小 值	0.09	11.14	50.04	0.48	16.65	10.26	1.13	56040.35
發生時間	22	18	18	23	9	23		21
零點偏移(率)	0.00 %	0.01 %	-0.05 %	-0.04 %		-0.02	-0.01	0.20 %
全幅偏移(率)	0.13 %	0.17 %	-0.34 %	-0.61 %		-0.16	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年09月06日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.04	13.44	57.72	2.18	16.91	11.51	1.00	79179.32
1	1.08	12.92	51.44	1.54	19.27	10.85	1.00	82931.01
2	2.87	12.71	56.27	1.62	17.67	11.26	1.00	81720.62
3	2.04	12.81	49.34	1.42	18.48	10.93	1.00	83459.57
4	5.75	12.84	52.32	2.06	17.70	11.14	0.99	82241.79
5	5.80	12.37	51.21	1.94	18.14	10.91	0.99	83808.83
6	7.17	12.18	50.29	1.19	18.51	10.76	0.95	80993.27
7	12.36	12.68	58.45	2.09	17.87	11.16	0.94	82298.84
8	6.22	12.22	51.19	1.37	18.27	10.82	0.94	84797.23
9	8.23	13.79	61.54	2.03	16.74	12.07	0.96	75937.00
10	9.69	12.83	60.63	1.62	18.96	10.55	0.94	85629.00
11	11.91	12.14	57.35	1.22	19.99	10.17	0.94	87056.82
12	11.64	12.91	65.19	0.97	19.19	10.63	0.94	84435.41
13	8.70	12.27	45.83	1.14	18.74	10.76	0.94	84267.02
14	11.36	12.39	60.42	1.45	18.14	10.93	0.94	83251.56
15	12.09	12.29	54.04	0.94	19.72	10.72	0.95	83663.00
16	6.13	12.33	54.59	0.79	19.92	10.74	0.96	83089.50
17	9.59	12.26	52.69	0.83	19.62	10.62	0.95	84587.21
18	5.60	12.60	58.69	0.86	19.82	10.92	0.94	81510.15
19	5.57	12.40	60.64	1.26	19.44	10.73	0.94	82614.80
20	7.48	12.34	51.90	1.09	20.50	10.40	0.94	83981.21
21	1.98	13.49	61.73	0.83	20.15	11.48	0.95	76914.83
22	1.20	12.92	46.28	1.77	19.96	10.72	0.96	82377.11
23	0.94	12.42	50.52	0.83	20.92	10.22	0.95	85188.60
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.56	12.65	55.01	1.38	18.94	10.88	0.96	82747.24
最 大 值	12.36	13.79	65.19	2.18	20.92	12.07	1.02	87056.82
發生時間	7	9	12	0	23	9		11
最 小 值	0.94	12.14	45.83	0.79	16.74	10.17	0.94	75937.00
發生時間	23	11	13	16	9	11		9
零點偏移(率)	-0.03 %	-0.10 %	-0.08 %	-0.01 %		0.02	-0.01	-0.10 %
全幅偏移(率)	0.94 %	-0.85 %	-0.45 %	-0.29 %		0.29	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 115年09月06日

報表日期: 115年09月06日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.72	11.70	61.39	2.76	19.27	10.17	1.23	75841.90
1	8.50	9.96	32.92	3.10	21.74	8.66	1.23	77658.75
2	11.18	11.19	50.65	2.98	20.26	9.29	1.23	77935.02
3	8.57	11.33	59.57	2.68	18.27	9.87	1.23	74893.53
4	10.14	11.25	59.18	2.88	18.85	9.78	1.23	76159.47
5	9.31	11.43	59.97	2.66	17.82	10.05	1.23	73769.51
6	8.87	11.30	62.07	2.76	18.44	9.88	1.25	75260.81
7	9.10	11.40	50.75	2.75	18.11	9.87	1.26	74111.89
8	10.03	11.19	55.81	3.06	18.56	9.69	1.27	74363.14
9	10.31	11.19	57.51	3.15	18.53	9.73	1.27	74740.42
10	8.95	11.44	61.77	3.44	19.80	9.79	1.27	76262.47
11	9.77	11.58	43.03	3.16	18.70	10.10	1.27	76686.28
12	8.93	11.97	53.48	3.00	18.62	10.49	1.27	72562.09
13	10.29	11.57	51.22	3.21	19.91	9.93	1.27	77295.78
14	10.07	11.53	48.94	3.46	19.34	10.01	1.27	76509.60
15	8.70	11.87	49.52	3.39	18.17	10.23	1.25	75658.60
16	11.39	11.70	63.74	4.03	19.02	10.13	1.25	80382.59
17	9.87	12.04	58.04	2.07	20.15	9.92	1.25	80092.54
18	8.96	11.51	53.09	1.39	19.23	10.00	1.24	77231.58
19	8.12	12.42	52.80	1.33	20.77	9.87	1.27	77744.38
20	13.04	12.65	50.57	1.45	19.02	9.96	1.25	76175.47
21	10.45	13.10	47.63	2.11	18.63	10.41	1.24	78163.91
22	9.74	13.15	48.42	1.41	18.60	10.43	1.25	77640.58
23	10.17	12.12	55.80	2.06	19.52	9.89	1.26	78145.34
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.72	11.69	53.66	2.68	19.14	9.92	1.25	76470.24
最 大 值	13.04	13.15	63.74	4.03	21.74	10.49	1.28	80382.59
發生時間	20	22	16	16	1	12		16
最 小 值	8.12	9.96	32.92	1.33	17.82	8.66	1.23	72562.09
發生時間	19	1	1	19	5	1		12
零點偏移(率)	-0.08 %	0.00 %	-0.02 %	-0.01 %		-0.01	-0.01	-0.10 %
全幅偏移(率)	2.36 %	0.94 %	0.61 %	0.38 %		0.25	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								