

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月09日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.43	4.70	59.73	1.04	19.73	12.02	1.39	70036.37
1	5.84	6.77	70.70	1.14	19.99	12.34	1.38	67878.98
2	3.07	9.55	69.11	1.40	17.81	12.62	1.44	67174.15
3	10.25	10.92	53.13	1.57	18.17	11.50	1.38	76003.76
4	10.81	9.37	59.96	1.49	18.76	11.21	1.38	77106.63
5	12.20	4.96	59.30	1.42	18.45	11.24	1.38	73019.31
6	12.28	5.95	54.79	1.53	17.97	11.51	1.36	74389.35
7	8.79	11.82	53.32	1.36	17.82	11.63	1.37	73718.35
8	7.56	1.98	59.67	1.27	17.98	11.74	1.37	73258.21
9	2.80	1.36	63.49	0.80	19.57	11.69	1.37	72845.80
10	5.31	2.16	54.35	0.92	19.29	11.23	1.36	76396.97
11	12.70	1.57	62.74	1.19	19.18	11.49	1.36	74602.59
12	9.35	2.04	50.59	1.11	19.02	11.23	1.36	76874.12
13	9.53	2.11	62.36	1.00	19.25	11.40	1.36	75792.26
14	9.82	1.51	64.65	0.82	20.18	11.21	1.36	76170.70
15	9.63	2.48	66.09	0.94	19.64	11.31	1.37	75641.95
16	10.96	6.17	52.95	1.26	18.53	11.31	1.38	76642.45
17	11.62	2.34	58.42	1.13	19.19	11.32	1.40	76342.07
18	8.49	1.71	64.55	1.05	19.36	11.71	1.41	74004.75
19	11.00	2.06	55.00	0.59	20.53	10.75	1.41	79403.41
20	9.39	3.71	61.19	1.22	18.31	11.79	1.41	70721.43
21	9.69	3.30	54.18	1.24	18.38	11.63	1.41	73227.16
22	12.21	3.73	49.10	1.48	17.77	11.65	1.41	74006.76
23	8.60	2.39	71.74	0.94	19.70	11.46	1.41	75307.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.06	4.36	59.63	1.16	18.94	11.54	1.38	74190.23
最大值	12.70	11.82	71.74	1.57	20.53	12.62	1.56	79403.41
發生時間	11	7	23	3	19	2		19
最小值	2.80	1.36	49.10	0.59	17.77	10.75	1.34	67174.15
發生時間	9	9	22	19	22	19		2
零點偏移(率)	-0.04 %	-0.00 %	-0.00 %	0.00 %		0.02	0.00	0.00 %
全幅偏移(率)	4.57 %	1.03 %	0.87 %	0.36 %		0.21	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月09日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.09	2.12	66.63	2.03	17.00	11.17	1.45	63978.76
1	7.79	7.41	58.36	2.21	17.95	10.82	1.45	65067.41
2	7.07	4.30	62.33	2.47	17.38	10.52	1.44	65443.66
3	8.86	3.48	65.39	2.85	17.37	10.43	1.45	67606.18
4	9.69	5.26	63.44	2.72	17.49	10.45	1.45	67798.09
5	6.10	1.98	62.80	2.01	18.04	10.32	1.46	68408.71
6	7.09	3.22	52.15	2.29	16.85	10.47	1.47	63122.14
7	9.11	2.38	66.41	2.68	16.68	10.81	1.46	65765.91
8	9.19	8.55	64.39	2.02	18.89	10.26	1.46	68197.91
9	9.33	0.73	61.47	2.30	17.43	10.83	1.47	65919.65
10	8.03	1.93	67.83	2.07	17.85	11.09	1.48	63484.31
11	15.06	1.13	62.10	3.32	18.05	10.54	1.49	66373.28
12	10.72	2.63	58.72	2.56	17.14	10.69	1.50	64639.41
13	15.45	6.03	61.73	4.40	17.57	10.68	1.50	65651.64
14	8.18	5.81	60.09	5.38	16.54	11.04	1.49	64771.48
15	12.46	7.14	64.73	2.68	16.85	10.88	1.49	65246.63
16	11.69	2.94	63.45	2.25	17.41	10.53	1.48	64695.27
17	12.65	4.85	58.16	3.08	17.57	10.34	1.46	65334.94
18	17.84	5.68	64.24	5.68	16.43	11.05	1.45	65457.75
19	17.15	6.77	63.46	5.56	17.47	10.85	1.44	67089.68
20	13.09	16.63	61.84	2.78	15.27	11.01	1.45	64666.19
21	10.61	3.33	58.21	2.57	15.38	10.92	1.45	63463.40
22	9.98	1.27	62.88	2.37	16.94	10.95	1.45	64198.93
23	9.94	6.63	64.29	1.89	19.01	10.11	1.45	68284.38
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.67	4.67	62.30	2.92	17.27	10.70	1.46	65611.07
最大值	17.84	16.63	67.83	5.68	19.01	11.17	1.52	68408.71
發生時間	18	20	10	18	23	0		5
最小值	6.10	0.73	52.15	1.89	15.27	10.11	1.43	63122.14
發生時間	5	9	6	23	20	23		6
零點偏移(率)	0.00 %	0.00 %	-0.01 %	-0.03 %		-0.04	0.00	0.00 %
全幅偏移(率)	1.81 %	0.78 %	0.85 %	0.44 %		0.05	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月09日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.87	6.91	61.85	2.24	16.23	11.61	1.29	76499.45
1	7.45	9.27	53.69	2.34	17.92	10.57	1.30	86138.16
2	11.55	11.21	65.86	3.80	14.00	11.43	1.30	84982.17
3	7.87	10.41	60.45	3.28	14.69	11.48	1.30	82741.04
4	9.18	5.91	60.58	2.91	15.38	11.05	1.30	84817.34
5	6.02	10.59	51.38	2.41	16.26	10.42	1.30	82670.56
6	6.26	4.93	57.62	2.26	17.18	10.47	1.30	82174.02
7	11.59	8.18	57.20	2.71	16.84	10.29	1.30	84386.70
8	6.44	1.49	60.42	2.30	15.91	10.88	1.30	83890.95
9	9.27	1.54	52.67	2.20	17.23	10.34	1.30	87184.35
10	8.30	2.07	55.31	2.38	15.95	10.67	1.29	83328.01
11	16.44	7.68	63.65	7.02	15.15	11.15	1.30	83745.42
12	7.11	1.26	60.54	4.29	14.38	11.77	1.29	81800.79
13	10.08	1.33	60.36	2.41	16.56	11.05	1.29	83631.42
14	13.85	1.05	58.63	3.12	16.86	10.79	1.30	85302.43
15	11.35	4.31	56.37	3.28	15.76	10.91	1.30	85554.92
16	15.16	12.49	59.26	3.36	14.32	11.17	1.30	84219.58
17	15.57	2.19	59.36	2.94	16.09	10.84	1.29	86373.84
18	14.86	6.18	63.31	3.34	15.65	11.16	1.28	84635.81
19	9.71	1.31	60.97	2.24	17.66	10.35	1.30	90145.16
20	14.58	19.03	59.03	3.72	13.85	11.18	1.30	83506.32
21	10.66	6.79	56.81	3.80	13.63	11.17	1.27	82209.47
22	12.91	4.35	58.39	3.64	14.68	10.88	1.28	83525.56
23	9.23	2.38	61.06	2.38	16.95	10.91	1.28	86171.68
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.43	5.95	58.95	3.10	15.80	10.94	1.29	84151.46
最大值	16.44	19.03	65.86	7.02	17.92	11.77	1.33	90145.16
發生時間	11	20	2	11	1	12		19
最小值	4.87	1.05	51.38	2.20	13.63	10.29	1.26	76499.45
發生時間	0	14	5	9	21	7		0
零點偏移(率)	-0.02 %	-0.00 %	-0.02 %	-0.02 %		0.01	0.00	0.00 %
全幅偏移(率)	0.29 %	0.38 %	-0.35 %	-0.46 %		0.41	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								