

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年03月20日

報表日期: 113年03月20日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.84	5.00	51.82	1.04	16.70	11.47	1.05	83531.75
1	7.06	6.29	40.30	2.39	15.91	11.67	1.04	81916.31
2	5.22	2.03	59.50	0.90	18.43	11.42	1.05	80756.60
3	10.45	4.61	52.81	1.32	17.18	10.87	1.06	87511.14
4	10.45	5.77	34.50	2.68	15.52	11.76	1.05	81651.80
5	11.82	8.35	62.18	1.91	17.36	11.24	1.02	79866.61
6	8.92	5.28	63.10	1.75	16.41	11.54	1.02	83330.19
7	4.99	5.74	48.16	1.95	15.08	12.02	1.04	77939.06
8	3.85	6.04	48.28	1.47	16.13	11.67	1.06	80318.87
9	5.72	5.40	46.63	1.41	16.32	11.39	1.03	82200.11
10	7.55	5.48	49.37	1.64	16.27	11.34	1.02	82301.44
11	10.21	5.74	42.71	2.70	14.22	11.66	1.04	80026.60
12	9.35	4.93	46.02	2.55	14.91	11.58	1.06	79967.47
13	9.07	4.98	42.00	2.65	14.71	11.57	1.06	81237.09
14	9.66	5.43	44.84	3.26	13.67	11.81	1.06	78150.99
15	13.35	5.67	50.11	2.56	14.18	11.93	1.06	77717.46
16	8.94	6.47	62.20	1.15	15.81	11.39	1.03	83006.85
17	5.66	6.56	74.48	0.85	16.54	11.42	1.02	83023.22
18	5.66	7.20	46.65	1.57	14.90	11.64	1.02	84270.87
19	9.34	6.75	58.84	2.05	15.26	11.53	1.03	84270.82
20	11.92	6.06	58.03	2.98	15.58	11.42	1.04	84743.76
21	10.03	7.05	55.17	4.32	14.45	11.59	1.05	83691.30
22	8.43	6.58	60.73	0.98	15.92	11.66	1.06	82755.97
23	8.60	6.57	58.75	2.24	15.37	11.67	1.04	82852.50
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.55	5.83	52.38	2.01	15.70	11.55	1.04	81959.95
最 大 值	13.35	8.35	74.48	4.32	18.43	12.02	1.06	87511.14
發生時間	15	5	17	21	2	7		3
最 小 值	3.85	2.03	34.50	0.85	13.67	10.87	1.01	77717.46
發生時間	8	2	4	17	14	3		15
零點偏移(率)	-0.04 %	-0.00 %	-0.02 %	-0.01 %		0.03		0.10 %
全幅偏移(率)	0.60 %	0.11 %	-0.10 %	0.02 %		0.34		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月20日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.08	3.73	53.55	2.94	14.26	11.46	1.04	80223.28
1	5.54	3.63	52.05	2.25	16.56	11.22	1.05	80321.37
2	7.31	4.50	32.89	2.91	15.28	11.26	1.04	81264.24
3	9.23	4.54	57.19	2.62	15.68	11.41	1.04	79673.15
4	6.98	4.28	35.95	2.47	16.13	11.02	1.04	82060.96
5	3.37	4.31	69.91	1.37	16.41	11.75	1.05	76006.60
6	2.84	11.80	47.05	3.07	15.14	11.25	1.04	85268.51
7	2.76	5.26	41.88	3.26	14.02	11.98	1.03	75912.55
8	3.57	3.02	44.69	2.17	15.55	11.25	0.99	80912.77
9	3.69	3.05	48.13	2.43	15.57	11.19	1.00	80458.93
10	0.20	4.20	45.01	3.36	12.72	11.74	1.02	78507.14
11	1.85	3.11	54.43	2.75	14.21	11.59	1.02	78703.09
12	2.43	3.05	52.59	2.41	14.94	11.53	1.02	78282.07
13	7.37	3.49	51.70	3.29	13.00	11.90	1.02	77282.86
14	6.95	3.25	51.71	3.58	13.46	11.82	1.02	77772.45
15	7.99	1.82	58.44	2.72	15.39	11.19	1.02	80756.47
16	5.18	2.26	60.74	2.19	15.43	11.35	1.01	78904.94
17	9.79	3.04	64.08	3.04	13.99	11.63	0.99	78790.69
18	9.47	3.81	59.43	2.76	13.43	11.64	0.96	79450.75
19	7.43	2.89	65.55	1.78	15.39	11.33	0.98	80594.41
20	7.78	3.43	51.78	3.30	14.04	11.26	1.00	82029.04
21	14.74	6.14	57.71	4.22	12.24	11.63	1.02	79823.83
22	7.86	4.05	55.35	2.95	14.04	11.48	1.02	80029.45
23	8.91	3.11	56.94	3.02	14.31	11.14	1.02	81553.09
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.26	3.99	52.86	2.79	14.63	11.46	1.02	79774.28
最 大 值	14.74	11.80	69.91	4.22	16.56	11.98	1.06	85268.51
發生時間	21	6	5	21	1	7		6
最 小 值	0.20	1.82	32.89	1.37	12.24	11.02	0.94	75912.55
發生時間	10	15	2	5	21	4		7
零點偏移(率)	-0.18 %	-0.11 %	-0.03 %	-0.03 %		0.00		0.10 %
全幅偏移(率)	0.14 %	-0.04 %	-0.04 %	0.07 %		0.20		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 113年03月20日

報表日期: 113年03月20日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	2.38	6.42	56.90	0.95	14.59	10.90	1.06	76811.72
1	2.29	7.59	58.64	0.31	18.50	10.16	1.06	81207.70
2	2.33	10.60	38.18	0.45	17.18	10.23	1.06	79432.66
3	2.27	6.88	43.88	0.63	15.58	10.51	1.06	77650.58
4	3.07	6.66	45.70	0.57	16.25	10.44	1.06	78675.24
5	2.27	6.42	50.59	0.28	17.14	10.32	1.06	80175.87
6	3.13	10.26	44.11	0.69	15.62	10.30	1.06	80523.11
7	1.79	6.08	55.57	0.85	15.40	10.56	1.09	76485.33
8	2.27	4.37	58.84	0.32	16.32	10.46	1.08	76965.52
9	1.42	4.34	49.87	0.56	16.28	10.37	1.08	78515.65
10	0.34	3.24	46.15	0.60	15.49	10.53	1.09	77349.84
11	1.24	3.46	47.81	1.09	14.73	10.79	1.09	76281.20
12	4.31	3.53	53.58	1.58	14.64	10.82	1.09	78394.85
13	4.41	4.07	48.96	2.23	13.57	11.00	1.09	75672.93
14	6.84	4.99	54.54	2.57	14.58	10.77	1.09	77160.51
15	5.06	3.15	58.01	1.93	13.92	11.04	1.09	75866.68
16	2.78	3.94	60.94	1.32	14.19	10.86	1.09	76870.24
17	1.10	3.68	62.89	1.31	13.97	10.84	1.08	75360.58
18	8.03	6.91	55.36	2.63	12.99	10.85	1.06	75936.28
19	8.06	3.04	62.75	1.12	15.36	10.66	1.06	80324.78
20	8.93	5.98	64.52	3.31	13.97	11.02	1.08	78616.50
21	10.77	3.71	59.18	1.99	14.52	10.76	1.09	79521.54
22	7.90	6.78	63.67	2.18	13.50	11.17	1.09	74632.52
23	7.20	3.28	60.79	1.61	14.06	10.97	1.09	74531.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.17	5.39	54.23	1.29	15.10	10.68	1.08	77623.45
最 大 值	10.77	10.60	64.52	3.31	18.50	11.17	1.10	81207.70
發生時間	21	2	20	20	1	22		1
最 小 值	0.34	3.04	38.18	0.28	12.99	10.16	1.05	74531.04
發生時間	10	19	2	5	18	1		23
零點偏移(率)	0.00 %	-0.00 %	-0.02 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.02 %	0.22 %	0.03 %	-0.05 %		0.16		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								