

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月24日

| 項目 | #1-HCl_C | #1-CO_C | #1-NOx_C | #1-SO2_C | #1-H2O | #1-O2_C | #1-OPAC | #1-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 8.96 | 8.27 | 56.32 | 1.85 | 17.36 | 11.52 | 1.10 | 74461.76 |
| 1 | 9.80 | 7.40 | 54.31 | 1.70 | 19.92 | 10.88 | 1.07 | 77319.69 |
| 2 | 9.57 | 8.90 | 64.68 | 1.63 | 19.69 | 10.99 | 1.07 | 77011.07 |
| 3 | 9.14 | 7.87 | 51.93 | 2.05 | 18.33 | 11.02 | 1.07 | 77555.60 |
| 4 | 9.65 | 9.52 | 66.84 | 1.67 | 17.87 | 11.59 | 1.10 | 73959.92 |
| 5 | 10.56 | 10.48 | 62.89 | 1.87 | 18.06 | 11.93 | 1.07 | 70386.19 |
| 6 | 9.48 | 8.82 | 39.05 | 1.84 | 18.03 | 11.25 | 1.05 | 76055.22 |
| 7 | 9.14 | 6.44 | 57.92 | 2.15 | 17.60 | 11.28 | 1.05 | 76154.93 |
| 8 | 8.90 | 5.79 | 61.28 | 1.41 | 18.49 | 11.38 | 1.06 | 74470.74 |
| 9 | 10.28 | 7.22 | 50.15 | 1.82 | 18.68 | 10.77 | 1.06 | 79064.52 |
| 10 | 9.35 | 6.27 | 60.06 | 2.06 | 17.52 | 11.27 | 1.05 | 75741.79 |
| 11 | 10.48 | 6.98 | 49.52 | 2.57 | 16.68 | 11.35 | 1.03 | 76311.31 |
| 12 | 9.46 | 6.24 | 56.01 | 2.21 | 16.84 | 11.54 | 1.04 | 74879.34 |
| 13 | 10.36 | 6.51 | 48.29 | 2.88 | 15.46 | 11.47 | 1.04 | 76424.21 |
| 14 | 8.89 | 6.14 | 50.99 | 2.65 | 15.55 | 11.68 | 1.05 | 74848.87 |
| 15 | 8.80 | 8.08 | 61.25 | 1.94 | 16.51 | 11.56 | 1.06 | 75214.85 |
| 16 | 8.47 | 8.35 | 48.02 | 1.99 | 16.18 | 11.38 | 1.07 | 76806.18 |
| 17 | 9.70 | 9.61 | 52.44 | 2.28 | 15.83 | 11.76 | 1.07 | 74068.05 |
| 18 | 9.09 | 8.27 | 63.38 | 1.72 | 17.45 | 11.52 | 1.08 | 74734.75 |
| 19 | 9.83 | 8.32 | 57.40 | 1.90 | 17.79 | 11.00 | 1.08 | 78357.42 |
| 20 | 8.16 | 9.57 | 65.81 | 1.42 | 18.77 | 11.13 | 1.09 | 76435.17 |
| 21 | 8.31 | 9.21 | 55.67 | 1.05 | 19.61 | 10.67 | 1.08 | 79704.20 |
| 22 | 9.95 | 9.61 | 52.20 | 1.73 | 18.10 | 10.81 | 1.07 | 79761.77 |
| 23 | 9.28 | 9.56 | 53.45 | 1.63 | 18.23 | 10.97 | 1.07 | 78284.87 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 9.40 | 8.06 | 55.83 | 1.92 | 17.69 | 11.28 | 1.07 | 76167.18 |
| 最大值 | 10.56 | 10.48 | 66.84 | 2.88 | 19.92 | 11.93 | 1.10 | 79761.77 |
| 發生時間 | 5 | 5 | 4 | 13 | 1 | 5 | | 22 |
| 最小值 | 8.16 | 5.79 | 39.05 | 1.05 | 15.46 | 10.67 | 1.02 | 70386.19 |
| 發生時間 | 20 | 8 | 6 | 21 | 13 | 21 | | 5 |
| 零點偏移(率) | -0.17 % | -0.04 % | -0.01 % | 0.00 % | | 0.00 | | 0.00 % |
| 全幅偏移(率) | 0.04 % | 0.31 % | -0.40 % | 0.03 % | | 0.16 | | 0.20 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月24日

| 項目 | #2-HCl_C | #2-CO_C | #2-NOx_C | #2-SO2_C | #2-H2O | #2-O2_C | #2-OPAC | #2-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 8.80 | 1.73 | 46.16 | 1.96 | 18.62 | 9.58 | 1.00 | 88928.06 |
| 1 | 9.66 | 3.27 | 55.26 | 2.34 | 18.50 | 9.91 | 1.01 | 86443.76 |
| 2 | 9.26 | 3.99 | 54.89 | 1.82 | 17.91 | 9.61 | 1.01 | 89548.72 |
| 3 | 9.35 | 4.06 | 51.05 | 2.85 | 16.09 | 10.31 | 1.01 | 86029.21 |
| 4 | 9.11 | 10.07 | 51.24 | 1.75 | 18.20 | 9.63 | 1.01 | 88840.14 |
| 5 | 9.12 | 3.61 | 61.80 | 2.05 | 17.17 | 10.05 | 1.00 | 86221.78 |
| 6 | 4.43 | 5.58 | 48.97 | 2.46 | 16.28 | 10.11 | 1.04 | 94323.22 |
| 7 | 8.12 | 3.10 | 59.69 | 2.46 | 16.12 | 10.37 | 1.04 | 85258.38 |
| 8 | 10.13 | 1.83 | 54.30 | 2.78 | 15.94 | 10.36 | 1.05 | 85563.30 |
| 9 | 8.69 | 2.54 | 55.61 | 1.65 | 17.38 | 9.87 | 1.05 | 87724.07 |
| 10 | 9.54 | 6.51 | 57.28 | 1.62 | 16.76 | 9.80 | 1.04 | 88072.86 |
| 11 | 9.55 | 5.15 | 52.61 | 2.40 | 15.55 | 10.25 | 1.02 | 85986.90 |
| 12 | 9.63 | 2.83 | 60.32 | 2.42 | 15.03 | 10.28 | 1.02 | 86728.00 |
| 13 | 9.85 | 5.24 | 51.43 | 3.32 | 13.94 | 10.53 | 1.00 | 85366.02 |
| 14 | 9.86 | 2.73 | 62.12 | 2.06 | 15.27 | 10.52 | 1.01 | 84387.73 |
| 15 | 9.50 | 7.31 | 46.55 | 2.30 | 15.34 | 10.19 | 0.99 | 87325.25 |
| 16 | 8.69 | 7.03 | 51.81 | 2.93 | 14.28 | 10.65 | 0.99 | 84767.75 |
| 17 | 8.69 | 3.92 | 51.10 | 2.49 | 15.00 | 10.42 | 0.99 | 85862.94 |
| 18 | 9.12 | 2.81 | 54.08 | 2.58 | 15.17 | 10.40 | 0.99 | 86165.19 |
| 19 | 10.31 | 2.44 | 57.92 | 2.91 | 14.82 | 10.39 | 0.99 | 85953.99 |
| 20 | 8.94 | 2.60 | 61.70 | 1.94 | 16.07 | 10.21 | 0.99 | 86574.22 |
| 21 | 8.94 | 2.46 | 48.58 | 2.45 | 15.67 | 10.18 | 1.00 | 86844.44 |
| 22 | 10.25 | 8.37 | 54.14 | 2.69 | 15.81 | 10.36 | 1.00 | 85358.95 |
| 23 | 9.23 | 3.15 | 53.39 | 2.69 | 15.74 | 10.31 | 0.99 | 85782.17 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 9.12 | 4.26 | 54.25 | 2.37 | 16.11 | 10.18 | 1.01 | 86835.71 |
| 最大值 | 10.31 | 10.07 | 62.12 | 3.32 | 18.62 | 10.65 | 1.06 | 94323.22 |
| 發生時間 | 19 | 4 | 14 | 13 | 0 | 16 | | 6 |
| 最小值 | 4.43 | 1.73 | 46.16 | 1.62 | 13.94 | 9.58 | 0.99 | 84387.73 |
| 發生時間 | 6 | 0 | 0 | 10 | 13 | 0 | | 14 |
| 零點偏移(率) | -0.05 % | -0.02 % | -0.01 % | 0.00 % | | 0.04 | | -0.10 % |
| 全幅偏移(率) | 0.04 % | 0.00 % | 0.01 % | 0.00 % | | -0.21 | | 0.00 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月24日

| 項目 | #3-HCl_C | #3-CO_C | #3-NOx_C | #3-SO2_C | #3-H2O | #3-O2_C | #3-OPAC | #3-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 8.48 | 3.61 | 55.64 | 1.48 | 16.88 | 10.91 | 0.94 | 82796.66 |
| 1 | 9.22 | 6.51 | 54.39 | 1.78 | 16.49 | 11.22 | 0.94 | 79808.29 |
| 2 | 9.87 | 5.35 | 54.29 | 1.74 | 16.86 | 10.64 | 0.94 | 85030.92 |
| 3 | 9.95 | 5.51 | 53.79 | 2.26 | 15.13 | 10.94 | 0.94 | 78965.02 |
| 4 | 10.70 | 4.97 | 59.17 | 2.12 | 14.69 | 11.33 | 0.94 | 79706.32 |
| 5 | 15.28 | 8.85 | 52.30 | 3.15 | 14.79 | 11.10 | 0.94 | 81462.78 |
| 6 | 8.78 | 11.74 | 56.24 | 2.06 | 15.31 | 11.06 | 0.94 | 80295.90 |
| 7 | 11.06 | 4.62 | 50.24 | 2.55 | 14.88 | 11.01 | 0.97 | 78726.28 |
| 8 | 9.46 | 3.02 | 54.68 | 2.17 | 15.08 | 10.96 | 0.97 | 80900.59 |
| 9 | 8.99 | 3.65 | 55.03 | 2.35 | 14.58 | 11.18 | 0.97 | 79204.11 |
| 10 | 9.37 | 5.25 | 61.64 | 2.20 | 14.81 | 11.05 | 0.96 | 82287.89 |
| 11 | 9.40 | 8.60 | 53.01 | 2.95 | 13.03 | 11.21 | 0.95 | 77507.99 |
| 12 | 8.89 | 4.66 | 56.78 | 3.08 | 12.74 | 11.16 | 0.94 | 75453.85 |
| 13 | 12.03 | 8.66 | 58.97 | 4.63 | 11.93 | 11.55 | 0.94 | 73799.46 |
| 14 | 8.96 | 3.68 | 51.71 | 5.92 | 12.31 | 11.61 | 0.92 | 75954.03 |
| 15 | 7.83 | 5.58 | 47.03 | 3.89 | 13.56 | 11.10 | 0.91 | 74530.92 |
| 16 | 8.75 | 8.29 | 47.39 | 2.08 | 14.36 | 10.82 | 0.92 | 78945.14 |
| 17 | 9.04 | 6.68 | 52.03 | 2.81 | 12.99 | 11.18 | 0.91 | 76649.19 |
| 18 | 10.66 | 10.18 | 54.20 | 3.08 | 12.57 | 11.22 | 0.93 | 78036.61 |
| 19 | 8.41 | 2.46 | 58.53 | 2.76 | 12.91 | 11.16 | 0.93 | 78547.30 |
| 20 | 6.32 | 2.96 | 68.45 | 1.36 | 16.62 | 10.77 | 0.94 | 81375.44 |
| 21 | 9.79 | 3.69 | 56.94 | 1.59 | 16.86 | 10.63 | 0.94 | 87383.82 |
| 22 | 9.40 | 3.92 | 56.15 | 1.82 | 15.50 | 11.07 | 0.95 | 84018.67 |
| 23 | 9.56 | 3.77 | 57.12 | 2.22 | 14.64 | 11.15 | 0.94 | 82335.56 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 9.59 | 5.68 | 55.24 | 2.59 | 14.56 | 11.08 | 0.94 | 79738.45 |
| 最大值 | 15.28 | 11.74 | 68.45 | 5.92 | 16.88 | 11.61 | 0.99 | 87383.82 |
| 發生時間 | 5 | 6 | 20 | 14 | 0 | 14 | | 21 |
| 最小值 | 6.32 | 2.46 | 47.03 | 1.36 | 11.93 | 10.63 | 0.91 | 73799.46 |
| 發生時間 | 20 | 19 | 15 | 20 | 13 | 21 | | 13 |
| 零點偏移(率) | -0.08 % | -0.11 % | -0.03 % | 0.00 % | | 0.04 | | 0.00 % |
| 全幅偏移(率) | 0.04 % | 0.25 % | -0.22 % | 0.16 % | | 0.18 | | 0.10 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |