

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月22日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.45	7.02	47.52	0.76	18.49	11.01	1.02	85468.19
1	3.26	5.50	62.96	0.96	18.92	11.72	1.02	79238.37
2	3.78	5.11	52.73	0.52	19.08	10.92	1.02	85629.24
3	5.85	6.30	51.09	0.95	17.40	11.67	0.99	81163.25
4	6.17	7.03	48.88	1.09	17.87	11.56	0.99	81816.74
5	4.65	5.02	52.21	0.85	18.33	11.24	1.00	84782.51
6	4.93	4.85	47.48	0.95	19.46	10.88	1.01	85638.28
7	7.16	4.38	49.06	1.22	18.12	11.22	1.01	84180.84
8	2.70	4.49	54.51	0.62	18.73	11.32	1.00	82738.92
9	6.97	4.42	50.56	1.14	17.45	11.33	1.02	83620.25
10	2.02	4.72	67.40	1.77	16.85	12.01	0.99	79679.26
11	3.03	4.67	57.91	2.03	16.05	11.79	0.97	81839.06
12	6.18	4.76	54.32	2.22	16.02	11.78	0.99	81600.73
13	12.91	4.96	50.85	2.92	15.75	11.78	1.00	82460.30
14	4.27	4.49	56.65	1.75	16.72	11.79	1.00	80872.07
15	0.88	4.40	59.46	1.06	16.97	11.89	0.99	79640.76
16	5.59	4.24	55.19	1.63	17.24	11.26	0.99	84855.15
17	7.26	4.52	57.64	1.25	17.88	11.31	0.97	83756.59
18	8.60	4.28	54.67	1.67	18.01	10.99	0.99	86103.92
19	8.11	4.81	63.38	1.42	18.14	11.21	1.00	84073.81
20	0.88	5.01	52.31	0.98	18.41	11.32	1.01	82779.73
21	2.75	5.32	50.49	1.42	19.25	10.57	0.99	88303.28
22	7.39	1.33	56.89	1.79	18.22	11.42	1.01	82216.65
23	8.65	2.86	50.65	1.84	17.15	11.71	1.02	81072.87
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.48	4.77	54.37	1.37	17.77	11.40	1.00	83063.78
最大值	12.91	7.03	67.40	2.92	19.46	12.01	1.02	88303.28
發生時間	13	4	10	13	6	10		21
最小值	0.88	1.33	47.48	0.52	15.75	10.57	0.97	79238.37
發生時間	15	22	6	2	13	21		1
零點偏移(率)	-0.02 %	-0.03 %	-0.05 %	-0.01 %		-0.07		0.00 %
全幅偏移(率)	0.00 %	0.29 %	-0.02 %	0.00 %		-0.18		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月22日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.40	5.81	53.33	2.31	17.15	11.36	1.01	78034.78
1	8.69	4.90	46.15	2.76	18.31	10.77	1.01	81508.43
2	8.90	3.60	46.49	2.68	16.59	11.31	1.02	79127.21
3	7.89	3.32	53.35	2.26	17.43	11.52	1.02	76481.37
4	7.56	4.02	58.16	2.22	18.16	11.20	1.00	78390.71
5	2.06	4.28	59.79	1.08	19.54	11.25	0.98	76857.73
6	0.80	4.50	51.80	0.83	20.44	10.74	0.98	75570.12
7	1.49	4.37	61.57	1.43	17.97	11.75	1.00	74103.25
8	1.40	4.25	52.04	0.70	19.73	11.23	1.02	75995.58
9	5.73	7.02	46.53	1.31	19.54	10.48	1.02	82160.95
10	5.91	4.65	41.85	2.30	17.68	11.18	1.02	78427.93
11	4.66	3.70	46.53	1.96	16.76	11.30	1.02	78947.41
12	4.72	3.74	46.69	2.18	15.72	11.71	1.02	76531.28
13	1.97	3.42	50.18	1.82	16.17	11.79	1.02	75616.71
14	1.61	4.01	54.30	1.93	16.03	12.01	1.02	73818.64
15	1.62	8.20	53.40	1.95	18.02	10.98	1.02	80291.38
16	5.23	4.28	41.62	2.82	15.93	11.25	1.02	79735.32
17	2.37	3.75	47.80	2.23	15.71	11.51	1.02	78096.62
18	1.88	4.17	55.91	1.99	15.63	11.98	1.02	74400.43
19	2.11	4.06	51.95	1.50	19.12	10.43	1.02	83219.79
20	5.00	4.47	48.24	2.37	18.32	10.70	1.02	81573.86
21	3.82	3.66	50.05	2.17	16.93	11.09	1.01	80818.55
22	3.11	4.59	54.15	3.11	15.49	11.87	1.01	75530.11
23	4.49	8.12	61.84	3.12	15.16	11.81	1.01	75967.60
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.31	4.62	51.40	2.04	17.40	11.30	1.01	77966.91
最大值	10.40	8.20	61.84	3.12	20.44	12.01	1.04	83219.79
發生時間	0	15	23	23	6	14		19
最小值	0.80	3.32	41.62	0.70	15.16	10.43	0.97	73818.64
發生時間	6	3	16	8	23	19		14
零點偏移(率)	-0.02 %	-0.00 %	-0.01 %	-0.01 %		-0.05		-0.10 %
全幅偏移(率)	0.14 %	0.46 %	0.01 %	0.39 %		-0.23		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月22日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.18	4.54	52.40	0.21	18.16	11.21	0.97	74702.53
1	4.15	8.35	36.29	0.28	20.83	9.67	0.96	81771.61
2	2.73	3.75	41.19	0.16	18.77	9.75	0.94	79924.07
3	2.50	3.75	52.49	0.15	19.01	9.95	0.92	80307.92
4	2.28	1.77	56.80	0.17	20.13	9.83	0.94	82848.50
5	2.29	1.82	57.60	0.15	19.89	9.90	0.95	82117.55
6	2.45	2.28	52.57	0.17	17.69	11.17	0.95	74421.36
7	1.15	6.07	60.85	0.15	19.10	10.94	0.99	77060.53
8	1.16	4.99	49.42	0.19	18.72	10.36	1.01	81660.34
9	1.15	6.02	42.33	0.20	18.56	10.33	1.00	81484.89
10	0.96	7.80	55.53	0.30	16.84	10.59	0.99	78748.11
11	0.15	11.98	57.67	0.96	15.94	11.05	1.01	80025.63
12	0.72	15.62	53.52	1.22	14.93	11.38	0.99	76912.90
13	2.31	12.91	58.64	0.77	15.97	11.43	0.99	77732.55
14	1.11	12.00	58.52	0.75	16.24	11.15	0.99	80713.60
15	1.58	11.89	61.06	0.70	17.21	11.02	1.00	81133.79
16	2.43	5.15	43.13	0.25	18.42	10.04	1.01	89622.46
17	2.78	6.96	37.07	0.37	18.40	9.73	0.98	88861.05
18	2.59	1.76	37.32	0.28	17.47	9.92	0.99	85048.27
19	2.56	3.95	39.39	0.21	19.04	9.54	0.99	87735.92
20	2.40	5.27	55.64	0.21	21.02	9.85	1.04	89109.11
21	2.82	5.76	48.38	0.27	19.57	9.25	0.99	96083.12
22	3.73	7.40	44.61	0.70	16.96	10.12	0.99	83135.65
23	2.94	4.40	54.53	0.68	15.41	11.08	0.99	78626.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.17	6.51	50.29	0.40	18.09	10.39	0.98	82074.50
最大值	4.15	15.62	61.06	1.22	21.02	11.43	1.29	96083.12
發生時間	1	12	15	12	20	13		21
最小值	0.15	1.76	36.29	0.15	14.93	9.25	0.92	74421.36
發生時間	11	18	1	3	12	21		6
零點偏移(率)	-0.02 %	-0.02 %	-0.02 %	-0.01 %		-0.05		0.00 %
全幅偏移(率)	0.02 %	0.65 %	-0.53 %	0.24 %		-0.13		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								