

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年02月12日

報表日期: 113年02月12日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.96	9.56	56.11	1.33	14.35	12.52	1.04	76362.99
1	9.90	10.89	55.68	0.93	15.15	12.01	1.06	80021.24
2	12.09	10.00	59.65	1.72	14.15	11.67	1.03	84339.74
3	10.25	9.49	43.02	1.56	15.41	11.80	1.02	81907.47
4	9.37	8.67	45.38	1.20	15.32	11.63	1.02	83720.12
5	8.72	8.46	54.99	1.70	14.11	12.52	1.02	79963.71
6	11.34	9.39	43.93	2.38	12.76	12.29	1.02	81885.67
7	8.72	11.36	48.06	2.23	12.84	12.56	1.02	77981.46
8	7.69	11.95	61.44	1.29	14.06	12.19	1.07	79842.38
9	11.75	12.84	47.52	2.09	13.16	11.89	1.03	83001.83
10	7.81	9.99	47.49	1.93	13.29	12.50	1.05	77434.39
11	6.90	5.95	58.51	0.79	14.98	11.88	1.04	81286.00
12	9.70	5.28	61.11	1.49	13.74	11.77	1.05	83104.94
13	8.22	8.49	45.32	1.76	14.11	11.99	1.06	80859.29
14	7.39	6.00	45.76	1.04	14.74	11.71	1.03	82700.67
15	5.84	9.30	46.22	2.01	13.27	12.28	1.05	78764.65
16	10.05	8.36	49.32	1.26	15.26	11.61	1.06	83097.65
17	12.04	8.45	46.54	1.71	13.71	11.80	1.05	82796.12
18	14.20	8.53	44.80	2.23	13.91	11.90	1.02	81420.69
19	10.81	8.14	53.03	0.97	15.28	11.52	1.05	83654.79
20	9.44	9.45	44.92	1.34	14.44	11.92	1.05	81197.64
21	7.03	9.64	61.31	1.04	15.61	11.94	1.05	80046.33
22	8.97	10.65	42.00	1.65	14.10	11.77	1.02	82461.20
23	8.14	10.37	51.53	1.67	14.36	12.32	1.03	77838.25
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.35	9.22	50.57	1.55	14.25	12.00	1.04	81070.38
最 大 值	14.20	12.84	61.44	2.38	15.61	12.56	1.15	84339.74
發生時間	18	9	8	6	21	7		2
最 小 值	5.84	5.28	42.00	0.79	12.76	11.52	1.02	76362.99
發生時間	15	12	22	11	6	19		0
零點偏移(率)	-0.01 %	0.00 %	-0.04 %	-0.01 %		-0.01		0.30 %
全幅偏移(率)	0.02 %	-0.22 %	0.01 %	0.11 %		0.14		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月12日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.65	4.99	49.96	1.77	14.68	11.67	1.11	77621.36
1	8.31	5.15	42.31	2.09	15.56	11.11	1.10	81246.02
2	9.37	4.91	46.23	2.34	14.59	11.40	1.10	79973.74
3	9.60	4.95	42.36	2.63	14.46	11.40	1.10	80265.26
4	7.74	4.60	54.15	1.75	15.23	11.45	1.10	78868.16
5	9.43	4.73	41.69	2.76	13.67	11.48	1.10	80538.91
6	10.85	4.53	47.02	2.46	12.39	11.88	1.06	78713.00
7	9.76	4.52	47.23	2.44	13.17	11.70	1.07	79008.00
8	10.27	4.96	46.06	3.10	12.33	11.89	1.10	77330.17
9	9.84	4.77	47.90	2.94	12.49	11.82	1.07	78378.16
10	9.10	5.87	49.28	2.77	11.65	12.36	1.09	74412.60
11	2.91	7.16	58.75	2.20	12.99	12.54	1.07	71023.27
12	3.33	5.54	51.89	2.51	12.84	11.57	1.09	79491.98
13	9.74	5.28	51.67	2.43	13.28	11.88	1.10	77033.61
14	9.18	4.78	49.32	2.73	13.29	11.48	1.10	79539.60
15	5.84	4.67	50.00	2.20	12.26	12.15	1.09	75363.97
16	8.62	7.03	45.17	2.41	13.31	11.58	1.10	79071.66
17	10.10	4.85	48.73	2.22	13.56	11.78	1.09	77213.44
18	8.80	6.66	50.69	2.48	12.29	12.33	1.06	73671.86
19	8.98	4.30	54.71	2.00	14.03	11.57	1.08	78540.77
20	8.76	4.46	48.75	2.24	13.53	11.59	1.10	78722.67
21	7.62	5.57	45.39	2.14	13.46	11.78	1.09	77265.47
22	9.67	6.29	45.88	2.38	12.90	11.86	1.08	77052.82
23	9.68	5.37	46.46	2.94	12.19	11.83	1.07	77806.48
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.42	5.25	48.40	2.41	13.34	11.75	1.09	77839.71
最 大 值	10.85	7.16	58.75	3.10	15.56	12.54	1.11	81246.02
發生時間	6	11	11	8	1	11		1
最 小 值	2.91	4.30	41.69	1.75	11.65	11.11	1.05	71023.27
發生時間	11	19	5	4	10	1		11
零點偏移(率)	-0.05 %	-0.01 %	-0.06 %	-0.00 %		0.07		0.10 %
全幅偏移(率)	0.00 %	0.37 %	-0.30 %	0.36 %		0.23		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月12日

[illegible]