

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年03月03日

報表日期: 113年03月03日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.70	4.39	39.70	1.77	15.34	12.54	1.13	75261.63
1	3.76	4.90	51.83	1.03	17.00	12.40	1.13	75077.43
2	5.37	7.05	52.38	1.21	17.38	11.51	1.13	82520.25
3	8.03	6.86	49.78	0.80	17.66	11.52	1.13	82333.84
4	8.55	7.19	53.91	1.13	17.28	11.31	1.13	84420.38
5	9.42	6.25	56.26	0.84	17.53	11.31	1.10	83077.18
6	8.89	6.20	47.07	1.46	16.45	11.57	1.09	82909.68
7	8.84	6.10	52.12	1.52	15.90	11.90	1.09	80947.67
8	9.24	5.73	47.72	1.75	16.01	11.51	1.10	83873.48
9	8.11	6.01	62.05	1.09	16.38	11.79	1.08	80955.26
10	5.83	7.37	63.97	1.59	16.09	12.34	1.07	75904.47
11	8.99	6.38	46.57	1.79	16.22	11.48	1.05	83333.72
12	9.38	5.87	53.15	1.95	15.86	11.58	1.06	82550.19
13	8.24	6.04	64.17	1.05	16.70	11.66	1.06	81615.24
14	7.81	6.31	52.10	1.47	16.04	11.49	1.06	83541.93
15	9.44	6.49	64.74	1.50	16.79	11.69	1.06	81322.64
16	9.27	6.21	45.16	1.14	17.22	11.35	1.06	83282.71
17	9.21	5.72	49.06	1.44	16.77	11.35	1.06	84147.14
18	9.78	5.93	52.74	1.85	16.14	11.67	1.06	81945.77
19	10.28	6.34	51.31	2.63	14.64	11.87	1.06	81848.59
20	8.75	6.12	51.53	2.01	15.85	11.76	1.06	81661.40
21	9.77	6.06	52.52	1.62	16.18	11.64	1.08	81795.07
22	10.46	7.45	42.92	2.18	15.77	11.72	1.09	81690.10
23	9.66	6.58	50.57	2.26	14.85	11.98	1.09	80262.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.53	6.23	52.22	1.54	16.34	11.71	1.08	81511.58
最 大 值	10.46	7.45	64.74	2.63	17.66	12.54	1.14	84420.38
發生時間	22	22	15	19	3	0		4
最 小 值	3.76	4.39	39.70	0.80	14.64	11.31	1.05	75077.43
發生時間	1	0	0	3	19	4		1
零點偏移(率)	-0.04 %	-0.03 %	-0.03 %	-0.01 %		-0.04		0.20 %
全幅偏移(率)	0.00 %	-0.24 %	-0.57 %	0.05 %		0.16		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月03日

項目 單位	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.37	4.27	47.36	1.58	17.16	11.51	1.07	76921.85
1	5.73	4.78	39.41	2.22	18.98	10.64	1.07	81634.08
2	7.27	4.59	43.73	2.68	17.03	10.98	1.07	81367.16
3	5.06	3.91	51.49	1.87	17.18	11.08	1.07	80482.81
4	7.20	4.01	40.97	2.23	17.32	10.73	1.06	83189.58
5	8.69	4.10	41.52	2.62	16.88	10.95	1.06	81789.43
6	9.68	7.81	53.21	2.89	16.65	10.99	1.06	79089.00
7	7.29	4.54	55.68	2.76	16.15	11.29	1.06	78787.21
8	8.38	4.17	54.24	3.03	15.64	11.29	1.06	80361.83
9	8.19	4.00	59.32	2.70	15.97	11.38	1.05	78786.72
10	6.59	4.50	52.61	2.34	16.41	11.65	1.02	76465.90
11	9.50	4.44	43.40	3.25	15.29	11.32	1.03	80078.22
12	7.94	3.78	43.44	2.89	15.99	11.25	1.06	79360.78
13	8.07	3.97	46.21	2.48	17.18	10.96	1.06	80280.83
14	9.40	5.80	40.48	2.65	17.20	10.92	1.04	81482.31
15	9.22	1.50	47.68	2.65	16.77	11.26	1.04	78896.45
16	8.55	1.41	45.79	2.98	15.99	11.14	1.04	81064.59
17	10.16	1.86	50.22	3.52	13.91	11.91	1.04	76613.40
18	9.50	1.64	48.76	3.34	14.97	11.52	1.02	78626.23
19	9.39	3.91	43.11	3.90	14.39	11.75	1.03	76933.55
20	8.42	3.86	46.77	2.99	15.04	11.63	1.04	77335.83
21	9.41	3.92	45.00	3.27	14.47	11.90	1.06	75581.36
22	9.64	3.76	41.39	3.02	15.50	11.46	1.06	78456.79
23	9.83	6.40	42.88	3.48	14.68	11.74	1.07	76949.97
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.14	4.04	46.86	2.81	16.11	11.30	1.05	79189.00
最 大 值	10.16	7.81	59.32	3.90	18.98	11.91	1.10	83189.58
發生時間	17	6	9	19	1	17		4
最 小 值	2.37	1.41	39.41	1.58	13.91	10.64	1.02	75581.36
發生時間	0	16	1	0	17	1		21
零點偏移(率)	-0.02 %	-0.04 %	-0.06 %	0.00 %		-0.04		0.00 %
全幅偏移(率)	0.13 %	0.40 %	0.56 %	0.24 %		0.03		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月03日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	2.21	4.41	61.71	0.61	15.89	11.67	1.14	72476.82
1	0.52	4.96	57.36	0.53	17.56	11.20	1.13	75838.88
2	3.33	6.39	57.48	0.80	16.33	10.79	1.13	80448.30
3	3.67	6.09	56.93	0.88	16.20	10.83	1.13	80255.01
4	4.67	6.19	59.59	0.93	16.50	10.92	1.14	78487.28
5	5.99	5.73	59.90	0.77	17.30	10.53	1.14	81255.04
6	8.25	6.00	57.63	1.09	16.47	10.68	1.13	80591.08
7	10.37	5.56	56.76	1.81	15.35	11.01	1.15	78501.76
8	7.66	6.18	57.02	1.27	16.23	10.66	1.15	81295.93
9	9.65	6.24	57.42	1.24	16.68	10.61	1.13	80793.72
10	8.30	5.83	64.65	0.99	17.36	10.69	1.15	79936.65
11	7.76	5.17	54.91	1.04	16.72	10.47	1.15	81459.18
12	8.14	7.03	52.71	1.50	15.87	10.52	1.15	81613.86
13	4.14	2.59	56.24	1.00	17.25	10.54	1.15	80673.88
14	6.07	3.90	53.85	0.89	17.42	10.40	1.15	81591.57
15	2.42	5.20	55.40	0.76	16.48	10.66	1.15	80253.60
16	2.12	5.17	59.23	0.72	16.22	10.98	1.15	78156.99
17	9.56	5.99	60.63	2.14	14.32	11.02	1.15	78847.95
18	7.14	7.33	65.24	2.59	13.54	11.67	1.15	72253.08
19	3.86	16.87	48.93	5.59	13.17	11.46	1.14	71186.68
20	9.34	2.81	45.52	2.25	14.24	11.17	1.15	73407.19
21	9.69	2.14	44.34	1.55	15.68	10.93	1.15	76452.57
22	8.92	2.17	42.13	1.87	14.51	11.32	1.15	73312.21
23	8.77	6.57	43.31	1.58	15.25	11.04	1.15	75597.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.36	5.69	55.37	1.43	15.94	10.91	1.14	78111.96
最 大 值	10.37	16.87	65.24	5.59	17.56	11.67	1.17	81613.86
發生時間	7	19	18	19	1	0		12
最 小 值	0.52	2.14	42.13	0.53	13.17	10.40	1.11	71186.68
發生時間	1	21	22	1	19	14		19
零點偏移(率)	-0.13 %	0.00 %	-0.02 %	-0.03 %		0.00		-0.10 %
全幅偏移(率)	0.02 %	-0.06 %	-0.74 %	0.05 %		0.23		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								