

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月17日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.92	5.11	49.19	2.47	16.53	12.41	1.35	70104.50
1	7.96	6.22	48.01	2.87	15.85	12.70	1.36	71929.83
2	10.90	2.64	53.47	2.69	16.64	12.39	1.36	72665.67
3	10.33	2.29	48.93	2.40	16.94	11.82	1.37	75090.06
4	14.39	3.21	51.20	2.61	16.42	12.21	1.39	71345.37
5	9.82	4.94	49.30	2.43	16.83	11.98	1.41	67382.87
6	7.64	3.55	58.11	2.17	17.64	12.06	1.43	72555.85
7	6.09	6.92	53.94	2.19	17.92	11.70	1.45	74973.05
8	13.62	1.23	50.28	2.37	17.69	11.67	1.43	75039.46
9	9.00	3.81	47.20	2.29	17.44	11.83	1.39	74248.58
10	9.49	6.03	45.93	2.50	16.51	12.07	1.38	72898.18
11	9.41	4.63	50.14	2.47	16.68	12.16	1.38	72255.38
12	6.55	3.59	57.34	2.20	17.35	11.98	1.39	73112.91
13	9.90	7.99	48.16	2.47	16.53	12.04	1.38	72179.51
14	9.58	7.67	54.29	2.07	18.58	11.40	1.40	76326.60
15	13.26	9.58	50.50	7.99	17.00	12.03	1.40	72942.31
16	6.85	9.17	48.11	5.02	16.55	12.74	1.39	69895.33
17	9.36	1.59	52.04	1.97	17.07	12.03	1.37	74032.53
18	9.29	2.17	55.09	2.27	17.36	12.19	1.38	72458.60
19	10.66	1.07	52.33	2.20	18.15	11.62	1.37	75548.30
20	12.62	3.52	51.11	2.70	16.93	11.90	1.38	73276.57
21	11.29	1.93	49.09	2.44	16.92	11.98	1.38	72420.77
22	11.74	1.08	52.92	2.31	17.73	11.82	1.37	73465.17
23	9.94	2.89	54.43	2.30	17.63	12.00	1.39	71962.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.94	4.28	51.30	2.73	17.12	12.03	1.39	72837.93
最大值	14.39	9.58	58.11	7.99	18.58	12.74	1.46	76326.60
發生時間	4	15	6	15	14	16		14
最小值	6.09	1.07	45.93	1.97	15.85	11.40	1.34	67382.87
發生時間	7	19	10	17	1	14		5
零點偏移(率)	-0.02 %	0.00 %	-0.05 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	-1.75 %	-0.08 %	-0.21 %	0.08 %		0.40	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月17日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.60	2.48	62.92	2.00	16.42	10.89	1.42	65863.34
1	9.50	3.09	52.03	1.89	17.31	10.84	1.43	64043.42
2	10.19	1.41	48.20	2.40	15.56	10.81	1.44	64224.60
3	10.88	0.46	60.75	2.38	15.48	10.91	1.45	65148.04
4	9.96	3.01	51.76	2.56	14.73	11.15	1.45	63894.19
5	11.48	7.32	54.12	2.24	16.15	10.46	1.44	64460.32
6	12.61	5.79	50.92	2.14	15.55	10.63	1.41	62011.77
7	9.29	5.66	52.11	2.19	15.50	10.77	1.41	62406.71
8	10.48	1.43	52.77	2.24	15.17	10.67	1.39	61520.60
9	11.92	2.34	52.58	2.47	14.69	10.82	1.37	63027.74
10	9.45	1.39	57.86	2.34	14.67	10.92	1.37	62985.90
11	10.68	0.93	57.53	2.52	14.94	11.00	1.38	62641.11
12	10.75	0.75	57.42	2.33	15.40	10.91	1.38	63514.11
13	10.81	1.46	60.54	2.65	14.61	11.20	1.38	63463.80
14	12.49	2.25	50.30	2.63	14.81	11.07	1.38	62076.38
15	14.11	3.71	59.55	5.83	15.82	10.72	1.38	63401.55
16	12.93	5.72	54.63	10.40	13.42	11.52	1.38	60895.01
17	11.30	3.07	51.37	5.79	15.74	10.58	1.38	60484.96
18	9.76	1.27	57.92	2.14	16.41	10.94	1.38	61349.84
19	10.28	0.83	61.72	1.75	17.50	10.75	1.38	65405.14
20	10.29	1.31	52.17	1.99	16.65	10.80	1.38	64592.61
21	9.45	2.58	61.50	2.01	16.25	10.99	1.38	64264.02
22	10.61	2.36	54.35	1.69	17.32	10.40	1.38	63827.44
23	10.98	13.83	41.30	1.95	17.70	9.90	1.38	63108.37
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.83	3.10	54.85	2.86	15.74	10.82	1.40	63275.46
最大值	14.11	13.83	62.92	10.40	17.70	11.52	1.46	65863.34
發生時間	15	23	0	16	23	16		0
最小值	9.29	0.46	41.30	1.69	13.42	9.90	1.36	60484.96
發生時間	7	3	23	22	16	23		17
零點偏移(率)	-0.13 %	-0.00 %	-0.01 %	-0.02 %		-0.02	0.00	0.00 %
全幅偏移(率)	0.02 %	0.00 %	0.16 %	0.02 %		0.34	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月17日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.38	4.74	56.33	1.98	14.69	11.14	1.72	85554.84
1	13.19	6.75	53.90	1.66	17.29	10.56	1.72	89018.32
2	10.84	10.57	54.12	2.17	14.81	11.24	1.72	86088.69
3	15.73	3.53	53.34	2.53	14.52	11.23	1.74	86221.57
4	10.33	4.44	56.06	2.45	14.08	11.40	1.76	85599.81
5	12.52	2.37	55.77	2.22	14.52	11.29	1.77	86289.12
6	12.23	5.64	61.15	2.82	13.83	11.55	1.77	86171.68
7	14.16	3.35	56.92	2.13	14.88	11.24	1.77	88317.53
8	9.19	2.97	53.98	1.97	15.30	11.21	1.73	86226.73
9	11.50	5.98	57.81	2.71	13.56	11.88	1.71	84698.78
10	12.90	9.67	55.68	3.46	12.27	12.22	1.71	84081.58
11	11.61	9.70	52.26	3.78	12.16	12.04	1.71	80471.39
12	14.55	2.72	51.37	3.53	12.62	12.19	1.71	78336.63
13	12.26	3.22	55.05	3.73	12.13	12.34	1.72	79090.79
14	13.38	2.60	60.35	3.89	12.29	12.33	1.72	80423.82
15	8.74	7.02	53.65	3.99	12.05	12.18	1.72	79286.56
16	15.35	3.55	50.79	3.15	13.40	11.39	1.72	79384.37
17	8.00	1.75	57.03	2.62	13.69	11.65	1.72	78395.55
18	7.79	2.63	54.08	1.59	16.49	10.81	1.72	82177.58
19	13.41	1.78	54.39	2.01	15.55	11.08	1.72	81844.97
20	9.50	3.16	60.42	2.18	15.10	11.28	1.73	81619.40
21	10.85	1.55	53.38	1.97	15.72	11.23	1.73	82765.78
22	14.44	0.96	53.60	2.09	15.08	11.28	1.72	81917.85
23	12.34	3.39	56.17	2.46	15.20	11.16	1.71	82575.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	11.92	4.33	55.32	2.63	14.22	11.50	1.73	83189.94
最大值	15.73	10.57	61.15	3.99	17.29	12.34	1.77	89018.32
發生時間	3	2	6	15	1	13		1
最小值	7.79	0.96	50.79	1.59	12.05	10.56	1.70	78336.63
發生時間	18	22	16	18	15	1		12
零點偏移(率)	0.00 %	-0.00 %	-0.02 %	-0.01 %		0.02	0.00	0.00 %
全幅偏移(率)	0.02 %	-0.01 %	-0.24 %	0.03 %		0.37	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								