

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年01月01日

報表日期: 114年01月01日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.15	3.03	54.29	0.99	15.17	12.44	1.25	74613.69
1	6.59	2.97	46.21	1.37	15.38	12.19	1.24	78207.02
2	8.51	3.05	53.72	1.16	14.80	12.21	1.24	78065.20
3	9.86	5.97	42.02	2.20	13.23	12.05	1.24	80226.69
4	9.28	6.23	54.63	2.32	13.35	12.69	1.25	74076.34
5	12.09	3.61	51.47	1.13	15.01	12.19	1.27	77565.98
6	8.83	4.37	58.00	1.00	14.72	12.25	1.27	77286.89
7	7.98	3.02	48.94	2.01	13.56	12.79	1.29	74219.31
8	11.90	3.01	62.96	1.50	15.18	12.38	1.28	76901.88
9	7.66	2.69	56.48	1.34	15.04	12.07	1.29	79699.47
10	7.97	2.52	62.07	0.55	16.23	11.99	1.29	79447.79
11	9.18	2.90	50.62	1.29	14.55	12.01	1.29	80162.95
12	8.21	3.32	45.30	2.00	13.84	12.18	1.29	78639.30
13	15.47	3.65	49.43	1.26	14.84	11.93	1.30	80602.36
14	6.95	3.98	55.36	0.77	14.45	11.92	1.33	80429.85
15	11.03	2.89	52.27	1.91	13.66	12.08	1.32	79117.12
16	12.16	2.88	46.09	2.08	13.79	12.16	1.31	78358.35
17	13.22	3.09	45.07	1.86	14.30	12.06	1.29	77630.13
18	16.07	4.82	47.18	2.54	14.11	11.99	1.29	77082.75
19	15.86	3.43	45.64	2.50	14.55	12.02	1.29	77366.95
20	15.27	4.10	57.71	2.70	14.71	11.88	1.29	78873.79
21	13.46	3.17	54.70	3.31	14.40	11.98	1.29	78080.11
22	9.65	5.46	66.60	2.45	15.39	11.72	1.30	79051.84
23	5.25	4.31	56.72	3.12	13.61	12.28	1.31	76166.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.32	3.69	52.65	1.81	14.49	12.14	1.28	77994.66
最 大 值	16.07	6.23	66.60	3.31	16.23	12.79	1.35	80602.36
發生時間	18	4	22	21	10	7		13
最 小 值	5.15	2.52	42.02	0.55	13.23	11.72	1.23	74076.34
發生時間	0	10	3	10	3	22		4
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	0.00 %		-0.20		0.30 %
全幅偏移(率)	0.00 %	-0.00 %	-0.21 %	0.28 %		-0.26		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

