

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年01月03日

報表日期: 113年01月03日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.48	7.96	66.65	0.89	17.51	11.27	1.03	83635.61
1	9.00	13.44	38.74	1.72	17.14	11.35	0.98	83862.57
2	8.67	11.44	50.67	2.20	14.47	11.99	1.01	81555.67
3	8.20	11.56	60.07	2.12	14.70	11.94	1.02	81189.58
4	7.85	11.47	52.26	2.09	14.62	12.00	1.02	81264.30
5	4.05	11.14	72.71	0.77	16.35	12.08	1.05	77883.69
6	3.89	12.65	45.17	1.09	16.34	11.49	1.05	83801.29
7	7.13	11.52	53.09	2.22	14.35	11.94	1.03	81516.92
8	7.69	9.33	54.57	2.82	13.45	12.19	1.02	78681.10
9	7.49	8.41	56.51	2.06	14.48	12.25	1.02	77422.60
10	8.11	8.26	64.84	1.29	15.81	11.98	1.02	80115.29
11	7.83	7.81	55.33	1.53	15.39	11.61	1.03	83921.41
12	9.67	11.68	43.36	3.03	13.85	11.87	1.05	82204.49
13	9.50	7.40	54.12	3.47	13.45	12.50	1.03	76400.63
14	8.15	7.50	63.28	1.60	14.97	12.01	1.04	80633.25
15	9.39	3.15	47.72	2.04	14.49	11.72	1.03	83198.00
16	9.73	6.80	43.59	2.81	12.85	12.23	1.02	78984.47
17	8.98	8.71	36.91	2.99	13.80	11.72	1.03	83320.73
18	9.54	6.53	41.30	2.91	13.57	11.92	1.02	80701.57
19	9.37	6.63	40.35	3.04	13.25	11.77	1.04	81979.27
20	9.10	10.72	50.07	2.49	13.89	11.79	1.03	82343.72
21	9.19	11.00	49.70	2.07	14.10	11.79	1.02	83563.19
22	9.28	10.92	56.86	1.86	14.46	11.93	1.05	81856.91
23	8.42	11.86	63.50	0.97	15.90	11.82	1.06	81277.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.11	9.50	52.56	2.09	14.72	11.88	1.03	81304.72
最 大 值	9.73	13.44	72.71	3.47	17.51	12.50	1.08	83921.41
發生時間	16	1	5	13	0	13		11
最 小 值	3.89	3.15	36.91	0.77	12.85	11.27	0.97	76400.63
發生時間	6	15	17	5	16	0		13
零點偏移(率)	-0.02 %	-0.05 %	-0.09 %	-0.01 %		-0.04		0.00 %
全幅偏移(率)	0.02 %	-0.05 %	0.67 %	0.27 %		-0.06		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年01月03日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	3.65	6.60	53.00	0.76	17.49	10.29	0.99	80425.11
1	4.29	3.31	45.19	0.85	18.26	10.04	0.99	79864.96
2	9.87	3.56	37.82	1.86	16.60	9.75	0.98	77212.76
3	2.30	9.14	37.78	1.50	15.59	9.91	0.98	75166.75
4	8.53	8.81	35.28	1.99	18.05	9.37	0.99	79207.38
5	4.92	11.64	39.38	1.88	16.99	9.95	0.99	75781.09
6	3.11	4.81	37.58	1.23	16.72	9.85	0.97	79037.76
7	6.02	8.81	44.16	1.71	16.63	10.01	0.99	72825.13
8	2.37	4.05	51.12	0.93	17.97	9.56	0.99	71897.91
9	1.75	6.70	48.58	0.99	17.95	9.15	0.98	76781.84
10	1.46	7.48	53.53	0.81	16.33	10.74	1.00	74999.93
11	0.61	7.17	55.92	1.31	14.54	10.94	1.00	77136.76
12	6.87	4.63	54.89	1.67	14.43	10.94	1.00	79884.24
13	9.34	6.32	57.97	2.10	15.35	10.92	1.03	79655.16
14	5.36	4.26	53.40	2.54	15.49	10.37	1.03	80535.85
15	9.76	4.16	61.52	2.18	15.57	10.38	1.04	80138.88
16	4.01	7.65	51.11	2.12	13.36	11.07	1.04	76070.74
17	6.96	2.61	50.27	2.26	14.35	10.61	1.03	77339.25
18	3.81	2.24	57.06	1.19	15.24	10.65	1.02	75001.02
19	11.69	6.12	51.52	1.97	14.91	10.13	1.02	78982.14
20	9.18	4.39	53.36	3.36	14.10	10.48	0.99	77175.57
21	10.49	4.91	53.60	2.40	15.15	10.32	0.98	76579.24
22	11.66	4.37	54.94	6.60	14.45	10.49	1.00	76806.07
23	10.43	5.38	55.53	2.34	14.69	10.64	1.01	77517.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.18	5.80	49.77	1.94	15.84	10.27	1.00	77334.28
最 大 值	11.69	11.64	61.52	6.60	18.26	11.07	1.06	80535.85
發生時間	19	5	15	22	1	16		14
最 小 值	0.61	2.24	35.28	0.76	13.36	9.15	0.97	71897.91
發生時間	11	18	4	0	16	9		8
零點偏移(率)	-0.08 %	-0.00 %	-0.01 %	-0.04 %		0.01		0.30 %
全幅偏移(率)	0.03 %	-0.60 %	-0.31 %	0.08 %		0.03		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								