

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月25日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.73	12.55	58.92	1.39	16.79	12.05	1.19	69739.42
1	0.96	11.90	46.99	2.89	17.65	11.43	1.18	74056.19
2	3.47	12.09	57.98	1.63	18.89	11.42	1.18	73233.84
3	8.35	11.46	37.84	3.01	18.67	10.76	1.18	77711.24
4	8.29	12.21	37.49	2.66	20.30	10.53	1.20	78483.99
5	13.82	13.21	48.91	2.45	17.66	11.26	1.18	77157.50
6	4.91	12.94	63.38	1.70	18.27	11.40	1.19	73556.48
7	11.41	12.93	50.94	3.65	16.31	11.55	1.19	74131.35
8	6.73	12.56	57.00	2.28	17.04	11.49	1.20	73850.00
9	7.34	11.67	56.15	1.61	17.67	11.32	1.24	75000.20
10	3.47	11.62	53.63	1.52	17.49	11.28	1.25	75081.96
11	4.95	11.83	51.24	1.67	17.15	11.26	1.24	75309.97
12	8.23	11.72	60.16	1.64	17.63	11.37	1.24	73898.28
13	4.32	11.97	56.93	1.32	17.27	11.51	1.24	72904.95
14	6.06	11.94	59.16	1.66	15.58	11.68	1.24	73154.68
15	7.23	12.06	58.19	2.38	15.24	11.92	1.24	72214.06
16	7.06	11.74	58.10	2.43	16.50	11.50	1.24	73975.91
17	7.60	11.56	61.46	1.30	19.17	11.05	1.25	75307.17
18	9.39	11.44	51.85	2.22	17.87	11.10	1.23	75626.61
19	8.37	11.79	51.97	2.51	16.38	11.52	1.22	73649.09
20	9.23	11.88	55.71	2.63	15.82	11.66	1.23	73175.25
21	8.59	11.64	54.69	2.48	16.81	11.33	1.22	75201.21
22	10.16	11.64	61.70	1.80	18.19	11.24	1.22	73666.16
23	4.76	11.40	51.25	2.16	18.10	10.97	1.23	75516.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.02	11.99	54.24	2.12	17.44	11.36	1.22	74400.10
最大值	13.82	13.21	63.38	3.65	20.30	12.05	1.25	78483.99
發生時間	5	5	6	7	4	0		4
最小值	0.96	11.40	37.49	1.30	15.24	10.53	1.18	69739.42
發生時間	1	23	4	17	15	4		0
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	-0.01 %		-0.05	-0.01	0.30 %
全幅偏移(率)	0.76 %	-1.09 %	0.41 %	-0.26 %		-0.09	0.10	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月25日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.56	11.83	58.73	2.35	17.47	10.37	0.94	80577.46
1	12.38	11.71	64.66	2.20	18.11	10.38	0.94	79826.56
2	8.23	11.72	55.35	2.01	17.84	10.41	0.93	80034.40
3	8.12	11.61	65.10	1.92	18.34	10.26	0.94	80650.74
4	9.97	11.54	47.48	3.99	17.84	10.22	0.94	79954.11
5	11.61	11.53	54.17	2.75	18.31	10.19	0.94	81114.27
6	12.11	11.61	56.22	1.90	17.95	10.44	0.96	78427.81
7	5.36	11.49	53.97	2.19	17.14	10.40	0.95	77361.14
8	9.00	11.29	54.81	2.51	17.20	10.12	0.96	77819.44
9	10.79	11.49	58.12	2.63	17.42	10.15	0.98	78065.06
10	9.07	11.57	57.10	3.35	17.21	10.35	0.98	78431.47
11	4.91	11.46	58.82	2.03	17.87	10.20	0.95	77051.30
12	7.56	11.98	55.16	2.14	17.36	10.25	0.96	77488.95
13	8.98	12.48	63.43	1.55	16.03	11.29	0.95	73349.63
14	9.36	12.40	59.31	1.44	15.93	11.22	0.95	75335.60
15	8.98	12.99	62.99	1.77	16.14	11.50	0.96	70747.25
16	10.76	11.59	55.77	1.40	17.78	10.22	0.96	80556.65
17	9.32	12.19	61.45	0.85	18.19	10.34	0.97	80055.04
18	12.56	11.78	59.50	1.13	18.23	9.94	0.98	82050.25
19	12.77	11.71	47.20	1.27	17.39	10.34	0.98	79027.52
20	8.78	11.96	39.95	1.16	17.69	10.11	0.97	79403.11
21	11.34	12.11	43.92	1.44	17.39	10.08	0.97	79131.49
22	13.75	11.68	59.30	1.46	17.71	10.07	0.98	81724.76
23	9.44	11.66	64.50	0.56	18.93	10.09	0.99	81218.70
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.90	11.81	56.54	1.92	17.56	10.37	0.96	78725.11
最大值	13.75	12.99	65.10	3.99	18.93	11.50	1.00	82050.25
發生時間	22	15	3	4	23	15		18
最小值	4.91	11.29	39.95	0.56	15.93	9.94	0.92	70747.25
發生時間	11	8	20	23	14	18		15
零點偏移(率)	-0.12 %	-0.00 %	-0.04 %	-0.00 %		-0.07	-0.01	0.10 %
全幅偏移(率)	0.36 %	-1.04 %	0.97 %	-0.14 %		0.08	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月25日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.82	12.94	30.17	2.84	18.44	8.59	1.35	73388.66
1	4.88	12.54	32.60	3.14	19.66	8.63	1.35	72964.88
2	7.37	11.73	43.08	2.69	20.46	8.27	1.36	77500.85
3	6.58	10.10	51.00	1.99	17.52	9.42	1.36	73872.28
4	8.41	10.93	44.17	3.90	20.15	8.85	1.36	75278.77
5	4.16	10.88	40.09	2.88	18.20	9.26	1.35	74411.98
6	5.87	11.57	47.82	3.03	18.92	9.25	1.36	75210.50
7	4.36	10.69	40.40	2.81	18.83	9.02	1.32	73818.08
8	5.28	11.10	48.68	2.55	16.60	9.92	1.33	73508.97
9	5.05	11.09	46.32	1.84	16.96	9.72	1.31	74974.35
10	6.00	10.95	47.74	1.83	17.77	9.73	1.33	74372.65
11	8.61	10.99	46.86	2.06	17.47	9.72	1.34	75498.22
12	9.97	11.21	45.50	2.05	17.99	9.85	1.34	76837.00
13	6.41	11.80	53.58	2.03	16.96	10.02	1.34	74971.10
14	8.82	11.18	57.42	2.26	18.41	9.75	1.34	76640.97
15	9.74	11.71	54.39	2.94	16.25	10.04	1.32	74003.94
16	5.98	11.26	55.56	2.84	16.62	9.79	1.31	76787.83
17	6.62	11.25	53.18	2.65	17.32	9.99	1.33	76200.51
18	6.91	11.16	53.95	2.90	16.92	9.86	1.32	76476.73
19	6.33	11.52	54.46	2.84	17.39	9.79	1.31	77060.61
20	6.05	11.53	53.85	2.63	17.38	10.08	1.34	77329.06
21	9.18	11.29	58.09	3.02	17.53	9.98	1.34	78141.85
22	7.17	11.48	61.67	2.94	18.32	10.08	1.34	76713.35
23	6.64	11.82	54.16	2.84	18.48	9.81	1.34	79688.68
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.68	11.36	48.95	2.65	17.94	9.56	1.34	75652.16
最大值	9.97	12.94	61.67	3.90	20.46	10.08	1.37	79688.68
發生時間	12	0	22	4	2	20		23
最小值	3.82	10.10	30.17	1.83	16.25	8.27	1.31	72964.88
發生時間	0	3	0	10	15	2		1
零點偏移(率)	-0.03 %	-0.01 %	-0.03 %	-0.00 %		-0.10	-0.01	0.00 %
全幅偏移(率)	0.96 %	-0.87 %	0.08 %	0.03 %		0.20	0.04	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								