

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月11日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	3.85	12.79	52.16	1.69	18.77	11.03	1.14	74637.82
1	7.10	13.30	47.83	2.36	17.79	11.46	1.13	73045.24
2	14.78	13.07	59.09	3.21	18.72	11.13	1.13	74403.00
3	10.95	13.20	59.83	2.22	18.87	11.41	1.13	72649.44
4	4.80	14.61	56.00	1.63	18.35	12.37	1.13	65984.79
5	2.70	11.60	54.06	2.10	17.35	11.28	1.13	72719.13
6	5.55	12.20	51.54	2.29	17.88	11.24	1.13	74221.49
7	13.54	12.65	58.43	3.53	18.18	11.04	1.13	75245.44
8	9.11	13.30	56.10	2.25	16.72	11.68	1.13	72030.83
9	5.99	13.11	64.01	1.42	18.21	11.45	1.14	72179.00
10	3.85	12.77	54.39	1.38	18.29	11.22	1.13	73442.80
11	12.60	13.04	60.18	1.02	19.00	11.35	1.13	73288.88
12	7.71	12.49	55.94	0.85	18.71	10.98	1.13	75057.32
13	10.80	12.84	60.18	1.08	17.46	11.39	1.12	72757.47
14	8.10	12.83	73.54	0.71	19.81	11.10	1.13	73342.76
15	10.31	12.30	56.91	0.75	20.14	10.58	1.13	77485.55
16	12.76	12.60	34.35	1.24	18.46	10.67	1.13	78150.86
17	7.80	12.83	34.39	0.82	18.98	11.04	1.13	74562.13
18	12.17	12.82	40.54	0.91	18.26	11.21	1.13	74089.23
19	8.06	13.12	32.36	1.02	17.55	11.33	1.13	73687.89
20	15.25	13.18	45.54	1.29	17.13	11.49	1.13	72377.95
21	8.12	12.72	43.96	1.25	18.88	10.96	1.13	75463.77
22	12.32	12.38	44.60	1.36	19.36	10.73	1.13	76598.03
23	4.63	13.65	49.01	1.54	17.18	11.88	1.12	69352.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.87	12.89	51.87	1.58	18.34	11.25	1.13	73615.54
最 大 值	15.25	14.61	73.54	3.53	20.14	12.37	1.15	78150.86
發生時間	20	4	14	7	15	4		16
最 小 值	2.70	11.60	32.36	0.71	16.72	10.58	1.10	65984.79
發生時間	5	5	19	14	8	15		4
零點偏移(率)	-0.03 %	-0.03 %	-0.08 %	-0.01 %		-0.02	-0.01	0.20 %
全幅偏移(率)	-1.67 %	1.18 %	0.34 %	0.33 %		-0.30	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月11日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.32	12.80	46.51	2.23	20.23	9.37	1.30	76313.53
1	6.85	12.81	42.72	1.94	21.33	9.22	1.36	75631.78
2	5.19	13.27	46.88	2.17	20.95	9.46	1.32	74797.08
3	5.67	11.43	37.99	3.22	20.69	8.49	1.27	74816.05
4	2.20	12.15	60.48	1.85	19.89	9.91	1.27	70632.66
5	2.22	11.42	45.61	1.66	21.13	9.44	1.27	75394.46
6	3.29	11.25	53.68	2.39	20.48	9.39	1.27	75066.53
7	5.40	11.74	46.20	2.31	19.19	10.17	1.29	73011.01
8	9.16	11.34	45.15	2.44	19.79	9.65	1.32	74968.73
9	9.77	11.29	45.34	2.24	20.94	9.15	1.29	76392.97
10	9.64	11.76	54.26	2.42	19.62	10.10	1.32	74230.24
11	11.47	12.35	35.25	2.33	20.14	9.45	1.28	75037.52
12	5.98	11.59	45.82	1.95	19.23	9.72	1.30	76685.12
13	8.16	11.79	53.44	2.21	18.11	10.36	1.31	76402.99
14	13.14	11.73	57.87	2.45	20.46	9.84	1.30	79016.98
15	5.16	13.07	51.61	2.38	20.71	9.59	1.27	75650.42
16	9.78	11.12	42.56	2.32	20.46	9.43	1.30	77831.49
17	8.27	11.36	45.92	2.27	18.92	10.00	1.31	76045.30
18	10.06	11.49	50.26	2.60	18.41	10.06	1.30	75654.78
19	9.99	11.59	54.69	2.52	18.91	10.06	1.28	75338.07
20	9.10	11.43	49.07	2.63	18.56	10.06	1.27	75969.62
21	9.36	11.32	45.07	2.48	18.80	9.95	1.27	75444.05
22	8.82	11.64	51.43	2.61	19.35	10.20	1.27	73559.91
23	10.13	11.13	44.48	2.50	19.33	9.69	1.30	77251.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.80	11.79	48.01	2.34	19.82	9.70	1.29	75464.29
最 大 值	13.14	13.27	60.48	3.22	21.33	10.36	1.39	79016.98
發生時間	14	2	4	3	1	13		14
最 小 值	2.20	11.12	35.25	1.66	18.11	8.49	1.26	70632.66
發生時間	4	16	11	5	13	3		4
零點偏移(率)	-0.09 %	0.01 %	-0.03 %	-0.01 %		-0.07	-0.01	0.20 %
全幅偏移(率)	0.49 %	-0.31 %	0.81 %	0.78 %		-0.09	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								