

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月11日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.12	3.32	67.90	3.52	15.28	12.17	1.38	72782.09
1	17.45	3.51	55.13	3.63	15.96	12.11	1.38	71934.31
2	11.61	3.62	60.66	3.27	16.32	11.97	1.36	73211.55
3	9.28	6.59	59.14	4.64	13.56	12.95	1.33	66766.57
4	11.47	5.33	61.18	4.16	13.98	12.64	1.33	69372.55
5	8.60	12.54	63.71	3.36	15.17	12.29	1.33	74273.54
6	10.49	5.80	65.08	3.38	14.97	12.32	1.33	71037.24
7	6.76	6.89	60.87	3.53	14.68	12.77	1.33	67528.04
8	6.22	9.60	66.66	3.96	14.27	13.43	1.34	61938.69
9	6.21	6.35	50.39	2.80	16.11	12.32	1.34	70037.86
10	5.66	5.40	62.94	2.65	16.08	11.91	1.34	72603.50
11	6.55	9.30	57.79	3.97	13.19	12.56	1.35	69867.85
12	9.74	2.45	56.19	4.13	13.62	12.49	1.33	70076.09
13	8.77	2.18	58.00	3.41	14.45	12.26	1.34	71557.05
14	10.52	5.29	52.24	4.26	13.29	12.61	1.33	69221.56
15	11.00	6.46	61.85	5.12	12.38	12.88	1.33	67446.19
16	9.87	2.45	63.87	4.37	13.37	12.61	1.34	69114.11
17	9.12	4.55	61.40	4.36	13.32	12.87	1.39	66947.29
18	8.84	3.98	65.10	4.04	13.71	12.63	1.41	68672.30
19	9.41	9.14	52.10	4.16	13.26	12.69	1.41	68608.16
20	8.49	8.18	59.35	3.75	14.03	12.54	1.40	69433.35
21	2.70	5.93	56.66	3.16	14.49	12.33	1.39	70303.39
22	8.23	7.28	46.43	3.39	14.79	12.62	1.36	67748.56
23	5.37	8.95	54.16	3.16	14.69	12.46	1.36	69015.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.98	6.05	59.12	3.76	14.37	12.52	1.35	69562.38
最大值	17.45	12.54	67.90	5.12	16.32	13.43	1.41	74273.54
發生時間	1	5	0	15	2	8		5
最小值	2.70	2.18	46.43	2.65	12.38	11.91	1.31	61938.69
發生時間	21	13	22	10	15	10		8
零點偏移(率)	-0.06 %	-0.00 %	-0.12 %	-0.01 %		-0.01	0.00	0.00 %
全幅偏移(率)	-0.93 %	1.25 %	-0.47 %	-0.00 %		0.02	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月11日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.27	1.68	56.69	1.90	18.23	10.15	1.38	85195.28
1	9.32	3.69	62.77	1.52	19.56	10.05	1.38	86535.98
2	5.81	2.52	43.24	1.83	19.34	9.88	1.34	83951.65
3	9.93	1.84	53.85	2.68	17.05	10.22	1.34	83254.47
4	10.07	1.51	63.68	2.18	18.28	10.22	1.37	84365.98
5	12.69	3.93	55.31	2.45	18.49	9.94	1.36	87700.93
6	5.33	18.81	54.43	1.59	18.93	10.68	1.36	81481.16
7	4.60	6.23	60.47	1.17	20.03	10.24	1.37	84592.67
8	3.07	5.75	56.16	1.06	20.70	10.00	1.37	86353.21
9	7.03	5.61	51.79	1.65	19.28	9.88	1.38	88795.04
10	10.48	5.56	57.59	2.49	17.39	10.50	1.38	85227.06
11	9.97	5.10	61.85	2.38	17.36	10.67	1.38	82242.94
12	9.43	5.57	65.26	2.56	16.70	10.62	1.38	83842.97
13	10.59	6.35	58.97	2.77	17.11	10.67	1.38	83274.88
14	10.04	6.84	57.70	2.71	16.80	10.57	1.38	84542.92
15	10.51	9.09	60.25	2.42	17.13	10.51	1.38	84732.99
16	12.68	8.41	57.00	2.90	15.39	10.90	1.38	82446.87
17	7.77	5.84	54.15	2.06	16.98	10.38	1.38	80532.11
18	8.52	5.05	48.18	1.75	17.86	10.03	1.38	81751.30
19	9.45	6.30	59.35	2.30	16.22	10.34	1.38	83738.88
20	11.84	7.63	67.89	2.56	16.01	10.65	1.38	78603.30
21	9.67	5.45	54.87	1.76	18.23	10.30	1.38	84435.34
22	10.04	5.53	54.58	1.56	19.24	10.12	1.36	85583.86
23	7.31	7.85	53.50	1.51	19.22	9.69	1.35	84021.78
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.98	5.92	57.06	2.07	17.98	10.30	1.37	84050.15
最大值	12.69	18.81	67.89	2.90	20.70	10.90	1.38	88795.04
發生時間	5	6	20	16	8	16		9
最小值	3.07	1.51	43.24	1.06	15.39	9.69	1.33	78603.30
發生時間	8	4	2	8	16	23		20
零點偏移(率)	-0.05 %	-0.01 %	-0.08 %	-0.03 %		-0.02	0.00	0.00 %
全幅偏移(率)	3.43 %	1.32 %	0.14 %	0.28 %		0.03	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月11日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.72	3.72	67.36	2.64	15.92	10.91	1.80	84669.48
1	10.63	4.22	65.96	2.79	16.14	10.97	1.81	83926.89
2	10.50	3.86	61.24	2.90	16.48	10.68	1.82	85259.22
3	10.27	4.65	63.70	2.98	15.84	10.76	1.83	83969.89
4	9.12	3.46	68.72	2.86	17.00	10.63	1.82	84480.39
5	10.61	3.41	60.51	2.88	16.37	10.52	1.82	85740.48
6	9.58	5.49	62.75	2.84	17.00	10.82	1.84	83729.96
7	9.72	9.78	64.55	2.45	18.89	10.00	1.83	86043.96
8	10.96	9.25	51.17	2.40	18.17	10.34	1.85	89069.57
9	9.11	6.22	67.70	2.25	17.25	10.82	1.84	85131.32
10	9.85	6.09	59.47	2.25	16.98	10.52	1.85	87796.87
11	9.23	6.24	65.24	2.18	16.59	10.99	1.83	82753.43
12	8.84	7.24	63.81	2.38	16.63	10.75	1.84	85551.40
13	15.55	10.04	61.04	4.38	14.66	11.45	1.84	80454.06
14	13.61	4.81	61.97	4.76	13.59	11.78	1.83	77461.52
15	11.84	3.00	63.25	3.25	14.98	11.16	1.83	83681.09
16	10.47	2.20	63.77	2.46	15.42	11.01	1.83	82384.56
17	10.47	2.04	59.55	2.88	14.80	10.95	1.85	80898.34
18	11.00	4.92	54.62	3.05	14.65	10.77	1.83	77790.88
19	11.18	5.14	64.36	2.25	16.24	10.71	1.83	81260.43
20	7.37	11.55	61.90	2.57	15.08	11.29	1.81	77529.02
21	6.17	6.08	55.35	2.12	16.92	11.17	1.83	81999.56
22	5.16	7.02	42.25	1.90	17.53	10.46	1.82	87087.48
23	10.84	12.64	48.06	2.66	15.11	11.21	1.82	83155.35
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.91	5.96	60.76	2.75	16.18	10.86	1.83	83409.38
最大值	15.55	12.64	68.72	4.76	18.89	11.78	1.85	89069.57
發生時間	13	23	4	14	7	14		8
最小值	5.16	2.04	42.25	1.90	13.59	10.00	1.80	77461.52
發生時間	22	17	22	22	14	7		14
零點偏移(率)	0.00 %	-0.00 %	-0.37 %	-0.09 %		0.03	0.00	0.00 %
全幅偏移(率)	1.18 %	0.03 %	-0.03 %	0.03 %		0.00	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								