

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年03月23日

報表日期: 113年03月23日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.80	8.33	40.55	2.06	15.51	12.12	1.06	77847.46
1	9.51	11.65	47.83	2.36	16.04	11.74	1.06	80677.58
2	11.70	6.10	53.62	2.49	15.14	11.89	1.04	80042.28
3	9.71	8.35	50.44	2.39	14.26	11.94	1.03	79493.35
4	8.73	6.77	58.58	1.55	15.72	11.97	1.02	78992.11
5	10.56	13.40	55.28	1.71	15.50	11.58	1.02	79780.09
6	9.20	2.90	65.85	1.82	15.67	11.83	1.02	79748.77
7	7.81	6.13	47.79	2.59	14.35	11.86	1.02	79048.03
8	8.81	6.18	46.80	3.41	13.79	11.98	1.03	77109.10
9	9.19	5.82	59.38	2.39	15.14	12.04	1.05	75658.09
10	9.34	7.10	53.85	2.67	14.11	12.04	1.06	77266.64
11	8.31	6.13	55.13	3.18	13.68	12.19	1.05	76732.27
12	4.52	6.63	66.20	1.42	15.44	12.67	1.06	71852.15
13	7.25	6.64	47.65	1.31	16.11	11.82	1.04	79723.09
14	5.24	6.67	47.10	2.38	14.39	11.81	1.03	79365.38
15	8.90	6.35	53.29	2.78	14.33	11.98	1.02	77737.81
16	8.48	6.59	55.47	3.15	13.89	12.19	1.05	76315.74
17	4.73	6.16	63.32	1.56	15.44	12.17	1.07	76029.73
18	3.24	6.52	40.25	1.21	16.22	11.68	1.06	81336.30
19	3.44	6.40	36.26	2.10	15.19	11.74	1.04	80202.00
20	7.05	6.26	56.84	2.47	15.69	11.64	1.04	79934.35
21	9.15	7.87	59.61	1.55	16.14	11.59	1.04	79739.68
22	8.93	8.69	60.46	1.71	15.59	11.94	1.04	76065.70
23	9.29	9.11	56.50	2.03	15.70	11.66	1.06	79765.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.00	7.20	53.25	2.18	15.13	11.92	1.04	78352.64
最 大 值	11.70	13.40	66.20	3.41	16.22	12.67	1.09	81336.30
發生時間	2	5	12	8	18	12		18
最 小 值	3.24	2.90	36.26	1.21	13.68	11.58	1.02	71852.15
發生時間	18	6	19	18	11	5		12
零點偏移(率)	-0.08 %	-0.10 %	-0.01 %	-0.01 %		0.01		0.10 %
全幅偏移(率)	0.00 %	0.61 %	0.53 %	0.05 %		0.05		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月23日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.34	7.61	52.66	2.29	16.55	11.00	1.06	80528.89
1	3.82	4.69	49.08	3.03	14.55	11.45	1.06	79206.04
2	6.98	4.17	62.75	2.85	15.72	11.29	1.06	79428.55
3	6.82	4.79	54.29	3.03	14.45	11.66	1.05	77731.65
4	8.45	4.06	62.63	2.55	16.34	11.38	1.05	78030.48
5	9.71	6.14	55.18	3.53	14.73	11.47	1.04	78937.94
6	13.64	5.36	56.49	3.84	14.63	11.52	1.04	74294.04
7	2.36	3.46	64.20	1.48	14.29	11.96	1.05	75755.34
8	7.89	2.48	51.48	1.36	15.24	11.28	1.07	79889.82
9	9.51	2.37	53.98	1.32	15.26	11.28	1.07	79203.77
10	9.64	3.33	47.19	1.85	13.61	11.58	1.07	78425.85
11	9.76	4.29	57.76	3.55	13.13	11.71	1.06	77951.87
12	10.43	3.31	54.00	4.07	12.01	11.63	1.06	78731.07
13	9.93	3.62	57.11	2.83	13.95	11.51	1.07	77888.74
14	12.25	3.21	65.34	1.95	14.28	11.72	1.06	76424.95
15	10.09	5.94	55.06	2.50	13.79	11.73	1.07	77059.17
16	3.30	3.78	63.39	1.95	13.28	11.62	1.07	78443.59
17	2.59	4.09	64.07	1.56	14.68	11.26	1.06	80389.87
18	6.33	1.99	53.61	1.55	16.22	10.98	1.06	80897.75
19	9.70	5.48	43.68	2.42	15.40	10.85	1.06	81302.72
20	10.42	2.00	55.80	2.29	15.86	11.03	1.05	80600.36
21	8.57	1.90	63.93	1.66	16.19	11.35	1.05	77441.62
22	11.10	2.78	46.96	2.32	16.38	11.08	1.05	79337.68
23	10.75	2.50	56.28	3.44	14.83	11.48	1.05	77929.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.39	3.89	56.12	2.47	14.81	11.41	1.06	78576.32
最 大 值	13.64	7.61	65.34	4.07	16.55	11.96	1.10	81302.72
發生時間	6	0	14	12	0	7		19
最 小 值	2.36	1.90	43.68	1.32	12.01	10.85	1.03	74294.04
發生時間	7	21	19	9	12	19		6
零點偏移(率)	-0.04 %	-0.00 %	-0.05 %	-0.01 %		-0.03		-0.10 %
全幅偏移(率)	0.14 %	0.34 %	-0.08 %	0.03 %		-0.28		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月23日

[illegible]