

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月15日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.95	8.18	60.00	1.46	19.35	11.16	1.02	79398.92
1	3.35	8.17	61.69	1.60	19.40	11.13	1.04	79495.21
2	4.97	9.29	50.37	2.09	17.34	11.77	1.05	76474.14
3	7.81	7.70	57.59	2.45	17.52	11.52	1.05	78476.38
4	8.94	8.01	58.47	2.07	18.46	11.28	1.05	79834.02
5	5.54	13.74	49.12	2.23	16.54	11.78	1.05	86689.94
6	9.54	11.16	47.84	2.75	17.00	11.63	1.06	77762.08
7	9.23	6.86	57.62	2.26	17.73	11.43	1.06	78997.99
8	8.98	7.82	53.17	1.84	18.48	11.32	1.06	78622.06
9	9.14	9.39	47.87	2.81	16.15	11.57	1.05	77385.29
10	5.51	9.66	63.52	1.79	17.01	12.12	1.07	73522.61
11	6.33	8.33	55.82	1.56	17.68	11.08	1.09	78348.24
12	7.75	12.09	41.92	2.69	16.03	11.62	1.05	75701.62
13	6.89	9.61	44.33	2.48	16.40	11.50	1.07	76211.37
14	7.01	10.52	51.51	1.90	17.01	11.74	1.07	71874.84
15	8.17	8.73	58.31	1.36	17.47	11.38	1.08	78680.62
16	9.31	11.21	56.21	2.31	15.72	12.51	1.06	68908.99
17	9.01	8.22	49.03	3.54	14.83	13.00	1.08	65356.07
18	10.05	7.01	56.81	3.21	14.75	13.04	1.06	66820.12
19	8.34	4.72	60.31	1.90	17.86	11.62	1.05	77446.19
20	11.09	6.38	53.11	4.62	17.55	11.33	1.06	79957.31
21	8.06	7.15	51.08	5.49	17.24	11.31	1.07	79261.51
22	3.88	6.40	51.37	3.64	17.18	11.51	1.06	77413.30
23	3.25	6.41	57.15	1.10	18.07	12.13	1.07	72808.86
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.30	8.62	53.93	2.46	17.20	11.69	1.06	76476.99
最大值	11.09	13.74	63.52	5.49	19.40	13.04	1.10	86689.94
發生時間	20	5	10	21	1	18		5
最小值	2.95	4.72	41.92	1.10	14.75	11.08	1.02	65356.07
發生時間	0	19	12	23	18	11		17
零點偏移(率)	-0.11 %	-0.00 %	-0.20 %	-0.04 %		0.01		0.00 %
全幅偏移(率)	0.04 %	0.03 %	0.23 %	-0.20 %		-0.01		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月15日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.76	11.41	48.09	1.94	19.19	10.19	0.99	85475.56
1	0.88	10.51	45.04	1.45	20.01	10.17	1.00	84359.86
2	1.29	4.94	43.30	2.13	19.08	10.11	1.00	86575.11
3	2.87	9.29	46.19	2.93	18.79	9.94	0.99	87536.57
4	4.82	3.16	47.84	1.92	19.05	10.07	0.99	86793.76
5	6.75	9.26	48.81	2.71	18.34	10.26	0.99	86061.78
6	9.63	10.68	50.95	3.73	18.65	10.08	0.99	87340.18
7	6.16	4.02	49.97	2.84	17.88	10.42	0.99	84672.29
8	6.15	4.37	45.63	2.96	17.73	10.32	1.01	85457.57
9	8.38	8.13	46.64	2.64	18.12	10.26	1.00	85047.70
10	9.90	9.48	44.23	2.96	17.27	10.28	1.00	85631.73
11	8.22	3.71	43.55	2.40	17.33	10.22	1.00	83961.97
12	9.91	4.45	44.44	2.16	18.04	9.96	1.02	87428.60
13	8.75	5.66	49.59	2.84	17.77	10.21	1.02	85729.79
14	7.53	4.65	42.83	2.12	19.95	10.13	1.01	84714.80
15	8.98	4.16	44.72	2.01	19.03	9.94	1.02	87761.10
16	4.78	6.02	52.43	2.74	16.73	11.33	1.01	78330.52
17	2.07	3.38	46.14	1.79	17.66	11.05	0.99	76142.52
18	1.94	4.62	53.25	1.66	18.25	11.15	0.99	78714.13
19	6.20	6.52	54.23	2.84	19.64	10.45	0.99	82630.28
20	7.71	4.74	53.75	4.07	18.90	10.36	0.99	85239.64
21	6.23	5.53	53.41	1.46	19.89	10.08	0.99	85875.01
22	9.07	4.18	52.92	1.42	20.62	9.61	0.99	88618.62
23	8.29	3.79	44.94	1.83	20.32	9.60	0.99	88298.40
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.14	6.11	48.04	2.40	18.68	10.26	1.00	84933.23
最大值	9.91	11.41	54.23	4.07	20.62	11.33	1.05	88618.62
發生時間	12	0	19	20	22	16		22
最小值	0.76	3.16	42.83	1.42	16.73	9.60	0.97	76142.52
發生時間	0	4	14	22	16	23		17
零點偏移(率)	0.00 %	0.00 %	-0.04 %	-0.00 %		0.00		-0.10 %
全幅偏移(率)	0.04 %	-0.01 %	-0.40 %	0.08 %		-0.24		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月15日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.88	3.15	49.31	1.15	17.07	10.88	1.04	80089.03
1	3.29	4.23	51.45	1.05	18.34	10.65	1.05	82852.32
2	6.62	4.96	44.10	1.33	17.53	10.40	1.05	83532.74
3	6.90	4.06	45.63	1.67	15.67	10.88	1.05	78504.26
4	7.29	8.48	46.25	1.51	17.50	10.18	1.04	82965.52
5	8.90	10.25	44.01	2.17	15.22	10.80	1.02	76262.51
6	9.15	6.33	49.66	2.47	14.74	11.09	1.02	76914.53
7	7.23	5.20	46.16	1.76	16.96	10.42	1.05	70313.54
8	9.24	6.81	43.38	2.20	16.12	10.32	1.04	78162.48
9	5.50	6.63	42.90	1.71	16.19	10.32	1.07	76651.49
10	7.57	8.48	41.82	1.96	15.79	10.42	1.04	75763.88
11	7.75	8.23	40.38	1.65	15.59	10.48	1.05	74443.85
12	6.80	5.36	38.82	1.69	15.41	10.46	1.07	72870.98
13	6.09	10.87	35.76	1.87	14.87	10.42	1.04	71369.30
14	6.68	3.92	42.41	1.71	16.43	10.48	1.02	71382.69
15	5.97	13.03	38.94	1.75	17.04	9.75	1.06	76107.44
16	2.45	2.45	44.65	2.00	14.03	11.86	1.03	62501.78
17	1.03	4.80	47.22	1.94	14.22	11.89	1.01	62812.47
18	1.48	3.67	50.18	2.03	14.38	11.80	1.01	65763.55
19	5.65	4.17	55.53	1.57	16.05	11.14	1.04	74476.39
20	13.44	9.43	36.87	8.28	16.44	10.27	1.04	78446.41
21	4.13	4.82	36.26	4.63	14.38	10.80	1.03	72209.49
22	3.68	6.21	42.44	2.92	14.67	10.90	1.05	72644.05
23	8.50	2.69	45.62	1.74	16.67	10.31	1.03	78889.13
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.30	6.18	44.16	2.20	15.89	10.71	1.04	74830.41
最大值	13.44	13.03	55.53	8.28	18.34	11.89	1.08	83532.74
發生時間	20	15	19	20	1	17		2
最小值	1.03	2.45	35.76	1.05	14.03	9.75	0.98	62501.78
發生時間	17	16	13	1	16	15		16
零點偏移(率)	-0.05 %	-0.01 %	-0.01 %	-0.00 %		-0.01		0.00 %
全幅偏移(率)	-0.87 %	-0.23 %	-0.76 %	-0.25 %		0.36		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								