

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月09日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.66	12.21	54.00	1.72	18.98	11.13	1.23	72405.62
1	9.63	12.22	52.31	2.40	17.62	11.42	1.24	71162.44
2	10.40	11.81	54.63	1.92	19.96	10.73	1.24	74646.61
3	9.31	11.94	44.24	2.67	17.89	11.16	1.23	73201.31
4	13.56	11.61	57.73	3.32	20.03	10.34	1.23	77027.90
5	6.06	11.90	53.55	1.21	20.44	10.57	1.23	73312.99
6	7.58	11.75	48.71	2.41	18.22	11.11	1.24	73245.41
7	6.96	12.07	66.51	1.77	19.40	11.31	1.24	70850.36
8	15.18	11.71	51.15	2.66	18.38	10.85	1.23	74559.85
9	14.37	11.58	58.30	1.70	20.28	10.82	1.23	73381.84
10	14.94	11.79	54.52	2.62	18.37	10.71	1.19	75344.44
11	7.55	11.78	50.77	2.18	17.40	11.32	1.21	72163.42
12	9.13	11.81	56.36	2.62	17.36	11.38	1.20	71811.86
13	11.27	12.14	53.10	2.47	16.50	11.70	1.22	69665.95
14	6.16	12.28	56.28	2.18	15.57	11.96	1.20	68980.78
15	10.34	12.09	54.75	2.44	16.40	11.67	1.19	69313.89
16	8.03	11.25	54.26	1.65	19.86	10.53	1.20	75525.56
17	8.64	12.49	44.34	2.06	19.50	10.40	1.20	76446.36
18	8.00	11.31	53.76	1.86	19.50	10.51	1.18	76073.06
19	8.32	12.29	52.12	1.43	19.62	10.60	1.19	74892.75
20	8.33	12.15	45.23	1.34	19.32	10.41	1.19	76588.44
21	12.58	12.31	41.11	1.50	20.47	10.10	1.20	77945.98
22	9.40	12.24	43.02	1.21	19.97	10.49	1.22	75242.12
23	7.71	12.33	52.61	1.11	19.52	11.13	1.20	71421.54
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.67	11.96	52.22	2.02	18.77	10.93	1.21	73550.44
最大值	15.18	12.49	66.51	3.32	20.47	11.96	1.25	77945.98
發生時間	8	17	7	4	21	14		21
最小值	6.06	11.25	41.11	1.11	15.57	10.10	1.18	68980.78
發生時間	5	16	21	23	14	21		14
零點偏移(率)	-0.01 %	0.01 %	-0.02 %	-0.01 %		-0.09	-0.01	0.20 %
全幅偏移(率)	1.26 %	1.97 %	0.28 %	0.40 %		-0.07	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月09日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.93	11.99	62.69	1.22	18.21	10.59	1.04	80725.79
1	9.00	11.91	54.29	1.40	20.59	10.05	1.04	79291.67
2	9.60	12.52	54.97	1.14	19.11	10.71	1.04	76301.17
3	9.37	11.77	45.07	1.05	19.45	10.21	1.04	80907.70
4	9.76	12.01	47.66	1.08	18.94	10.46	1.04	80355.50
5	9.09	12.17	44.04	0.93	19.46	10.30	1.05	75609.18
6	5.93	12.01	41.34	0.71	19.96	10.34	1.04	80287.51
7	10.18	12.65	45.19	0.58	19.31	10.81	1.04	70045.41
8	9.00	12.50	59.33	0.50	19.01	10.86	1.04	71813.73
9	10.16	11.97	59.43	0.99	18.69	10.49	1.06	78082.82
10	10.50	12.29	59.48	1.14	18.59	10.71	1.05	78211.63
11	10.00	11.75	59.49	0.82	19.35	10.21	1.04	81889.50
12	10.17	12.07	46.49	0.67	19.34	10.22	1.04	81202.53
13	9.17	11.98	54.01	0.69	19.05	10.32	1.06	80389.49
14	10.53	12.43	65.13	0.95	18.22	10.58	1.05	77019.28
15	9.80	13.05	58.60	1.14	18.48	10.59	1.06	76521.51
16	22.28	12.46	45.57	0.73	19.33	9.97	1.06	80521.74
17	15.01	14.04	27.26	0.65	19.48	9.93	1.06	78653.67
18	8.07	13.77	42.68	0.95	21.29	9.83	1.04	77771.34
19	9.63	8.95	49.07	1.70	20.67	9.32	1.04	85163.83
20	7.97	10.73	42.79	0.69	20.33	9.09	1.04	78413.89
21	11.03	11.05	42.32	0.37	21.34	8.89	1.03	79712.51
22	9.14	11.94	67.74	0.70	19.56	10.42	1.02	75212.50
23	9.00	12.77	44.74	0.36	19.75	11.18	1.04	74828.03
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.18	12.12	50.81	0.88	19.48	10.25	1.04	78288.83
最大值	22.28	14.04	67.74	1.70	21.34	11.18	1.07	85163.83
發生時間	16	17	22	19	21	23		19
最小值	5.93	8.95	27.26	0.36	18.21	8.89	1.02	70045.41
發生時間	6	19	17	23	0	21		7
零點偏移(率)	-0.14 %	-0.07 %	-0.08 %	-0.01 %		-0.12	-0.01	0.10 %
全幅偏移(率)	-1.01 %	1.59 %	0.10 %	0.78 %		-0.30	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月09日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.75	11.08	57.76	1.70	18.35	9.56	1.31	76312.38
1	9.84	11.20	55.50	1.74	19.83	9.50	1.31	78126.55
2	8.21	10.96	53.87	1.64	19.19	9.41	1.31	77775.35
3	9.75	10.75	53.81	1.74	19.01	9.32	1.31	76293.36
4	10.79	10.67	52.63	1.87	18.18	9.17	1.31	73910.35
5	9.80	10.49	52.11	1.86	19.52	8.74	1.31	74485.38
6	8.77	10.48	45.96	1.75	19.08	8.70	1.31	74886.76
7	8.74	11.03	49.16	3.71	18.15	9.38	1.32	76007.10
8	11.07	10.71	50.08	2.36	19.20	9.06	1.32	76429.62
9	7.92	12.72	46.94	3.64	18.87	9.62	1.32	77001.53
10	8.28	11.85	54.83	3.66	17.94	10.10	1.35	76441.27
11	6.19	11.66	54.12	3.56	17.41	10.31	1.31	76771.15
12	3.17	11.95	61.79	3.25	19.18	10.37	1.31	75040.53
13	7.23	11.93	51.48	3.49	18.75	10.12	1.32	77598.65
14	6.75	12.04	59.06	3.54	18.24	10.47	1.34	75797.46
15	10.73	12.03	57.99	3.99	18.79	10.11	1.30	76425.85
16	13.35	11.18	49.59	4.34	19.78	9.33	1.31	77665.25
17	7.54	11.56	54.46	3.32	20.45	9.24	1.30	75759.03
18	5.44	12.30	47.08	2.94	22.42	8.75	1.32	73556.28
19	6.59	9.48	36.35	0.37	21.35	6.78	1.31	74549.68
20	7.11	11.24	35.37	1.26	22.20	7.13	1.31	72370.21
21	5.09	12.58	43.38	2.40	19.95	7.19	1.30	70719.17
22	10.24	9.74	44.90	0.64	21.07	7.75	1.28	66541.40
23	8.18	13.50	41.51	2.62	21.87	7.23	1.29	68843.69
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.36	11.38	50.41	2.56	19.53	9.06	1.31	74971.17
最大值	13.35	13.50	61.79	4.34	22.42	10.47	1.36	78126.55
發生時間	16	23	12	16	18	14		1
最小值	3.17	9.48	35.37	0.37	17.41	6.78	1.27	66541.40
發生時間	12	19	20	19	11	19		22
零點偏移(率)	-0.14 %	-0.02 %	-0.04 %	-0.00 %		-0.10	-0.01	0.20 %
全幅偏移(率)	-0.71 %	-0.02 %	-0.13 %	-0.07 %		0.21	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								