

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月07日

| 項目      | #1-HCl_C | #1-CO_C  | #1-NOx_C | #1-SO2_C | #1-H2O   | #1-O2_C  | #1-OPAC  | #1-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 6.87     | 7.90     | 69.70    | 0.63     | 19.44    | 11.42    | 1.03     | 72471.38  |
| 1       | 9.46     | 7.72     | 52.94    | 1.21     | 19.29    | 11.41    | 1.02     | 72662.09  |
| 2       | 8.42     | 7.81     | 61.11    | 1.11     | 18.57    | 11.73    | 1.02     | 71566.54  |
| 3       | 9.41     | 9.30     | 57.81    | 1.37     | 18.39    | 11.66    | 1.02     | 71852.72  |
| 4       | 9.56     | 8.24     | 56.93    | 0.94     | 20.17    | 10.95    | 1.02     | 75923.19  |
| 5       | 11.52    | 11.07    | 53.33    | 1.60     | 19.66    | 10.80    | 1.02     | 75433.15  |
| 6       | 8.95     | 11.17    | 52.51    | 1.40     | 19.67    | 10.99    | 1.02     | 75614.21  |
| 7       | 8.15     | 8.50     | 56.89    | 1.09     | 19.52    | 11.30    | 1.02     | 73142.62  |
| 8       | 8.30     | 7.49     | 61.11    | 1.09     | 19.79    | 11.16    | 1.03     | 74337.34  |
| 9       | 6.98     | 10.74    | 53.73    | 1.08     | 19.36    | 11.14    | 1.05     | 74499.45  |
| 10      | 8.04     | 10.80    | 52.87    | 1.31     | 20.18    | 10.58    | 1.05     | 77670.45  |
| 11      | 8.74     | 10.48    | 54.96    | 1.13     | 19.65    | 10.97    | 1.05     | 75279.00  |
| 12      | 6.08     | 11.64    | 57.68    | 1.12     | 19.04    | 11.56    | 1.02     | 71377.77  |
| 13      | 8.71     | 9.58     | 63.66    | 1.41     | 19.05    | 11.81    | 1.01     | 69632.10  |
| 14      | 9.38     | 9.01     | 56.20    | 1.32     | 19.09    | 11.06    | 1.00     | 75161.11  |
| 15      | 8.85     | 8.19     | 49.06    | 1.54     | 18.88    | 10.98    | 1.01     | 76095.61  |
| 16      | 9.59     | 5.36     | 49.19    | 2.02     | 17.13    | 11.62    | 1.01     | 73438.78  |
| 17      | 9.10     | 3.58     | 58.96    | 1.44     | 18.25    | 11.63    | 1.04     | 72224.07  |
| 18      | 9.82     | 5.12     | 56.32    | 1.01     | 19.28    | 10.99    | 1.05     | 76423.85  |
| 19      | 8.51     | 9.01     | 47.06    | 1.72     | 18.21    | 11.14    | 1.03     | 75467.18  |
| 20      | 7.41     | 6.19     | 50.59    | 1.64     | 17.82    | 11.62    | 1.02     | 72588.63  |
| 21      | 8.58     | 7.53     | 59.22    | 0.73     | 20.32    | 10.91    | 1.02     | 75781.09  |
| 22      | 8.21     | 7.28     | 58.98    | 0.72     | 20.75    | 10.54    | 1.02     | 77591.18  |
| 23      | 9.00     | 8.70     | 58.39    | 0.86     | 20.13    | 10.98    | 1.02     | 74978.89  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 8.65     | 8.43     | 56.22    | 1.23     | 19.23    | 11.21    | 1.03     | 74217.18  |
| 最大值     | 11.52    | 11.64    | 69.70    | 2.02     | 20.75    | 11.81    | 1.05     | 77670.45  |
| 發生時間    | 5        | 12       | 0        | 16       | 22       | 13       |          | 10        |
| 最小值     | 6.08     | 3.58     | 47.06    | 0.63     | 17.13    | 10.54    | 0.99     | 69632.10  |
| 發生時間    | 12       | 17       | 19       | 0        | 16       | 22       |          | 13        |
| 零點偏移(率) | -0.04 %  | -0.02 %  | -0.02 %  | -0.00 %  |          | 0.00     |          | 0.00 %    |
| 全幅偏移(率) | 0.00 %   | -0.44 %  | -0.40 %  | 0.15 %   |          | -0.08    |          | 0.20 %    |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月07日

| 項目      | #2-HCl_C | #2-CO_C  | #2-NOx_C | #2-SO2_C | #2-H2O   | #2-O2_C  | #2-OPAC  | #2-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 8.59     | 7.59     | 54.69    | 1.52     | 17.92    | 10.41    | 1.02     | 83944.68  |
| 1       | 1.20     | 4.79     | 65.33    | 1.83     | 18.80    | 10.88    | 1.03     | 79476.65  |
| 2       | 3.92     | 4.79     | 56.80    | 2.00     | 17.55    | 10.57    | 1.02     | 83687.72  |
| 3       | 4.72     | 8.80     | 64.27    | 2.58     | 16.40    | 10.80    | 1.03     | 82969.74  |
| 4       | 8.01     | 6.00     | 58.06    | 2.48     | 16.89    | 10.43    | 1.03     | 85100.74  |
| 5       | 4.91     | 5.81     | 67.66    | 1.77     | 17.64    | 10.70    | 1.04     | 82155.43  |
| 6       | 8.37     | 7.55     | 52.20    | 3.09     | 17.23    | 10.43    | 1.05     | 85556.20  |
| 7       | 8.10     | 7.85     | 62.77    | 3.24     | 16.31    | 10.87    | 1.05     | 81677.81  |
| 8       | 13.00    | 5.58     | 62.17    | 3.26     | 16.47    | 10.64    | 1.05     | 82965.86  |
| 9       | 9.78     | 3.73     | 55.35    | 2.52     | 17.51    | 10.40    | 1.05     | 84909.97  |
| 10      | 8.20     | 3.08     | 64.78    | 1.91     | 16.86    | 11.01    | 1.06     | 80684.49  |
| 11      | 7.55     | 5.17     | 56.67    | 2.34     | 17.01    | 10.56    | 1.06     | 83910.01  |
| 12      | 5.63     | 4.96     | 57.53    | 2.85     | 15.50    | 10.74    | 1.05     | 83795.68  |
| 13      | 5.31     | 3.29     | 64.63    | 2.50     | 15.71    | 10.93    | 1.05     | 82208.69  |
| 14      | 9.48     | 10.00    | 55.68    | 2.84     | 16.37    | 10.48    | 1.05     | 84549.69  |
| 15      | 9.93     | 11.96    | 62.69    | 2.68     | 15.67    | 10.55    | 1.05     | 84569.09  |
| 16      | 8.64     | 6.57     | 61.40    | 3.03     | 15.16    | 10.88    | 1.05     | 82860.75  |
| 17      | 7.00     | 1.83     | 58.66    | 2.27     | 17.10    | 10.35    | 1.05     | 85243.72  |
| 18      | 5.30     | 2.84     | 61.47    | 1.83     | 17.92    | 10.06    | 1.05     | 86200.71  |
| 19      | 8.49     | 9.23     | 58.36    | 2.71     | 15.71    | 10.47    | 1.05     | 85238.97  |
| 20      | 8.74     | 5.98     | 61.34    | 2.26     | 16.65    | 10.42    | 1.05     | 85574.46  |
| 21      | 9.56     | 5.89     | 56.64    | 2.01     | 17.34    | 10.12    | 1.05     | 86924.19  |
| 22      | 8.20     | 5.67     | 60.41    | 1.48     | 18.16    | 10.15    | 1.05     | 86870.40  |
| 23      | 7.59     | 5.86     | 55.85    | 1.14     | 18.87    | 10.18    | 1.05     | 84969.28  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 7.51     | 6.03     | 59.81    | 2.34     | 16.95    | 10.54    | 1.05     | 84001.87  |
| 最大值     | 13.00    | 11.96    | 67.66    | 3.26     | 18.87    | 11.01    | 1.07     | 86924.19  |
| 發生時間    | 8        | 15       | 5        | 8        | 23       | 10       |          | 21        |
| 最小值     | 1.20     | 1.83     | 52.20    | 1.14     | 15.16    | 10.06    | 1.02     | 79476.65  |
| 發生時間    | 1        | 17       | 6        | 23       | 16       | 18       |          | 1         |
| 零點偏移(率) | -0.02 %  | -0.06 %  | -0.02 %  | 0.00 %   |          | 0.04     |          | -0.20 %   |
| 全幅偏移(率) | 0.04 %   | 0.00 %   | -0.07 %  | -0.13 %  |          | 0.21     |          | -0.10 %   |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月07日

| 項目      | #3-HCl_C | #3-CO_C  | #3-NOx_C | #3-SO2_C | #3-H2O   | #3-O2_C  | #3-OPAC  | #3-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 8.92     | 2.65     | 47.54    | 1.61     | 16.08    | 10.69    | 1.04     | 80129.96  |
| 1       | 10.16    | 5.83     | 57.84    | 1.76     | 18.41    | 10.67    | 1.00     | 82072.11  |
| 2       | 9.42     | 5.22     | 56.55    | 1.89     | 16.87    | 10.76    | 0.99     | 82963.23  |
| 3       | 8.54     | 6.78     | 50.72    | 2.26     | 15.70    | 10.81    | 0.99     | 83661.54  |
| 4       | 9.29     | 5.93     | 54.86    | 2.00     | 16.84    | 10.48    | 0.99     | 82854.63  |
| 5       | 10.60    | 6.76     | 52.99    | 2.61     | 15.49    | 10.75    | 0.99     | 80299.82  |
| 6       | 8.15     | 4.90     | 55.00    | 2.02     | 15.75    | 10.69    | 0.99     | 81233.21  |
| 7       | 10.27    | 7.52     | 45.33    | 2.03     | 16.75    | 10.12    | 0.99     | 76911.48  |
| 8       | 11.60    | 8.79     | 59.21    | 2.47     | 15.13    | 11.01    | 0.99     | 81145.60  |
| 9       | 11.78    | 8.04     | 52.78    | 2.63     | 14.41    | 11.43    | 0.99     | 79882.70  |
| 10      | 9.67     | 8.53     | 56.16    | 2.50     | 14.58    | 10.95    | 0.99     | 76698.72  |
| 11      | 8.66     | 10.68    | 49.84    | 2.64     | 13.86    | 10.88    | 0.97     | 75637.41  |
| 12      | 9.44     | 3.22     | 48.49    | 1.86     | 15.49    | 10.52    | 0.98     | 75912.97  |
| 13      | 10.33    | 6.65     | 47.96    | 2.26     | 15.49    | 10.43    | 1.01     | 78774.97  |
| 14      | 9.00     | 6.92     | 46.33    | 3.18     | 14.02    | 10.53    | 1.02     | 75944.45  |
| 15      | 9.68     | 9.98     | 46.33    | 2.75     | 14.18    | 10.44    | 1.01     | 76271.78  |
| 16      | 8.50     | 5.01     | 48.54    | 2.46     | 14.00    | 10.67    | 0.97     | 74270.91  |
| 17      | 8.62     | 6.20     | 45.15    | 1.90     | 14.74    | 10.59    | 0.97     | 76148.12  |
| 18      | 8.70     | 6.39     | 45.38    | 2.01     | 14.68    | 10.55    | 0.97     | 77598.92  |
| 19      | 6.54     | 5.01     | 48.24    | 1.56     | 15.09    | 10.58    | 0.99     | 78700.58  |
| 20      | 9.12     | 7.14     | 51.88    | 1.78     | 15.41    | 10.77    | 0.99     | 79685.01  |
| 21      | 9.26     | 7.81     | 54.14    | 1.68     | 16.20    | 10.55    | 0.99     | 82594.98  |
| 22      | 9.66     | 10.43    | 51.95    | 1.62     | 16.81    | 10.51    | 0.97     | 84006.44  |
| 23      | 7.73     | 6.10     | 52.49    | 1.41     | 17.34    | 10.20    | 0.97     | 83266.63  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 9.32     | 6.77     | 51.07    | 2.12     | 15.56    | 10.65    | 0.99     | 79444.42  |
| 最大值     | 11.78    | 10.68    | 59.21    | 3.18     | 18.41    | 11.43    | 1.09     | 84006.44  |
| 發生時間    | 9        | 11       | 8        | 14       | 1        | 9        |          | 22        |
| 最小值     | 6.54     | 2.65     | 45.15    | 1.41     | 13.86    | 10.12    | 0.94     | 74270.91  |
| 發生時間    | 19       | 0        | 17       | 23       | 11       | 7        |          | 16        |
| 零點偏移(率) | -0.04 %  | -0.01 %  | -0.05 %  | -0.01 %  |          | 0.00     |          | 0.00 %    |
| 全幅偏移(率) | -1.28 %  | 0.66 %   | -0.17 %  | -0.18 %  |          | 0.33     |          | 0.30 %    |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |