

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月01日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.09	2.79	53.22	2.44	20.12	11.13	1.40	77525.60
1	10.39	3.43	60.50	1.81	19.44	11.20	1.41	77691.70
2	9.10	5.47	69.56	2.21	18.90	12.12	1.42	71438.49
3	11.20	4.19	60.71	2.05	19.58	11.30	1.42	76797.41
4	14.66	8.84	54.11	2.40	17.71	11.56	1.43	78459.36
5	13.52	2.97	63.22	2.68	18.63	11.31	1.41	75045.76
6	9.44	4.75	59.87	2.14	19.41	11.11	1.41	77918.83
7	9.47	2.44	68.07	1.52	20.83	10.88	1.46	78343.69
8	11.13	4.61	55.09	1.78	20.20	10.83	1.44	79635.04
9	9.48	6.09	60.72	1.71	19.85	11.04	1.43	77140.01
10	11.02	3.40	54.81	1.82	20.03	11.03	1.38	77514.66
11	12.12	6.07	61.57	2.03	20.16	11.10	1.40	76936.91
12	13.17	7.35	49.02	1.96	20.09	10.96	1.42	77850.71
13	13.10	5.63	60.92	1.89	20.26	11.05	1.43	76665.51
14	10.05	9.58	54.47	2.01	19.41	11.19	1.43	76596.50
15	9.34	5.44	57.20	1.98	19.42	11.54	1.43	74386.16
16	5.74	1.70	65.94	2.12	19.47	12.26	1.46	68461.84
17	8.06	1.10	54.09	0.44	23.24	10.24	1.41	80801.00
18	9.30	4.50	45.61	1.20	21.55	10.39	1.38	81304.66
19	12.07	2.00	55.15	1.89	19.55	11.00	1.39	78400.96
20	12.62	1.17	59.28	1.61	20.73	10.57	1.39	80024.97
21	14.58	3.06	54.74	1.90	19.65	11.08	1.39	77026.01
22	13.64	2.94	57.64	2.25	19.44	11.51	1.39	73900.59
23	11.70	6.96	63.00	2.14	19.84	11.55	1.38	73517.35
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	11.17	4.44	58.27	1.92	19.90	11.16	1.41	76807.65
最大值	14.66	9.58	69.56	2.68	23.24	12.26	1.51	81304.66
發生時間	4	14	2	5	17	16		18
最小值	5.74	1.10	45.61	0.44	17.71	10.24	1.37	68461.84
發生時間	16	17	18	17	4	17		16
零點偏移(率)	-0.04 %	0.00 %	-0.01 %	0.00 %		0.05	0.00	0.00 %
全幅偏移(率)	-1.30 %	0.03 %	-0.19 %	0.50 %		0.31	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月01日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.65	9.38	62.34	2.36	16.11	11.26	1.33	62328.29
1	10.19	6.66	68.60	1.87	18.45	10.52	1.35	65818.57
2	10.62	7.04	58.58	1.91	18.38	10.06	1.36	68481.38
3	8.71	8.58	58.05	2.26	16.86	10.39	1.36	63815.12
4	11.63	5.18	69.53	2.82	15.39	10.72	1.37	61131.12
5	9.76	2.61	68.96	2.14	17.40	10.50	1.37	65036.07
6	10.10	3.38	69.57	2.56	14.74	11.06	1.35	60242.05
7	8.35	1.59	66.57	2.39	15.83	10.94	1.33	60899.47
8	9.80	4.45	59.88	2.46	15.72	10.78	1.31	65067.16
9	9.97	6.26	58.98	2.36	16.08	10.65	1.27	64212.72
10	10.03	16.16	62.38	2.29	16.51	10.55	1.29	63359.76
11	10.12	7.38	62.85	2.45	17.25	9.98	1.32	65380.80
12	10.79	2.75	43.73	2.80	16.33	10.17	1.33	61367.74
13	10.54	3.21	63.76	2.52	17.01	10.34	1.33	65195.01
14	10.92	3.38	60.09	2.67	16.60	10.41	1.33	65373.12
15	10.27	0.83	63.79	2.30	17.55	10.40	1.33	65807.94
16	6.70	2.96	68.39	1.44	19.83	10.68	1.33	63988.60
17	9.65	5.15	52.93	1.66	18.96	9.89	1.32	69876.06
18	9.94	8.72	59.19	2.05	16.94	10.48	1.31	66288.65
19	8.72	5.13	64.63	2.21	15.93	10.79	1.32	64215.56
20	9.66	2.50	64.67	2.05	16.99	10.48	1.31	65375.23
21	9.75	3.95	66.31	2.37	16.00	10.86	1.30	62857.58
22	11.42	7.26	59.22	2.51	16.22	10.54	1.31	65237.06
23	11.16	9.80	69.36	2.63	15.82	10.78	1.30	65170.61
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.94	5.60	62.60	2.29	16.79	10.55	1.33	64438.57
最大值	11.63	16.16	69.57	2.82	19.83	11.26	1.40	69876.06
發生時間	4	10	6	4	16	0		17
最小值	6.70	0.83	43.73	1.44	14.74	9.89	1.25	60242.05
發生時間	16	15	12	16	6	17		6
零點偏移(率)	-0.08 %	0.00 %	-0.02 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	2.61 %	0.55 %	-0.37 %	-0.14 %		0.15	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月01日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.49	5.14	60.30	2.19	15.47	11.01	1.86	84859.00
1	9.27	4.69	60.13	2.29	16.28	10.59	1.86	83476.81
2	9.91	4.86	65.74	2.21	16.42	10.48	1.86	86405.66
3	6.64	7.41	57.07	1.94	15.90	10.55	1.85	86853.03
4	12.81	3.92	70.45	2.82	15.01	10.87	1.86	85323.92
5	9.60	6.59	60.30	2.51	14.75	10.90	1.82	84383.96
6	10.55	3.15	69.64	3.00	14.25	11.09	1.83	82565.40
7	6.80	4.41	59.38	2.27	15.07	10.73	1.81	85541.47
8	3.79	1.39	63.08	2.17	15.65	10.70	1.80	83767.78
9	11.77	3.55	61.64	2.73	14.80	11.10	1.81	80666.55
10	8.82	2.32	56.17	2.56	15.71	10.61	1.80	85822.34
11	12.02	5.06	58.10	2.77	15.55	10.50	1.81	84048.71
12	15.97	1.18	63.56	2.92	15.54	10.69	1.81	85520.87
13	13.41	0.76	61.47	3.20	15.88	10.79	1.81	83401.60
14	12.39	4.93	59.13	2.86	15.55	10.60	1.80	83670.58
15	12.53	3.76	61.12	3.06	15.70	11.03	1.80	83960.66
16	13.40	0.95	62.27	2.63	16.63	10.42	1.80	84020.62
17	9.46	2.28	67.58	2.31	18.63	10.11	1.81	88698.97
18	8.10	2.94	58.27	2.06	16.96	10.62	1.80	85621.14
19	10.61	1.13	61.01	2.26	16.00	10.51	1.81	86002.08
20	9.27	1.36	63.19	2.50	15.25	10.75	1.80	84116.54
21	10.14	1.41	59.29	2.30	16.76	10.25	1.81	88635.06
22	9.64	0.95	69.61	2.49	16.54	10.36	1.81	86549.65
23	10.66	5.40	52.38	2.59	15.91	10.10	1.80	84400.33
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.29	3.31	61.70	2.53	15.84	10.64	1.82	84929.70
最大值	15.97	7.41	70.45	3.20	18.63	11.10	1.87	88698.97
發生時間	12	3	4	13	17	9		17
最小值	3.79	0.76	52.38	1.94	14.25	10.10	1.80	80666.55
發生時間	8	13	23	3	6	23		9
零點偏移(率)	-0.01 %	0.00 %	-0.07 %	-0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	3.71 %	1.69 %	-0.05 %	0.75 %		0.34	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								