

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月29日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.01	13.31	44.40	2.40	16.24	11.62	1.18	78963.19
1	7.27	12.89	49.81	2.22	17.47	11.34	1.18	80450.80
2	11.27	12.05	56.47	2.63	17.82	10.73	1.18	85365.57
3	12.75	12.33	51.79	2.69	16.74	11.13	1.18	83705.24
4	8.83	12.43	53.14	2.80	16.20	11.11	1.18	84378.02
5	10.38	11.51	54.63	1.90	15.56	11.48	1.22	89248.65
6	9.13	11.64	59.37	1.76	15.27	11.57	1.21	81330.26
7	12.59	12.72	61.98	2.93	14.64	11.92	1.21	78901.53
8	6.92	11.67	59.17	1.45	15.76	11.54	1.23	80905.36
9	12.79	11.23	56.60	1.45	16.71	11.09	1.23	83956.74
10	7.10	11.47	54.66	1.19	16.51	11.25	1.23	82002.10
11	15.08	11.58	54.41	1.57	15.89	11.38	1.23	81369.04
12	4.73	12.20	57.74	2.89	16.24	11.39	1.23	81144.75
13	4.83	11.79	64.30	3.36	15.73	11.71	1.24	79227.87
14	8.93	11.74	48.16	4.16	15.31	11.60	1.24	80589.79
15	3.67	14.21	55.04	4.11	14.84	11.70	1.25	80469.18
16	9.54	14.03	61.20	3.60	16.52	11.13	1.24	83767.52
17	7.85	14.01	53.06	4.01	15.82	11.44	1.23	81559.92
18	14.27	13.87	57.46	5.05	15.14	11.38	1.23	82592.39
19	5.53	16.09	56.14	5.27	13.70	11.75	1.23	80471.27
20	8.35	14.92	57.00	4.81	14.01	11.66	1.23	81692.84
21	10.58	14.50	55.67	2.49	14.31	11.65	1.23	81068.21
22	11.35	14.61	58.30	2.64	14.76	11.55	1.23	81667.91
23	8.33	14.26	58.30	2.14	15.91	11.12	1.23	83951.87
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.34	12.96	55.78	2.90	15.71	11.43	1.22	82032.50
最大值	15.08	16.09	64.30	5.27	17.82	11.92	1.25	89248.65
發生時間	11	19	13	19	2	7		5
最小值	3.67	11.23	44.40	1.19	13.70	10.73	1.17	78901.53
發生時間	15	9	0	10	19	2		7
零點偏移(率)	0.00 %	-0.00 %	-0.52 %	-0.00 %		-0.01	-0.01	0.10 %
全幅偏移(率)	-0.25 %	-1.90 %	1.25 %	-0.35 %		0.35	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月29日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.46	14.00	65.44	1.41	16.98	12.13	0.95	71481.56
1	3.15	12.28	51.96	1.19	19.00	10.72	0.95	81740.29
2	10.05	12.01	49.54	1.46	17.68	10.69	0.96	83364.00
3	9.45	11.95	48.58	2.02	17.26	10.66	0.95	81460.07
4	10.63	12.17	53.28	1.90	17.21	10.55	0.96	82598.49
5	8.20	11.78	55.04	1.60	17.62	10.51	0.95	83445.23
6	9.82	12.12	58.78	1.49	17.52	10.85	0.95	80941.26
7	6.14	12.26	55.75	1.82	16.82	11.05	0.95	77896.65
8	11.63	11.77	47.12	2.31	16.77	10.62	0.96	77799.74
9	6.97	11.70	54.11	1.63	17.67	10.43	0.97	81402.54
10	14.37	11.81	50.97	1.57	18.01	10.51	0.97	80734.87
11	6.96	11.88	63.00	1.20	17.74	10.57	0.97	82794.72
12	10.12	11.99	47.00	1.18	18.02	10.45	0.96	80167.19
13	6.01	11.53	43.74	1.24	18.56	9.92	0.94	79033.17
14	12.02	11.48	55.73	1.12	18.51	9.87	0.94	79931.59
15	6.31	13.38	56.67	0.82	18.85	9.75	0.94	79814.19
16	10.34	13.73	46.69	1.27	19.29	9.48	0.95	82815.32
17	9.63	14.69	54.47	1.36	18.70	10.26	0.97	82720.67
18	8.40	14.19	54.30	2.09	17.03	10.48	0.95	78365.59
19	11.26	14.07	52.97	2.81	15.89	10.28	0.94	79296.64
20	8.19	13.99	52.10	2.59	16.65	10.04	0.94	80660.06
21	14.07	14.82	56.71	2.78	15.66	10.62	0.94	79146.59
22	9.55	14.19	50.80	2.19	16.00	10.20	0.94	77234.69
23	9.56	13.66	51.80	1.77	16.05	10.30	0.94	76371.60
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.26	12.81	53.19	1.70	17.48	10.46	0.95	80050.70
最大值	14.37	14.82	65.44	2.81	19.29	12.13	0.98	83445.23
發生時間	10	21	0	19	16	0		5
最小值	3.15	11.48	43.74	0.82	15.66	9.48	0.94	71481.56
發生時間	1	14	13	15	21	16		0
零點偏移(率)	-0.59 %	-0.07 %	-1.03 %	-0.11 %		0.00	-0.01	-0.10 %
全幅偏移(率)	-1.99 %	-1.32 %	0.78 %	-1.01 %		0.17	-0.06	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月29日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.43	11.74	42.22	2.66	17.06	10.41	1.27	69559.41
1	5.18	10.91	38.31	2.82	19.44	9.19	1.27	76956.70
2	4.79	11.19	41.24	2.70	17.20	9.91	1.28	74600.05
3	7.42	11.16	39.31	2.73	16.70	9.97	1.27	76361.47
4	6.70	11.55	40.48	2.72	16.91	10.38	1.27	75281.49
5	3.43	11.47	41.10	2.65	16.88	10.31	1.29	74457.84
6	3.42	11.42	37.67	2.66	16.55	10.28	1.32	75125.29
7	2.40	11.85	48.13	2.89	16.51	10.64	1.33	71385.13
8	2.37	12.07	53.26	2.71	16.13	10.87	1.31	69880.17
9	2.67	11.57	50.01	2.66	16.27	10.44	1.32	72854.88
10	2.49	11.72	54.23	2.61	16.72	10.53	1.32	72673.77
11	3.48	11.67	59.28	2.81	18.14	10.30	1.30	74269.63
12	6.27	11.65	49.06	2.68	17.60	10.33	1.33	73210.37
13	8.56	11.41	51.78	2.89	18.48	9.86	1.34	71369.37
14	6.14	11.17	52.79	2.85	19.12	9.51	1.35	72747.47
15	5.98	13.25	61.32	3.02	19.08	9.58	1.32	75383.51
16	7.67	13.03	52.39	3.08	18.93	9.26	1.31	73386.69
17	11.19	13.05	45.88	2.90	17.30	9.41	1.29	72414.38
18	6.45	13.44	41.92	3.33	16.66	9.59	1.29	69011.58
19	6.32	11.37	44.83	0.06	17.24	9.69	1.29	64383.62
20	9.80	12.00	40.66	0.93	17.27	8.91	1.29	69814.43
21	6.77	11.09	39.81	0.36	17.10	9.30	1.29	65128.94
22	7.75	11.27	39.60	0.27	16.42	9.25	1.28	66211.92
23	10.23	11.43	38.65	0.35	15.82	8.88	1.27	69572.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.83	11.77	46.00	2.31	17.31	9.87	1.30	71918.35
最大值	11.19	13.44	61.32	3.33	19.44	10.87	1.36	76956.70
發生時間	17	18	15	18	1	8		1
最小值	2.37	10.91	37.67	0.06	15.82	8.88	1.27	64383.62
發生時間	8	1	6	19	23	23		19
零點偏移(率)	-0.14 %	-0.00 %	-0.76 %	0.00 %		-0.04	-0.01	0.20 %
全幅偏移(率)	-0.76 %	-0.91 %	0.71 %	-0.00 %		0.22	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								