

報表日期: 113年05月03日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	1.61	5.13	56.59	0.87	16.55	12.31	1.02	76923.15
1	4.40	4.13	52.99	1.42	18.15	10.87	0.99	87193.99
2	8.70	4.06	53.91	1.37	16.81	11.12	0.98	87072.41
3	7.98	4.50	65.08	1.13	16.98	11.28	0.98	85610.00
4	9.63	6.24	46.73	1.31	16.92	11.07	0.98	87174.37
5	10.10	2.76	47.49	1.32	17.01	10.93	0.98	83937.04
6	7.89	7.17	58.31	0.60	16.91	11.72	0.98	81822.86
7	8.37	7.13	55.59	0.66	18.10	11.11	0.97	85547.78
8	8.83	4.61	50.97	0.71	16.94	11.52	0.97	83530.63
9	8.95	4.80	48.21	1.13	16.63	11.64	1.01	82380.74
10	10.05	4.57	45.56	1.75	16.04	11.59	1.01	83556.32
11	8.62	4.77	52.63	1.44	16.01	12.13	0.98	78801.10
12	5.82	5.03	56.84	0.77	16.68	12.05	0.98	78886.80
13	8.29	6.85	57.21	0.66	16.44	11.69	0.99	81870.33
14	9.48	7.64	47.88	1.20	16.52	11.54	0.99	82465.53
15	12.44	11.63	45.55	2.06	15.40	11.99	0.99	79944.16
16	11.18	6.67	48.47	1.04	16.98	11.39	0.99	84109.31
17	10.15	6.73	48.41	0.91	17.00	11.20	1.01	85931.94
18	8.55	7.10	45.16	1.19	16.01	11.74	1.02	82079.84
19	8.48	6.17	50.60	0.90	16.69	11.38	1.00	84920.45
20	8.62	6.63	47.96	0.79	16.82	11.29	0.98	84958.92
21	9.16	6.33	48.80	0.96	16.26	11.51	0.97	83907.38
22	9.22	7.77	48.24	1.68	15.05	11.91	0.97	81106.62
23	9.03	6.79	61.17	0.90	15.91	12.23	0.99	77923.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.56	6.05	51.68	1.12	16.62	11.55	0.99	82985.64
最 大 值	12.44	11.63	65.08	2.06	18.15	12.31	1.04	87193.99
發生時間	15	15	3	15	1	0		1
最 小 值	1.61	2.76	45.16	0.60	15.05	10.87	0.96	76923.15
發生時間	0	5	18	6	22	1		0
零點偏移(率)	0.00 %	-0.00 %	-0.03 %	-0.11 %		-0.09		0.10 %
全幅偏移(率)	0.00 %	-0.23 %	-0.05 %	-0.15 %		0.28		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年05月03日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	7.63	4.56	44.46	1.77	16.63	11.34	1.04	79350.79
1	5.09	4.58	46.12	1.55	18.38	10.82	1.04	81766.82
2	8.59	4.36	44.09	1.18	18.52	10.33	1.04	85852.86
3	9.54	5.33	49.39	1.73	17.16	10.99	1.04	82473.78
4	9.81	4.52	51.25	1.98	16.09	11.34	1.04	79866.62
5	5.45	5.33	63.78	1.62	15.93	11.96	1.05	75213.31
6	8.90	3.24	50.87	2.60	17.19	10.61	1.06	80658.54
7	9.91	3.77	53.18	2.88	16.27	10.95	1.05	83515.74
8	8.72	2.94	57.15	2.22	16.36	11.26	1.05	80037.83
9	7.15	3.02	55.74	1.96	16.76	11.42	1.06	78780.09
10	10.59	2.92	41.63	3.38	15.18	11.36	1.06	80653.38
11	9.63	3.40	49.82	3.16	15.66	11.56	1.05	78335.64
12	9.29	2.83	44.81	2.89	15.72	11.40	1.04	79593.85
13	9.40	2.88	46.53	2.13	16.66	11.44	1.05	78276.49
14	9.74	2.87	43.40	2.65	17.23	11.07	1.05	80483.25
15	10.29	5.36	43.37	3.27	15.94	11.33	1.06	79411.93
16	9.23	2.77	42.23	2.35	16.46	11.15	1.04	81171.90
17	9.10	2.59	44.31	2.15	16.67	11.02	1.04	82302.97
18	9.45	2.86	42.79	2.31	17.11	10.90	1.06	82881.06
19	9.27	2.74	43.99	2.51	16.64	10.79	1.06	84261.69
20	10.28	2.77	41.41	2.14	16.16	11.05	1.05	82277.90
21	9.24	3.27	38.80	2.89	15.33	11.21	1.05	81517.22
22	9.81	4.54	55.51	2.63	16.26	11.45	1.06	79509.61
23	10.51	4.57	52.86	2.40	16.63	11.28	1.06	79965.64
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.03	3.67	47.81	2.35	16.54	11.17	1.05	80756.62
最 大 值	10.59	5.36	63.78	3.38	18.52	11.96	1.08	85852.86
發生時間	10	15	5	10	2	5		2
最 小 值	5.09	2.59	38.80	1.18	15.18	10.33	1.03	75213.31
發生時間	1	17	21	2	10	2		5
零點偏移(率)	-0.01 %	-0.00 %	-0.01 %	0.00 %		-0.05		-0.10 %
全幅偏移(率)	0.14 %	-0.97 %	-0.09 %	0.01 %		0.30		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年05月03日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	1.07	4.27	53.11	0.60	18.09	10.16	0.95	84554.19
1	0.18	6.37	66.13	0.90	17.36	12.10	1.06	70041.46
2	0.41	5.75	45.45	0.52	19.16	9.43	0.95	88501.55
3	3.14	5.19	49.63	0.88	17.83	9.76	0.95	87728.00
4	4.08	6.50	61.16	1.25	17.24	10.11	0.94	85644.01
5	3.87	5.15	59.71	0.89	17.12	10.19	0.94	84512.57
6	2.79	5.43	60.63	0.76	17.22	10.27	0.95	83506.11
7	2.23	6.62	46.70	1.27	17.27	10.34	1.00	85382.86
8	3.51	2.74	55.67	1.16	17.00	10.51	1.00	83094.57
9	1.33	2.52	57.44	1.11	16.24	11.13	1.01	78091.12
10	1.64	2.20	53.81	1.03	16.52	10.56	1.00	82455.13
11	2.24	2.73	56.20	1.12	16.14	11.11	1.00	78628.14
12	3.05	2.61	51.51	1.41	15.53	10.96	0.99	79156.17
13	1.80	2.53	55.00	1.36	15.92	11.16	0.99	77611.11
14	4.49	3.76	55.36	2.13	16.33	11.06	0.99	78563.20
15	3.29	4.58	53.78	1.21	16.58	10.84	0.99	79552.09
16	1.42	5.71	51.53	1.01	16.83	10.35	0.99	84067.49
17	1.86	9.72	55.42	1.38	15.93	10.54	0.99	83183.97
18	2.10	2.39	56.27	1.34	15.68	10.65	0.99	82093.00
19	2.57	2.36	53.55	1.09	16.06	10.53	0.99	83484.31
20	1.49	2.46	56.93	1.44	15.46	10.81	0.99	81707.53
21	2.64	3.74	54.87	1.53	15.02	11.02	1.00	79770.18
22	2.15	6.18	56.57	1.10	15.77	10.88	0.99	79213.87
23	3.49	5.72	59.82	0.84	16.82	10.72	0.99	80967.25
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.37	4.47	55.26	1.14	16.63	10.63	0.99	81729.58
最 大 值	4.49	9.72	66.13	2.13	19.16	12.10	1.20	88501.55
發生時間	14	17	1	14	2	1		2
最 小 值	0.18	2.20	45.45	0.52	15.02	9.43	0.94	70041.46
發生時間	1	10	2	2	21	2		1
零點偏移(率)	-0.03 %	0.01 %	-0.01 %	0.00 %		-0.05		-0.10 %
全幅偏移(率)	-0.24 %	-0.71 %	-0.63 %	-0.09 %		0.46		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								