

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月14日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.61	13.11	68.88	0.93	17.02	12.79	1.14	65259.22
1	2.10	7.73	43.59	0.74	19.19	11.52	1.06	77021.06
2	7.71	6.46	57.95	1.67	15.76	11.78	1.02	77470.70
3	9.58	6.45	46.38	2.04	15.95	11.81	1.01	78200.49
4	7.32	9.76	58.82	2.00	16.21	11.93	1.03	76235.43
5	9.60	10.94	59.86	1.08	19.75	10.84	1.04	78863.63
6	9.75	6.89	58.55	1.59	17.24	11.73	1.02	76556.82
7	10.06	5.77	60.78	1.63	18.94	11.03	1.02	79482.65
8	8.83	6.12	48.49	2.13	15.95	11.64	1.04	73168.42
9	7.34	6.15	70.75	1.19	17.62	11.99	1.06	72398.55
10	6.45	9.87	42.93	0.87	18.66	10.35	1.05	81884.08
11	8.67	3.01	51.93	1.77	16.28	11.78	1.05	74415.39
12	7.89	8.73	40.25	1.97	15.94	11.66	1.05	74072.01
13	7.72	18.37	36.11	2.26	16.31	11.15	1.05	73837.43
14	8.70	9.50	35.51	2.02	16.50	10.96	1.02	75109.52
15	9.19	6.52	42.18	1.59	17.17	11.17	1.02	76517.07
16	8.79	11.60	40.85	2.37	15.68	11.54	1.03	73027.41
17	7.30	7.21	45.52	1.64	16.72	11.26	1.04	74310.50
18	8.25	10.27	42.85	2.47	15.49	11.48	1.04	72887.06
19	3.21	11.83	44.23	1.81	15.63	11.96	1.05	69836.03
20	1.16	8.17	51.94	0.70	17.79	11.48	1.05	75846.87
21	4.60	11.08	52.25	0.86	18.26	11.29	1.04	78501.64
22	8.49	13.00	48.68	1.14	17.29	11.58	1.04	76982.60
23	6.88	11.91	55.13	0.96	18.10	11.30	1.06	78890.30
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.22	9.19	50.18	1.56	17.06	11.50	1.04	75448.95
最大值	10.06	18.37	70.75	2.47	19.75	12.79	1.22	81884.08
發生時間	7	13	9	18	5	0		10
最小值	1.16	3.01	35.51	0.70	15.49	10.35	1.00	65259.22
發生時間	20	11	14	20	18	10		0
零點偏移(率)	-0.12 %	0.00 %	-0.03 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.02 %	-0.34 %	0.05 %	-0.05 %		-0.16		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月14日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.69	8.80	58.50	1.83	16.55	11.26	1.05	75132.98
1	2.68	4.60	55.31	0.89	23.44	8.67	1.05	89639.62
2	8.20	4.67	50.72	1.60	20.15	9.21	1.05	86175.90
3	6.74	2.87	48.49	2.67	14.90	10.70	1.06	78823.66
4	8.41	3.62	45.15	2.12	17.74	9.72	1.06	84307.97
5	9.82	6.18	47.64	2.02	19.05	9.26	1.06	87766.03
6	13.68	7.18	60.24	1.50	18.46	9.79	1.07	85810.63
7	9.27	7.30	53.68	1.42	19.27	9.50	1.07	83441.14
8	8.84	9.90	44.20	1.63	18.54	9.28	1.06	83432.46
9	9.30	6.65	48.97	1.12	20.10	8.61	1.07	89313.47
10	8.37	4.85	42.82	1.70	17.44	9.41	1.09	82731.89
11	5.71	4.76	40.01	2.20	16.39	10.04	1.08	78756.67
12	8.45	5.88	54.00	1.83	16.89	10.49	1.10	80757.13
13	10.01	3.00	52.60	1.42	17.43	10.26	1.09	83151.64
14	9.20	3.05	59.29	1.39	16.48	10.73	1.07	81078.34
15	10.99	6.41	43.31	1.55	18.09	9.47	1.08	85526.61
16	10.56	3.70	63.39	1.52	16.88	10.36	1.09	82033.89
17	8.38	6.41	51.52	1.90	15.78	10.41	1.08	82214.50
18	8.52	6.96	54.27	2.01	14.96	10.51	1.08	81473.71
19	8.35	3.69	56.14	1.00	18.31	10.00	1.09	83700.11
20	8.83	8.38	59.66	1.01	18.42	9.93	1.10	84537.54
21	6.64	9.93	42.84	1.51	18.05	9.97	1.09	85115.92
22	5.78	8.14	60.01	1.32	17.12	10.83	1.07	78459.94
23	3.33	7.84	54.83	1.09	17.96	10.60	1.07	81096.33
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.95	6.03	51.98	1.59	17.85	9.96	1.07	83103.25
最大值	13.68	9.93	63.39	2.67	23.44	11.26	1.10	89639.62
發生時間	6	21	16	3	1	0		1
最小值	0.69	2.87	40.01	0.89	14.90	8.61	1.05	75132.98
發生時間	0	3	11	1	3	9		0
零點偏移(率)	-0.12 %	-0.01 %	-0.02 %	-0.15 %		0.01		0.00 %
全幅偏移(率)	0.04 %	4.10 %	1.02 %	1.81 %		-0.37		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月14日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.02	6.78	65.53	2.09	14.71	10.89	1.07	73254.14
1	9.03	7.38	48.02	1.44	17.69	9.67	1.00	80455.71
2	9.05	3.12	50.49	1.87	17.12	9.34	0.99	77844.07
3	10.13	2.50	51.86	2.14	15.76	9.76	0.97	76066.57
4	7.50	20.00	35.49	1.03	16.27	9.98	0.97	72917.73
5	7.95	10.65	38.34	1.51	17.50	9.88	0.98	75722.28
6	9.62	3.14	51.98	2.02	17.92	9.61	0.98	79443.62
7	0.00	7.96	44.63	1.03	17.45	9.98	1.01	78222.36
8	0.00	7.03	52.86	2.76	18.07	9.65	1.00	78436.87
9	5.71	9.39	53.99	2.35	16.76	9.94	1.03	76148.56
10	9.60	11.81	44.50	1.93	15.46	11.09	1.01	76215.27
11	8.56	6.16	49.45	2.09	15.58	11.36	0.97	77186.38
12	9.59	8.57	42.66	2.70	14.41	11.40	0.97	75964.68
13	6.92	5.53	61.28	1.87	15.11	11.76	0.97	76099.74
14	4.41	3.75	56.89	1.54	15.88	11.42	0.97	76086.32
15	8.47	5.62	51.53	2.35	14.96	11.29	0.98	79606.59
16	8.20	5.76	50.07	2.18	14.82	11.49	0.97	75125.69
17	5.93	3.09	61.76	1.66	15.67	11.22	0.97	73658.56
18	7.79	8.03	45.13	2.02	14.90	10.90	0.97	75623.32
19	7.73	6.65	64.19	1.91	14.93	11.47	0.97	73230.34
20	7.28	9.81	54.02	1.29	16.29	11.18	0.99	77367.29
21	6.71	11.71	55.38	1.59	16.01	11.09	1.02	77365.44
22	4.55	12.30	62.37	1.40	15.66	11.71	0.99	73746.22
23	2.62	10.93	64.06	1.32	15.95	11.79	0.99	73568.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.97	7.82	52.35	1.84	16.04	10.74	0.99	76223.17
最大值	10.13	20.00	65.53	2.76	18.07	11.79	1.12	80455.71
發生時間	3	4	0	8	8	23		1
最小值	0.00	2.50	35.49	1.03	14.41	9.34	0.97	72917.73
發生時間	7	3	4	4	12	2		4
零點偏移(率)	-0.01 %	-0.01 %	-0.09 %	-0.15 %		-0.01		0.00 %
全幅偏移(率)	0.00 %	4.03 %	-1.12 %	7.13 %		-0.05		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								