

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月07日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.36	13.37	36.44	0.37	21.70	10.38	1.02	79131.54
1	7.19	14.07	45.39	0.59	21.63	10.84	1.05	75797.93
2	1.84	11.64	56.04	0.54	19.51	11.62	1.08	72386.07
3	7.85	9.83	58.33	0.52	19.13	11.11	1.05	76797.69
4	9.68	9.84	47.06	1.38	17.11	11.20	1.05	76848.58
5	9.48	11.21	53.52	0.98	17.42	11.60	1.01	72996.81
6	8.44	11.32	51.83	1.11	17.34	11.51	1.02	74479.93
7	9.06	10.53	51.74	1.26	17.21	11.31	1.02	76715.29
8	9.22	10.64	53.06	1.03	17.49	11.29	1.01	76577.63
9	9.12	10.86	61.43	0.86	18.86	11.06	0.99	77359.22
10	8.71	10.97	51.22	1.14	17.86	11.03	1.01	77904.98
11	8.73	11.46	49.09	1.90	17.11	11.20	1.05	76654.10
12	2.83	10.44	50.00	0.97	17.11	11.27	1.05	74519.46
13	10.72	10.37	44.07	2.44	15.26	11.61	1.05	71907.93
14	5.11	6.68	57.86	1.01	17.83	11.71	1.05	71719.21
15	7.63	8.31	57.68	0.63	18.56	11.15	1.05	75851.86
16	7.41	7.24	45.59	0.96	18.33	11.19	1.02	75703.84
17	9.25	8.11	49.97	1.59	16.71	11.36	1.01	75720.80
18	9.22	0.88	52.53	1.33	16.56	11.51	0.99	75331.25
19	7.29	4.43	56.98	1.10	16.53	11.78	0.99	73451.99
20	2.50	5.65	57.04	0.73	17.67	11.13	0.99	77784.99
21	5.06	6.39	58.88	0.69	18.49	11.14	0.99	76352.54
22	6.01	6.86	62.48	0.82	18.30	11.50	0.99	74182.04
23	1.13	8.42	67.88	0.58	18.59	11.81	0.99	71182.07
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.16	9.15	53.17	1.02	18.01	11.30	1.02	75306.57
最大值	10.72	14.07	67.88	2.44	21.70	11.81	1.22	79131.54
發生時間	13	1	23	13	0	23		0
最小值	1.13	0.88	36.44	0.37	15.26	10.38	0.99	71182.07
發生時間	23	18	0	0	13	0		23
零點偏移(率)	-0.11 %	-0.07 %	-0.03 %	-0.01 %		-0.17		0.00 %
全幅偏移(率)	0.00 %	-0.09 %	-0.04 %	0.02 %		0.09		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月07日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.43	8.64	43.75	3.00	17.99	10.23	1.02	83988.66
1	2.53	4.49	58.45	2.07	17.41	11.04	1.02	78086.69
2	2.46	5.95	57.66	1.22	17.30	11.14	1.02	78542.25
3	6.04	5.63	47.44	1.36	18.59	9.79	1.02	87466.04
4	6.88	5.57	52.19	2.46	16.94	10.05	1.02	86825.50
5	8.63	5.43	58.30	3.39	15.29	10.50	1.02	85071.75
6	4.00	4.52	53.54	1.94	17.07	10.05	1.00	88149.05
7	8.11	3.55	54.70	2.24	16.26	10.53	0.99	83635.09
8	4.46	3.56	46.33	1.50	17.72	10.08	1.00	85750.66
9	2.22	4.55	48.79	1.77	17.17	9.95	1.01	86953.17
10	2.85	4.33	52.56	2.18	16.24	10.18	1.04	85830.79
11	5.10	7.39	62.42	2.79	15.94	10.16	1.05	86273.78
12	7.60	3.31	59.08	3.10	15.27	10.46	1.05	84542.26
13	7.95	3.47	60.97	2.22	16.34	10.39	1.05	84458.29
14	9.37	6.57	54.59	1.75	17.53	9.84	1.05	88230.33
15	7.46	4.79	52.70	2.70	16.49	10.19	1.05	85591.22
16	8.13	3.63	58.48	1.79	17.23	9.96	1.03	87004.26
17	6.81	7.42	49.51	2.49	16.50	10.15	1.03	85649.85
18	7.30	8.48	53.95	4.44	15.65	10.58	1.00	83030.98
19	5.54	2.08	66.72	1.30	16.91	10.34	0.99	84522.22
20	8.79	4.29	56.52	3.00	16.14	10.03	0.99	87301.05
21	7.99	3.78	57.87	2.26	16.65	10.28	0.99	85122.65
22	4.18	3.99	68.37	1.37	17.49	11.00	0.99	78707.31
23	6.55	4.57	50.44	2.05	17.85	10.08	0.99	85410.11
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.27	5.00	55.22	2.27	16.83	10.29	1.02	84839.33
最大值	9.43	8.64	68.37	4.44	18.59	11.14	1.06	88230.33
發生時間	0	0	22	18	3	2		14
最小值	2.22	2.08	43.75	1.22	15.27	9.79	0.99	78086.69
發生時間	9	19	0	2	12	3		1
零點偏移(率)	-0.09 %	-0.11 %	-0.02 %	-0.01 %		0.05		-0.10 %
全幅偏移(率)	0.02 %	-0.13 %	0.13 %	0.17 %		-0.11		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月07日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.48	8.01	43.84	0.85	17.27	10.78	0.97	79810.29
1	5.76	7.08	43.77	1.11	17.27	11.05	0.99	80991.87
2	7.15	6.83	49.91	1.61	15.64	11.06	0.99	79274.88
3	3.98	9.92	54.38	2.06	14.44	11.49	0.99	77187.23
4	5.06	8.76	48.50	1.92	14.69	11.06	0.99	76000.92
5	6.36	6.93	56.68	1.60	15.76	11.07	0.99	79933.63
6	6.76	5.05	51.51	1.46	16.09	10.96	0.99	82095.16
7	6.13	5.51	45.85	1.95	14.67	10.92	1.01	79992.21
8	4.53	9.84	44.66	1.84	15.21	10.58	1.01	79495.18
9	1.82	4.67	50.22	1.64	14.46	10.89	1.02	76750.06
10	1.21	6.73	46.87	1.68	15.14	10.77	1.00	78281.73
11	2.19	4.01	48.71	1.41	15.11	10.75	1.01	77445.45
12	2.38	10.47	54.58	1.47	14.99	10.86	1.00	78576.97
13	1.72	8.68	59.46	0.77	17.55	10.61	1.04	82540.75
14	6.26	6.54	47.27	1.83	14.54	10.85	1.02	78899.14
15	5.16	4.24	44.78	1.59	16.01	10.64	1.02	78477.37
16	6.60	7.81	43.47	1.86	15.52	10.50	1.02	81070.62
17	7.05	5.41	50.27	1.90	14.63	10.89	1.01	78460.56
18	5.79	1.39	52.61	1.61	14.85	11.03	1.02	78851.03
19	3.83	4.40	53.24	1.87	14.43	11.15	1.02	78598.93
20	4.44	10.14	55.09	2.52	13.58	11.41	1.02	77327.70
21	8.22	1.35	54.00	1.81	15.68	10.76	1.02	79553.06
22	6.02	2.22	55.09	1.78	15.09	11.11	1.02	76445.67
23	6.37	1.60	55.23	1.17	18.35	9.78	1.02	82221.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.01	6.15	50.42	1.64	15.46	10.87	1.01	79095.07
最大值	8.22	10.47	59.46	2.52	18.35	11.49	1.07	82540.75
發生時間	21	12	13	20	23	3		13
最小值	1.21	1.35	43.47	0.77	13.58	9.78	0.97	76000.92
發生時間	10	21	16	13	20	23		4
零點偏移(率)	0.00 %	-0.07 %	-0.05 %	-0.01 %		0.01		0.00 %
全幅偏移(率)	0.02 %	0.03 %	-0.06 %	0.01 %		0.27		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								