

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月15日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.16	2.71	56.47	0.74	20.35	12.94	1.71	64234.86
1	6.19	1.09	35.77	0.25	22.28	10.44	1.40	81517.34
2	10.65	1.41	48.93	0.31	22.29	10.60	1.40	79958.07
3	9.69	1.75	42.79	0.57	20.60	10.79	1.39	80846.62
4	11.35	2.54	43.29	0.50	21.17	10.92	1.38	79055.76
5	6.55	2.47	67.71	0.07	22.36	11.17	1.41	81142.30
6	7.55	5.02	45.65	0.11	24.28	9.72	1.40	85877.44
7	10.27	0.72	51.59	0.44	21.55	11.05	1.39	78231.40
8	10.86	1.92	56.08	0.11	23.96	10.07	1.41	83016.03
9	10.65	5.57	49.19	0.34	21.91	10.27	1.41	83187.84
10	10.87	4.88	49.05	1.23	19.11	11.33	1.43	77456.84
11	13.73	11.76	50.56	1.07	20.97	10.63	1.43	80922.42
12	12.54	10.24	35.04	1.33	19.60	10.56	1.42	79141.72
13	8.70	7.98	52.61	1.34	18.72	11.80	1.40	74182.20
14	9.92	2.14	50.95	1.01	19.86	11.26	1.38	77305.70
15	11.18	0.89	55.53	0.98	20.27	11.14	1.38	77534.17
16	9.26	1.50	44.63	1.22	18.89	11.51	1.39	76666.05
17	9.53	1.53	54.25	1.34	18.96	11.72	1.40	75092.62
18	5.07	1.22	58.93	0.86	20.21	11.80	1.41	73677.44
19	6.02	1.08	61.09	0.96	20.37	11.84	1.42	72691.10
20	10.42	1.18	50.41	0.84	19.88	11.11	1.44	79190.16
21	5.93	7.96	68.82	1.04	19.70	12.30	1.47	69693.63
22	7.46	9.45	53.51	1.15	19.48	12.51	1.47	67399.73
23	10.05	5.54	50.68	0.61	20.80	11.17	1.42	75967.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.94	3.86	51.40	0.77	20.73	11.19	1.42	77249.55
最大值	13.73	11.76	68.82	1.34	24.28	12.94	1.99	85877.44
發生時間	11	11	21	13	6	0		6
最小值	0.16	0.72	35.04	0.07	18.72	9.72	1.37	64234.86
發生時間	0	7	12	5	13	6		0
零點偏移(率)	-0.14 %	0.00 %	-0.01 %	-0.00 %		0.03	0.00	0.00 %
全幅偏移(率)	0.84 %	0.51 %	-0.75 %	0.16 %		0.27	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月15日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.46	5.50	58.99	1.88	18.22	10.40	1.49	66885.76
1	10.27	3.04	61.41	2.15	17.45	10.91	1.49	65093.41
2	10.96	2.52	56.78	2.66	17.02	10.57	1.50	67842.06
3	8.94	1.57	56.14	2.46	15.91	11.12	1.50	62928.23
4	9.57	0.71	63.86	1.77	18.42	10.74	1.50	65862.13
5	10.04	4.22	56.46	1.62	18.53	10.46	1.49	67368.48
6	6.33	4.33	62.16	1.91	16.51	11.13	1.44	64571.16
7	10.11	6.25	61.04	2.00	16.55	11.26	1.45	63429.27
8	11.51	6.47	54.92	2.16	16.78	10.75	1.46	66543.22
9	10.92	4.25	60.34	2.05	17.39	10.67	1.46	66106.76
10	11.47	20.03	66.12	1.84	18.88	10.05	1.45	68728.49
11	8.73	2.46	59.68	2.11	16.14	11.22	1.44	62769.68
12	8.01	2.79	70.65	2.09	16.18	11.72	1.40	60257.37
13	12.19	3.56	65.95	2.18	16.52	10.96	1.38	64653.91
14	11.93	9.40	61.67	2.63	15.85	11.14	1.40	63250.00
15	10.15	5.05	58.28	2.47	15.69	11.13	1.42	64669.81
16	11.46	9.85	51.93	5.32	14.92	11.19	1.45	64261.61
17	9.97	1.83	70.27	4.54	15.92	11.01	1.46	64869.18
18	9.79	0.64	56.87	2.19	17.76	10.60	1.46	63316.81
19	9.95	1.06	62.23	2.28	17.15	11.10	1.46	60809.75
20	10.63	0.85	59.37	1.86	19.01	10.62	1.44	65000.17
21	11.60	5.45	59.95	2.10	17.59	10.86	1.42	63829.08
22	15.02	9.80	66.31	3.24	16.10	11.31	1.41	61339.41
23	11.00	2.76	59.85	2.25	17.53	11.08	1.41	62751.17
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.50	4.77	60.88	2.41	17.00	10.92	1.45	64464.04
最大值	15.02	20.03	70.65	5.32	19.01	11.72	1.51	68728.49
發生時間	22	10	12	16	20	12		10
最小值	6.33	0.64	51.93	1.62	14.92	10.05	1.38	60257.37
發生時間	6	18	16	5	16	10		12
零點偏移(率)	-0.34 %	-0.00 %	-0.01 %	0.00 %		-0.06	0.00	0.00 %
全幅偏移(率)	2.55 %	0.44 %	-0.43 %	0.00 %		0.01	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月15日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.17	6.00	55.74	1.54	17.72	10.31	1.38	86685.85
1	7.70	0.84	54.61	1.67	16.96	10.86	1.38	84003.55
2	9.62	2.29	55.26	1.90	16.13	10.65	1.38	86260.86
3	10.25	9.11	54.90	2.01	16.56	10.39	1.38	88030.87
4	9.65	1.09	51.57	1.87	15.82	10.50	1.38	87834.81
5	9.31	1.83	57.55	1.90	16.13	11.05	1.40	85402.20
6	8.53	2.06	60.55	2.31	14.89	11.38	1.38	84899.87
7	9.48	5.39	58.06	2.84	13.64	10.97	1.35	80243.47
8	10.01	2.09	55.70	2.71	14.30	11.21	1.38	84740.60
9	9.92	1.60	54.77	2.23	16.06	10.52	1.37	89120.67
10	10.00	1.41	54.98	1.83	16.14	10.61	1.34	83865.35
11	10.96	5.95	48.81	2.96	14.36	10.51	1.30	83628.96
12	9.82	2.18	61.52	2.80	13.54	11.29	1.30	81495.48
13	10.34	3.68	59.24	2.90	13.60	11.54	1.31	79710.73
14	10.25	1.18	59.75	2.45	14.36	11.36	1.36	81361.90
15	9.90	1.11	58.42	2.19	14.89	11.22	1.37	85487.15
16	8.53	3.27	52.71	2.30	14.30	11.25	1.36	82689.05
17	7.99	2.57	54.85	2.62	14.32	11.14	1.36	80522.37
18	6.42	1.46	61.68	2.04	14.98	11.40	1.33	78322.96
19	9.30	0.98	63.27	1.67	15.91	11.36	1.32	79072.57
20	6.84	1.68	57.81	1.86	15.73	11.19	1.30	80452.78
21	7.05	5.42	60.24	2.38	15.29	11.35	1.31	78455.83
22	11.70	10.16	52.37	2.12	16.25	10.70	1.34	84546.86
23	8.66	6.38	52.18	2.17	16.41	10.75	1.33	83006.58
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.23	3.32	56.52	2.22	15.35	10.98	1.35	83326.72
最大值	11.70	10.16	63.27	2.96	17.72	11.54	1.41	89120.67
發生時間	22	22	19	11	0	13		9
最小值	6.42	0.84	48.81	1.54	13.54	10.31	1.30	78322.96
發生時間	18	1	11	0	12	0		18
零點偏移(率)	-0.01 %	-0.00 %	-0.05 %	-0.03 %		0.00	0.00	0.00 %
全幅偏移(率)	0.61 %	0.02 %	-0.36 %	0.01 %		0.33	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								