

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月13日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.91	3.19	62.03	2.73	14.81	12.34	1.37	70185.74
1	8.86	3.50	56.29	3.68	13.67	12.75	1.36	67468.12
2	10.16	3.60	53.76	4.07	12.90	12.62	1.38	68956.90
3	10.67	6.17	58.60	4.38	12.29	12.55	1.36	69946.15
4	9.12	5.56	60.31	4.10	12.67	12.53	1.34	70461.05
5	0.41	5.43	65.91	3.04	13.53	12.70	1.33	69116.67
6	4.30	4.17	62.43	3.50	13.30	12.80	1.35	68249.49
7	7.14	3.17	67.89	3.64	13.49	12.74	1.37	68616.12
8	10.41	3.28	54.42	3.47	13.89	12.09	1.37	73005.80
9	15.23	3.03	58.76	4.31	13.14	12.56	1.36	69292.35
10	7.41	2.97	53.83	3.55	13.50	12.53	1.33	69423.43
11	5.41	3.44	53.51	3.05	13.84	12.40	1.33	70473.85
12	9.35	3.09	48.98	3.51	13.13	12.35	1.33	71101.97
13	6.79	3.87	58.94	3.93	12.55	12.97	1.33	66048.13
14	8.85	4.74	57.48	3.77	13.23	12.86	1.33	67182.05
15	7.54	3.77	52.50	3.57	13.29	12.91	1.33	67007.98
16	2.79	5.39	59.73	3.27	13.14	12.75	1.36	68487.28
17	7.70	9.55	50.44	3.72	12.38	12.70	1.36	68886.55
18	10.20	5.98	64.06	3.44	13.38	12.71	1.37	67743.10
19	7.00	3.63	65.17	2.69	14.48	12.60	1.36	68779.38
20	5.29	5.00	48.47	2.84	14.09	12.52	1.34	69243.89
21	6.66	5.14	53.74	3.44	13.35	12.78	1.35	67486.90
22	8.21	5.21	63.27	3.05	14.22	12.78	1.39	67135.88
23	8.25	3.56	67.54	2.64	14.85	12.66	1.38	67534.56
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.57	4.43	58.25	3.47	13.46	12.63	1.35	68826.39
最大值	15.23	9.55	67.89	4.38	14.85	12.97	1.42	73005.80
發生時間	9	17	7	3	23	13		8
最小值	0.41	2.97	48.47	2.64	12.29	12.09	1.33	66048.13
發生時間	5	10	20	23	3	8		13
零點偏移(率)	-0.17 %	-0.00 %	-0.00 %	-0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	2.42 %	-0.11 %	-0.36 %	0.07 %		0.27	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月13日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.22	3.71	46.12	2.02	17.76	10.12	1.45	84960.01
1	9.13	5.59	46.23	2.46	16.21	10.34	1.45	83200.15
2	10.12	5.73	46.79	3.06	13.94	10.83	1.45	80464.41
3	10.34	3.95	59.53	2.69	15.47	10.41	1.43	83584.07
4	10.65	3.38	46.78	2.75	15.44	10.67	1.43	81748.36
5	8.45	11.25	42.35	2.33	15.94	10.61	1.41	80490.48
6	11.73	3.81	38.66	3.20	15.18	10.16	1.44	86651.42
7	9.44	5.60	44.02	2.56	16.06	10.17	1.44	82021.33
8	11.08	3.92	54.15	3.16	15.36	10.63	1.44	81891.44
9	10.76	6.26	38.28	2.40	15.98	10.37	1.46	83559.01
10	8.48	2.96	52.00	2.31	16.16	10.73	1.46	82588.36
11	6.28	3.03	52.35	1.96	17.11	10.35	1.46	82766.55
12	7.70	3.06	48.37	2.64	16.76	10.43	1.47	83884.48
13	9.93	3.43	61.21	3.27	17.13	10.57	1.49	85796.48
14	10.10	4.04	43.70	2.40	17.14	10.22	1.49	85570.67
15	8.80	3.53	46.21	2.34	15.90	10.53	1.50	83882.56
16	10.33	2.67	48.11	2.05	17.29	10.24	1.50	88643.38
17	10.04	2.89	56.54	2.20	16.61	10.59	1.50	85788.91
18	8.40	2.76	53.06	1.86	17.75	10.37	1.50	86215.81
19	9.38	4.54	51.28	1.86	17.54	10.20	1.50	87981.09
20	11.28	6.53	50.59	3.12	14.71	10.69	1.49	84612.55
21	10.09	4.28	49.18	2.56	15.90	10.52	1.46	84613.91
22	9.64	3.13	44.33	2.39	16.30	10.26	1.43	81567.97
23	9.32	3.73	46.30	1.72	18.97	10.01	1.43	86299.71
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.65	4.32	48.59	2.47	16.36	10.42	1.46	84115.96
最大值	11.73	11.25	61.21	3.27	18.97	10.83	1.51	88643.38
發生時間	6	5	13	13	23	2		16
最小值	6.28	2.67	38.28	1.72	13.94	10.01	1.41	80464.41
發生時間	11	16	9	23	2	23		2
零點偏移(率)	-0.92 %	-0.13 %	-0.12 %	-0.01 %		-0.03	0.00	0.00 %
全幅偏移(率)	-7.92 %	-0.12 %	-0.46 %	0.00 %		0.25	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月13日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.44	3.61	57.17	2.14	14.63	11.70	1.31	77480.23
1	5.67	3.74	53.84	2.12	15.38	11.09	1.30	80768.85
2	12.31	5.43	50.63	3.27	14.02	11.00	1.32	82724.08
3	5.71	4.17	52.11	2.60	13.51	11.26	1.31	79351.79
4	10.83	8.41	45.65	2.63	15.10	10.43	1.29	79372.92
5	7.80	5.46	45.15	2.59	13.99	10.91	1.31	77846.35
6	4.53	4.91	57.62	1.41	16.59	10.55	1.35	83117.10
7	4.61	9.34	41.84	2.08	13.68	11.23	1.37	84500.08
8	6.26	2.01	49.96	1.98	14.86	11.16	1.39	79399.37
9	9.20	1.77	51.53	1.97	14.69	11.07	1.41	83143.44
10	8.16	3.36	57.18	1.55	15.80	10.88	1.40	84331.65
11	6.67	2.45	46.70	1.52	15.12	11.09	1.41	82734.69
12	2.94	1.97	51.56	1.01	15.77	10.81	1.41	85242.65
13	2.18	2.60	52.74	1.77	14.13	11.42	1.39	80313.78
14	4.85	1.92	56.77	1.40	15.79	11.02	1.38	83808.81
15	5.73	2.00	48.37	1.51	14.81	11.03	1.38	82833.88
16	6.56	2.07	47.38	1.50	14.70	11.00	1.37	83286.71
17	2.58	2.06	54.17	1.30	15.30	11.10	1.37	83668.57
18	3.04	2.02	63.20	0.93	17.16	10.57	1.38	87430.13
19	6.12	4.48	46.37	1.22	15.60	10.82	1.37	85895.25
20	8.95	4.26	49.73	1.80	15.16	10.96	1.37	85937.58
21	9.45	2.64	51.88	2.05	14.32	11.32	1.39	84677.35
22	6.27	3.23	53.80	1.20	16.16	11.03	1.43	84912.98
23	7.85	3.82	55.82	1.17	16.57	11.14	1.41	83865.52
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.45	3.66	51.72	1.78	15.12	11.02	1.37	82776.82
最大值	12.31	9.34	63.20	3.27	17.16	11.70	1.43	87430.13
發生時間	2	7	18	2	18	0		18
最小值	2.18	1.77	41.84	0.93	13.51	10.43	1.28	77480.23
發生時間	13	9	7	18	3	4		0
零點偏移(率)	-0.02 %	0.00 %	-0.19 %	0.00 %		0.02	0.00	0.00 %
全幅偏移(率)	1.35 %	-0.24 %	-0.20 %	0.17 %		0.33	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								