

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年02月24日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.06	7.47	53.96	0.86	17.60	11.20	1.32	84392.37
1	8.86	4.82	66.94	0.79	18.80	11.54	1.31	80837.10
2	10.64	4.53	57.72	1.11	16.83	11.50	1.29	82759.10
3	14.10	4.10	64.46	0.89	16.94	11.53	1.29	82286.94
4	11.25	4.37	56.32	0.72	16.90	11.59	1.29	81648.40
5	3.93	4.12	45.09	1.65	14.83	11.93	1.29	79147.56
6	11.11	6.26	46.27	1.95	16.14	11.50	1.27	81596.69
7	9.52	2.53	48.17	1.26	15.71	11.53	1.27	79814.19
8	7.36	3.40	61.89	1.32	15.34	11.95	1.25	76844.73
9	10.00	3.23	55.26	0.87	15.75	11.79	1.25	80830.90
10	12.23	3.20	43.99	1.33	15.84	11.53	1.26	81654.07
11	10.92	2.77	57.31	0.91	16.49	11.91	1.27	77789.27
12	8.59	3.13	48.47	1.32	15.11	12.05	1.27	79801.11
13	7.81	2.90	53.70	0.91	15.48	12.30	1.29	76891.78
14	0.82	3.05	66.08	0.65	15.75	12.65	1.28	73814.12
15	3.43	2.96	52.07	0.68	15.76	12.22	1.27	77464.16
16	4.21	9.33	59.08	1.75	15.92	12.35	1.27	75625.75
17	7.35	2.89	58.74	0.48	16.62	11.59	1.26	82222.06
18	9.21	2.88	51.40	0.55	16.29	11.30	1.27	84993.30
19	9.19	4.56	51.69	1.52	14.48	11.94	1.27	80045.29
20	5.53	2.99	50.40	0.86	15.54	11.78	1.28	81557.87
21	3.57	2.60	55.54	0.93	15.96	11.77	1.28	81234.35
22	2.57	2.80	66.24	0.81	15.61	12.53	1.28	74850.74
23	1.75	2.90	45.15	0.53	16.04	11.65	1.29	81596.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.67	3.91	54.83	1.03	16.07	11.82	1.28	79987.41
最 大 值	14.10	9.33	66.94	1.95	18.80	12.65	1.33	84993.30
發生時間	3	16	1	6	1	14		18
最 小 值	0.82	2.53	43.99	0.48	14.48	11.20	1.25	73814.12
發生時間	14	7	10	17	19	0		14
零點偏移(率)	-0.08 %	0.01 %	-0.02 %	-0.00 %		-0.35		0.30 %
全幅偏移(率)	0.61 %	-0.30 %	0.06 %	0.00 %		-0.16		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年02月24日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.63	6.20	55.73	1.68	17.57	10.48	1.15	84206.83
1	9.93	5.58	53.44	1.55	17.70	10.56	1.14	83934.59
2	15.05	7.28	43.10	2.23	16.32	10.73	1.13	83449.88
3	16.13	5.39	58.37	2.89	14.78	11.14	1.14	81779.16
4	3.57	5.45	61.54	1.81	15.50	11.43	1.12	79020.94
5	8.27	5.05	54.23	1.99	15.99	10.84	1.10	83232.92
6	9.80	4.18	50.38	2.06	14.14	11.43	1.14	78953.11
7	10.30	3.80	55.79	2.32	14.27	11.27	1.15	81685.50
8	11.48	3.71	55.27	1.92	13.93	11.44	1.14	80023.02
9	12.03	4.48	55.34	1.85	15.53	11.26	1.14	80798.83
10	15.41	5.51	53.21	2.46	13.56	11.64	1.13	78931.62
11	13.77	5.95	57.40	1.97	14.95	11.63	1.14	78017.27
12	12.24	4.29	54.22	2.40	14.42	11.23	1.14	81956.07
13	11.37	3.90	57.69	2.12	14.61	11.36	1.15	80668.43
14	10.58	3.78	58.29	2.34	14.01	11.47	1.14	80203.65
15	9.17	4.44	56.95	1.81	14.20	11.49	1.13	79506.20
16	7.62	7.92	53.92	2.70	13.69	11.46	1.12	80130.78
17	7.41	1.47	46.60	2.84	12.87	11.60	1.12	80168.76
18	7.60	10.46	53.44	3.98	12.74	11.35	1.12	81703.47
19	8.25	2.07	61.12	2.86	14.25	11.47	1.12	79479.66
20	6.96	2.63	55.43	3.54	13.44	11.60	1.14	79806.47
21	8.57	2.73	57.47	2.28	14.79	11.21	1.15	81287.59
22	8.27	2.44	56.62	2.49	14.61	11.51	1.15	79183.29
23	8.51	4.03	56.45	2.23	14.93	11.24	1.12	81369.95
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.04	4.70	55.08	2.35	14.70	11.29	1.13	80812.42
最 大 值	16.13	10.46	61.54	3.98	17.70	11.64	1.20	84206.83
發生時間	3	18	4	18	1	10		0
最 小 值	3.57	1.47	43.10	1.55	12.74	10.48	1.10	78017.27
發生時間	4	17	2	1	18	0		11
零點偏移(率)	-0.09 %	0.00 %	-0.04 %	0.00 %		-0.13		0.10 %
全幅偏移(率)	0.14 %	0.67 %	0.93 %	0.22 %		-0.07		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年02月24日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.24	4.08	58.79	0.55	15.49	11.25	1.55	78428.01
1	9.05	3.57	63.31	0.54	16.38	11.13	1.56	79692.88
2	9.52	4.64	64.33	0.47	16.86	10.69	1.56	82934.00
3	9.92	8.45	52.38	2.03	15.37	10.78	1.56	82492.39
4	11.17	3.48	55.70	0.79	14.95	11.35	1.56	77710.27
5	9.20	6.69	60.01	0.88	14.55	11.41	1.56	77964.96
6	9.11	3.12	62.23	0.90	14.64	11.43	1.57	78196.65
7	10.97	3.75	59.94	0.69	14.71	11.34	1.56	76542.12
8	9.52	7.46	55.76	0.54	15.46	10.90	1.55	77329.05
9	10.48	5.73	55.13	0.49	15.47	10.96	1.55	77038.06
10	9.19	3.93	58.44	0.60	15.19	11.10	1.55	76192.29
11	9.73	5.64	55.86	0.52	15.50	11.11	1.56	74991.70
12	7.61	2.42	55.27	0.49	14.93	11.22	1.57	74160.17
13	7.78	2.01	62.51	0.52	14.80	11.44	1.57	73053.31
14	7.15	2.58	60.34	0.37	15.09	11.19	1.56	74745.70
15	6.28	2.63	59.14	0.58	14.31	11.39	1.56	72711.70
16	8.25	2.21	59.96	0.57	15.20	10.99	1.56	77692.70
17	7.98	2.85	58.92	0.37	15.61	10.96	1.56	80244.98
18	7.73	2.48	58.80	0.41	15.78	10.74	1.53	81067.15
19	8.56	2.18	59.80	0.39	15.60	11.05	1.53	78838.35
20	8.67	3.18	58.08	0.79	14.93	11.02	1.54	78700.54
21	10.21	6.07	58.76	0.35	16.80	10.60	1.56	81758.69
22	7.52	5.73	55.25	0.39	16.01	10.95	1.56	78640.31
23	8.35	2.45	57.32	0.29	16.86	10.77	1.57	78712.62
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.84	4.06	58.58	0.60	15.44	11.07	1.56	77909.94
最 大 值	11.17	8.45	64.33	2.03	16.86	11.44	1.63	82934.00
發生時間	4	3	2	3	2	13		2
最 小 值	6.28	2.01	52.38	0.29	14.31	10.60	1.52	72711.70
發生時間	15	13	3	23	15	21		15
零點偏移(率)	-0.06 %	-0.03 %	-0.03 %	-0.01 %		-0.42		-0.10 %
全幅偏移(率)	1.53 %	-0.20 %	0.03 %	-0.06 %		-0.21		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								