

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月08日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.87	7.08	55.46	0.62	18.34	11.14	1.05	83975.64
1	6.62	6.74	47.38	0.72	18.43	10.80	1.04	86618.81
2	3.92	6.31	67.28	1.01	17.18	12.11	1.05	76193.74
3	3.56	6.25	53.37	0.61	17.29	11.78	1.06	79719.16
4	0.20	6.73	69.50	1.54	14.72	13.60	1.38	66023.17
5	0.14	4.02	42.63	0.29	17.12	11.33	1.06	84173.77
6	3.15	13.42	59.25	0.87	17.85	10.82	1.02	87441.54
7	8.90	12.77	57.94	1.43	17.10	11.27	1.02	84457.02
8	9.67	8.46	49.91	1.84	16.46	11.65	1.04	81953.32
9	9.55	6.97	59.42	1.01	17.24	11.83	1.04	81667.02
10	9.54	6.41	47.05	2.34	15.00	12.33	1.02	80856.76
11	10.96	8.14	43.05	4.38	13.82	12.38	1.03	81219.07
12	6.10	9.88	53.34	2.56	14.44	12.84	1.02	76046.51
13	9.57	11.10	58.82	2.55	14.67	12.53	1.02	79239.92
14	9.42	10.15	64.38	2.55	14.63	12.86	1.02	75932.27
15	6.87	11.59	56.51	2.01	15.08	12.86	1.03	75577.64
16	3.39	16.15	66.79	1.14	15.15	12.67	1.03	77356.50
17	5.36	14.01	63.28	1.19	15.46	12.06	1.02	82590.28
18	5.34	13.01	57.86	1.90	15.06	12.07	1.02	83125.99
19	8.01	13.23	62.00	2.04	14.73	12.80	1.02	76490.72
20	10.71	8.16	59.11	2.73	15.68	12.03	1.01	83103.58
21	10.21	7.25	53.60	2.44	14.56	12.02	1.01	84281.95
22	10.21	3.78	51.09	2.54	14.93	11.98	1.04	81412.83
23	6.10	8.46	62.60	1.84	14.22	12.81	1.03	74400.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.77	9.17	56.73	1.76	15.80	12.11	1.05	80160.74
最大值	10.96	16.15	69.50	4.38	18.43	13.60	1.85	87441.54
發生時間	11	16	4	11	1	4		6
最小值	0.14	3.78	42.63	0.29	13.82	10.80	0.99	66023.17
發生時間	5	22	5	5	11	1		4
零點偏移(率)	-0.06 %	0.00 %	-0.16 %	0.00 %		-0.06		0.10 %
全幅偏移(率)	0.00 %	-0.00 %	-0.10 %	0.25 %		-0.17		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月08日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.48	4.59	43.85	1.52	16.68	11.05	1.05	79333.36
1	2.88	8.34	47.43	1.84	16.90	10.79	1.06	81539.40
2	2.24	4.75	45.38	1.67	16.72	11.12	1.06	79215.11
3	0.78	4.69	41.05	1.35	17.27	10.89	1.06	81210.23
4	0.13	4.44	45.05	1.80	16.05	11.75	1.06	75439.54
5	0.11	6.67	48.76	1.00	18.03	11.23	1.06	77394.23
6	0.14	6.16	51.53	0.99	17.94	10.87	1.04	79913.48
7	6.11	7.46	55.58	1.62	18.17	10.53	1.03	83101.88
8	4.38	2.07	57.37	1.69	16.49	11.37	1.04	77949.69
9	4.67	2.28	42.65	1.49	17.28	10.75	1.04	81059.42
10	6.17	3.92	33.58	2.81	14.41	11.63	1.04	77155.97
11	6.45	2.93	38.35	2.16	15.59	11.65	1.03	76071.33
12	5.64	2.43	43.61	2.24	14.79	11.90	1.02	74818.41
13	1.38	2.63	58.50	1.01	17.01	11.50	1.02	76284.36
14	3.93	3.13	45.69	1.96	16.16	11.08	1.03	80014.94
15	6.43	3.13	34.59	2.54	15.73	11.44	1.02	77560.83
16	8.46	2.58	36.38	2.63	15.44	11.08	1.02	80410.26
17	10.04	2.87	45.29	2.80	14.69	11.32	1.03	79424.13
18	9.46	3.41	46.80	3.12	14.50	11.31	1.03	79872.58
19	13.21	5.60	47.02	3.68	14.26	11.37	1.03	79305.98
20	7.94	1.56	53.91	3.08	15.65	11.30	1.02	79427.52
21	6.19	2.81	54.77	2.21	15.55	11.47	1.02	77646.75
22	6.64	2.43	53.49	2.42	14.69	11.48	1.00	78352.33
23	1.52	3.79	59.45	1.93	15.29	11.60	1.02	77085.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.06	3.94	47.09	2.06	16.05	11.27	1.04	78732.78
最大值	13.21	8.34	59.45	3.68	18.17	11.90	1.07	83101.88
發生時間	19	1	23	19	7	12		7
最小值	0.11	1.56	33.58	0.99	14.26	10.53	0.99	74818.41
發生時間	5	20	10	6	19	7		12
零點偏移(率)	-0.02 %	-0.00 %	-0.02 %	-0.05 %		-0.01		-0.20 %
全幅偏移(率)	-0.28 %	1.00 %	0.01 %	0.26 %		-0.15		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月08日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.95	7.17	56.00	0.49	17.18	10.53	1.04	81062.53
1	2.84	4.38	59.35	0.52	17.51	10.54	1.04	80356.34
2	5.72	4.33	52.66	0.80	17.67	10.28	1.04	81912.42
3	2.76	4.36	54.26	0.30	17.61	10.34	1.05	81002.67
4	2.30	5.80	50.06	0.52	16.42	10.23	1.04	78657.71
5	4.04	1.10	60.19	0.92	15.71	10.32	1.04	77150.66
6	4.63	4.25	60.02	1.01	15.57	10.45	1.04	76685.58
7	6.23	7.05	44.77	1.31	15.52	10.39	1.04	75722.01
8	8.45	11.69	50.25	1.07	16.59	10.24	1.04	75797.73
9	9.27	9.14	39.86	0.75	17.48	9.80	1.04	75169.18
10	10.83	4.49	43.52	0.91	17.43	9.85	1.05	77947.18
11	4.37	3.91	52.97	0.55	16.16	10.74	1.05	77554.30
12	5.02	4.28	56.38	0.55	15.93	10.91	1.05	78647.22
13	8.69	4.11	58.24	0.79	16.68	10.73	1.05	78487.55
14	6.81	3.70	53.46	0.74	16.22	10.66	1.04	78145.22
15	9.16	3.97	60.65	0.87	16.19	10.84	1.05	78462.29
16	9.17	3.94	56.96	1.45	15.55	10.66	1.06	81145.17
17	9.03	3.85	56.93	1.83	15.09	10.59	1.06	81199.85
18	6.86	3.32	49.91	1.24	15.66	10.24	1.06	79017.84
19	7.25	5.58	58.64	1.03	15.61	10.52	1.05	78203.83
20	7.59	5.69	58.99	0.93	16.13	10.62	1.04	79267.58
21	5.48	6.07	58.55	0.58	16.45	10.45	1.04	81326.17
22	4.29	6.64	56.93	0.59	16.45	10.40	1.04	79778.17
23	2.72	6.23	61.76	0.66	15.48	11.32	1.04	74248.46
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.10	5.21	54.64	0.85	16.35	10.49	1.05	78622.82
最大值	10.83	11.69	61.76	1.83	17.67	11.32	1.06	81912.42
發生時間	10	8	23	17	2	23		2
最小值	2.30	1.10	39.86	0.30	15.09	9.80	1.03	74248.46
發生時間	4	5	9	3	17	9		23
零點偏移(率)	-0.05 %	-0.01 %	-0.02 %	-0.03 %		-0.05		0.30 %
全幅偏移(率)	0.02 %	0.39 %	-0.29 %	0.31 %		-0.07		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								