

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月13日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.23	3.48	49.20	2.67	17.29	11.78	1.46	72247.56
1	6.12	4.09	56.40	3.00	16.80	11.97	1.45	70997.62
2	8.46	4.47	52.27	3.09	16.97	11.84	1.42	71815.67
3	5.90	3.53	56.91	3.35	16.15	12.12	1.42	70715.81
4	5.67	3.22	59.35	2.77	17.23	11.87	1.43	71683.80
5	7.10	4.57	54.43	3.16	17.60	11.58	1.40	71480.70
6	8.92	3.49	51.75	3.11	17.23	11.55	1.42	73478.57
7	10.71	3.11	56.42	3.53	16.28	11.70	1.43	72499.51
8	10.62	3.69	54.11	4.05	15.76	12.11	1.40	69261.12
9	8.99	4.64	61.93	3.50	16.22	12.17	1.44	68771.91
10	10.25	3.42	57.37	3.54	16.67	11.95	1.54	70528.66
11	7.29	3.45	55.73	3.07	17.73	11.75	1.42	70902.65
12	10.51	4.04	52.92	3.74	16.32	11.59	1.43	72688.60
13	10.81	6.49	48.74	4.20	15.27	12.19	1.39	69275.05
14	9.18	8.63	49.20	4.35	14.70	12.37	1.40	68282.70
15	9.83	7.88	56.35	4.40	14.85	12.51	1.42	67408.14
16	3.90	3.64	63.28	3.07	16.74	12.16	1.45	68524.02
17	3.34	3.71	49.79	2.69	17.81	11.64	1.43	71675.49
18	2.36	4.12	62.07	3.21	16.40	12.80	1.44	64258.63
19	1.87	4.03	45.69	2.81	16.89	11.83	1.45	71286.88
20	4.02	4.48	36.06	3.32	16.25	11.77	1.42	72464.37
21	9.99	4.87	39.62	4.33	14.46	12.03	1.40	71808.98
22	10.56	4.20	53.57	4.51	14.58	12.34	1.38	68600.78
23	3.86	3.64	60.89	2.89	17.29	12.27	1.41	67750.09
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.19	4.37	53.50	3.43	16.40	12.00	1.43	70350.30
最大值	10.81	8.63	63.28	4.51	17.81	12.80	1.70	73478.57
發生時間	13	14	16	22	17	18		6
最小值	1.87	3.11	36.06	2.67	14.46	11.55	1.38	64258.63
發生時間	19	7	20	0	21	6		18
零點偏移(率)	-0.02 %	-0.01 %	-0.00 %	-0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	-0.08 %	-0.45 %	-0.47 %	0.10 %		-0.04	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月13日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.53	3.80	31.67	1.82	19.17	9.60	1.38	81944.26
1	13.65	4.38	35.89	2.70	18.99	10.02	1.38	78510.26
2	5.38	4.07	42.69	3.85	18.78	10.26	1.37	81614.10
3	8.67	2.18	38.40	3.16	17.10	10.08	1.37	80720.85
4	5.20	2.15	38.02	2.13	18.47	10.16	1.37	78741.62
5	8.03	3.64	49.53	2.87	16.68	10.36	1.38	80576.69
6	11.28	4.71	51.53	3.64	16.91	10.32	1.38	71952.23
7	10.58	4.58	53.73	3.59	16.92	10.22	1.40	79413.85
8	9.60	9.93	43.78	3.81	17.24	9.95	1.41	78651.96
9	11.64	13.04	36.29	5.72	17.65	9.59	1.43	79216.05
10	9.83	5.25	39.31	3.63	17.58	9.83	1.39	79402.91
11	7.50	3.94	41.35	2.97	17.43	9.89	1.42	78140.50
12	2.44	5.20	42.43	2.04	18.00	9.37	1.42	79807.08
13	6.81	4.99	40.73	2.59	17.82	9.81	1.42	78469.94
14	9.64	4.64	39.64	2.84	18.32	9.85	1.41	78065.25
15	6.27	3.50	52.05	2.11	19.53	9.99	1.42	78815.19
16	7.28	4.23	55.94	2.04	19.88	9.68	1.43	84840.10
17	9.74	5.95	33.27	2.84	18.27	9.60	1.41	84103.22
18	5.80	1.72	45.31	2.16	19.13	9.68	1.41	85846.89
19	8.71	2.44	52.49	2.27	19.37	9.62	1.38	84393.14
20	9.92	2.42	52.22	2.79	17.16	9.97	1.40	80451.91
21	5.07	1.82	50.10	1.93	19.36	10.08	1.42	78065.05
22	7.68	4.51	45.25	2.10	20.14	9.49	1.43	80543.30
23	3.40	3.95	45.53	1.30	20.43	10.10	1.43	79869.14
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.86	4.46	44.05	2.79	18.35	9.90	1.40	80089.81
最大值	13.65	13.04	55.94	5.72	20.43	10.36	1.44	85846.89
發生時間	1	9	16	9	23	5		18
最小值	2.44	1.72	31.67	1.30	16.68	9.37	1.36	71952.23
發生時間	12	18	0	23	5	12		6
零點偏移(率)	-0.02 %	-0.00 %	-0.02 %	0.00 %		-0.04	0.00	0.00 %
全幅偏移(率)	2.40 %	0.13 %	-0.54 %	0.24 %		-0.16	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月13日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.10	4.87	50.16	2.18	16.88	10.52	1.49	82022.64
1	3.31	4.66	51.13	2.16	16.65	10.56	1.49	79851.98
2	4.60	4.39	55.04	2.44	15.89	10.70	1.49	77628.73
3	4.33	5.99	53.31	2.29	17.27	10.43	1.49	82252.16
4	9.68	4.05	49.56	2.54	16.25	10.56	1.49	79688.32
5	7.91	3.44	50.37	2.66	17.44	10.12	1.49	80584.28
6	8.84	6.00	49.83	3.58	14.81	10.59	1.49	78582.96
7	7.14	4.13	54.25	2.98	15.43	10.60	1.48	78443.05
8	8.43	4.02	53.17	2.74	15.89	10.60	1.49	81127.78
9	10.03	3.40	58.67	2.97	17.66	10.25	1.49	82657.31
10	9.89	4.45	53.70	3.22	18.01	9.90	1.49	83503.21
11	7.10	5.88	50.30	3.11	14.87	10.70	1.46	75171.24
12	4.16	3.70	57.07	2.60	16.95	10.32	1.49	79620.87
13	7.56	4.83	52.75	2.87	16.31	10.37	1.46	78073.25
14	7.62	6.09	54.35	2.56	16.27	10.51	1.45	79818.00
15	8.14	6.84	60.42	2.47	17.70	10.46	1.46	79546.59
16	6.66	3.91	56.76	2.49	19.16	9.95	1.48	84217.39
17	4.77	7.21	49.22	2.26	18.55	9.31	1.49	86984.26
18	7.36	4.66	52.28	2.45	19.11	9.60	1.46	86847.26
19	3.91	3.42	45.90	2.20	18.62	9.66	1.47	83580.97
20	5.08	2.59	49.78	2.30	16.98	10.29	1.48	81199.48
21	8.41	7.89	46.99	3.03	15.66	10.27	1.45	76137.86
22	9.17	4.02	52.18	2.87	16.39	10.29	1.46	77098.70
23	9.01	5.23	59.96	2.69	18.22	10.33	1.48	80405.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.01	4.82	52.80	2.65	16.96	10.29	1.48	80626.81
最大值	10.03	7.89	60.42	3.58	19.16	10.70	1.50	86984.26
發生時間	9	21	15	6	16	2		17
最小值	3.31	2.59	45.90	2.16	14.81	9.31	1.44	75171.24
發生時間	1	20	19	1	6	17		11
零點偏移(率)	-0.02 %	-0.00 %	-0.01 %	-0.01 %		-0.01	0.00	0.00 %
全幅偏移(率)	1.62 %	-0.23 %	-1.00 %	0.14 %		0.04	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								