

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月02日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.03	2.28	58.74	2.74	20.37	10.71	1.41	71715.82
1	1.87	2.48	31.14	2.91	18.33	10.81	1.43	72656.07
2	5.87	4.16	51.79	3.99	16.71	11.09	1.44	72395.14
3	8.56	5.76	57.76	4.77	15.50	11.33	1.43	70467.14
4	8.21	5.63	62.48	4.07	16.77	11.22	1.43	71036.83
5	6.02	4.55	59.08	3.82	16.90	11.30	1.43	65844.74
6	9.57	6.27	52.69	5.58	14.45	11.70	1.43	68848.32
7	7.62	4.16	56.27	5.62	13.98	12.05	1.43	66175.46
8	8.50	1.65	61.16	4.24	16.71	11.34	1.41	69419.43
9	8.34	1.78	60.47	3.71	20.14	10.01	1.42	74604.43
10	7.60	2.66	50.43	4.61	16.11	11.50	1.40	66573.44
11	7.49	1.93	57.66	3.87	17.23	10.99	1.40	71697.34
12	6.24	1.75	58.12	3.61	18.00	11.08	1.42	70079.89
13	6.58	2.16	68.57	3.95	16.15	11.84	1.42	66464.99
14	8.60	2.56	55.19	4.08	16.67	11.23	1.41	70726.57
15	9.64	2.35	54.93	4.43	15.97	11.25	1.40	69236.57
16	9.99	1.76	63.28	4.50	16.71	11.02	1.40	70543.45
17	8.88	1.88	52.31	4.44	15.93	11.17	1.39	70098.44
18	6.36	1.63	69.32	3.85	16.61	11.26	1.40	69296.55
19	6.36	2.14	55.34	3.90	17.07	11.03	1.41	70657.08
20	10.09	2.07	57.48	4.40	16.86	10.73	1.40	71662.08
21	10.24	2.57	51.50	4.72	15.63	10.98	1.37	70583.09
22	10.03	2.29	66.17	4.00	17.71	10.94	1.38	70191.82
23	9.00	2.08	53.56	4.21	16.65	10.96	1.39	70440.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.65	2.86	56.89	4.17	16.80	11.15	1.41	70058.96
最大值	10.24	6.27	69.32	5.62	20.37	12.05	1.45	74604.43
發生時間	21	6	18	7	0	7		9
最小值	1.87	1.63	31.14	2.74	13.98	10.01	1.36	65844.74
發生時間	1	18	1	0	7	9		5
零點偏移(率)	-0.19 %	-0.03 %	-0.01 %	-0.01 %		0.05	0.00	0.00 %
全幅偏移(率)	4.44 %	0.15 %	-0.26 %	0.32 %		0.01	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月02日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.23	2.37	51.59	0.70	20.00	9.74	1.48	81574.74
1	0.09	2.56	58.35	0.62	20.48	10.22	1.48	81150.16
2	0.51	4.38	49.25	1.03	19.30	9.83	1.46	86152.65
3	1.57	6.63	59.58	3.45	17.58	9.85	1.46	84393.20
4	4.92	3.94	58.63	1.88	18.03	9.62	1.45	83879.54
5	4.49	3.21	43.84	1.30	19.32	9.63	1.44	81698.87
6	1.90	2.66	45.03	1.54	17.63	9.68	1.41	83700.16
7	2.42	3.84	46.12	1.77	17.64	9.86	1.44	81992.28
8	5.31	4.08	48.93	2.08	17.41	9.82	1.45	83274.40
9	8.50	2.19	51.05	2.14	18.85	9.69	1.46	83706.52
10	8.23	2.31	50.45	1.79	18.65	9.39	1.44	85119.09
11	3.58	3.53	59.54	1.39	18.40	9.81	1.43	80759.93
12	0.92	4.94	57.62	1.38	18.25	9.03	1.45	81274.48
13	0.98	3.03	45.80	1.36	19.42	8.82	1.43	80302.16
14	9.92	1.72	43.04	2.70	18.35	9.00	1.41	80308.25
15	13.04	1.53	49.11	2.53	18.78	8.97	1.43	81549.04
16	9.55	1.46	54.96	2.59	17.53	9.38	1.44	79841.98
17	8.58	1.62	51.66	1.96	18.65	9.33	1.44	80886.06
18	9.95	2.90	43.57	2.86	18.42	9.11	1.43	79935.16
19	9.16	3.42	46.74	2.19	17.68	9.27	1.43	80589.25
20	9.45	3.70	49.19	1.73	19.51	8.67	1.42	82434.20
21	7.98	2.44	41.82	2.01	17.97	9.28	1.43	78924.36
22	3.05	2.41	44.24	1.30	18.69	9.23	1.44	79721.79
23	3.14	3.46	47.36	1.19	19.59	9.25	1.45	76787.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.31	3.10	49.89	1.81	18.59	9.44	1.44	81664.83
最大值	13.04	6.63	59.58	3.45	20.48	10.22	1.49	86152.65
發生時間	15	3	3	3	1	1		2
最小值	0.09	1.46	41.82	0.62	17.41	8.67	1.40	76787.57
發生時間	1	16	21	1	8	20		23
零點偏移(率)	0.00 %	-0.05 %	-0.01 %	0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	0.03 %	0.04 %	-0.24 %	0.03 %		-0.03	-0.03	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年06月02日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.47	7.03	52.78	2.40	17.97	10.24	1.38	82385.94
1	7.06	2.96	58.84	2.58	18.22	10.37	1.38	81686.01
2	13.03	7.38	56.80	4.08	17.58	10.37	1.38	82965.42
3	9.05	5.20	57.65	3.58	16.28	10.58	1.38	81880.06
4	8.73	4.42	63.36	3.25	15.34	10.87	1.38	79920.09
5	5.45	2.75	64.04	2.55	17.48	10.70	1.38	80344.21
6	7.85	2.49	62.63	2.90	16.60	10.53	1.38	83269.21
7	8.87	1.28	52.37	2.92	18.28	10.25	1.38	79693.73
8	10.29	2.05	52.43	3.10	16.98	10.19	1.40	81273.03
9	7.69	7.24	57.48	3.10	16.16	10.51	1.37	77463.03
10	9.48	1.83	57.49	2.73	17.80	10.20	1.40	82799.82
11	2.84	2.00	53.98	2.18	17.00	10.23	1.43	79773.50
12	4.97	2.01	54.11	2.28	17.92	9.94	1.37	78949.48
13	6.97	2.20	47.49	2.52	18.20	9.46	1.36	78213.28
14	8.34	2.78	44.77	2.51	17.07	9.93	1.37	76414.50
15	11.71	1.72	54.29	2.68	16.71	10.28	1.38	77642.80
16	12.85	1.91	59.66	2.98	16.05	10.49	1.38	78129.67
17	12.05	2.67	57.24	3.03	16.22	10.54	1.38	80218.26
18	6.80	1.78	61.29	2.49	17.22	10.56	1.35	77551.60
19	9.04	3.33	61.62	3.80	15.69	10.61	1.37	81839.78
20	10.85	2.42	60.30	3.01	15.62	10.72	1.38	82462.32
21	8.99	1.74	62.93	2.55	17.15	10.52	1.33	81819.63
22	8.95	4.63	58.77	2.57	16.98	10.55	1.37	81435.48
23	9.00	4.19	59.22	2.71	17.81	10.18	1.34	81051.75
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.56	3.25	57.15	2.85	17.01	10.37	1.38	80382.61
最大值	13.03	7.38	64.04	4.08	18.28	10.87	1.43	83269.21
發生時間	2	2	5	2	7	4		6
最小值	2.84	1.28	44.77	2.18	15.34	9.46	1.32	76414.50
發生時間	11	7	14	11	4	13		14
零點偏移(率)	-0.02 %	-0.02 %	-0.15 %	0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	0.00 %	0.00 %	-0.44 %	0.04 %		0.27	0.02	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								