

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年08月06日

報表日期: 114年08月06日

[illegible]

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月06日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.63	13.10	57.89	2.33	17.03	10.92	0.98	81622.56
1	7.91	11.48	60.22	2.81	17.78	11.39	0.97	75672.65
2	9.34	7.30	52.63	2.55	17.41	11.07	0.94	79086.13
3	9.11	8.45	52.71	2.15	17.70	10.77	0.96	83144.68
4	8.59	11.04	51.95	2.45	17.95	10.68	0.97	84276.39
5	10.26	9.96	53.98	3.16	16.80	11.06	0.97	81506.68
6	1.37	5.51	55.04	2.72	16.14	10.93	0.96	84224.19
7	9.58	5.35	55.31	2.30	18.35	10.50	0.94	79062.87
8	8.02	6.20	54.46	2.85	16.73	10.90	0.97	79188.62
9	11.52	5.78	65.04	3.36	16.17	11.35	0.98	79624.60
10	7.27	6.31	57.47	2.92	17.32	10.86	0.97	82071.89
11	9.04	6.72	50.82	3.08	16.77	10.94	0.97	79626.64
12	8.40	8.28	52.95	3.29	16.41	10.90	0.97	80511.64
13	9.33	5.40	60.86	2.35	18.14	10.78	0.97	81714.21
14	3.67	7.23	62.05	3.85	14.23	12.50	0.96	73433.90
15	2.00	8.58	62.72	3.70	14.03	12.61	0.94	73598.89
16	9.87	6.73	63.32	2.43	16.02	11.07	0.94	82908.20
17	8.77	5.80	58.74	2.20	16.48	10.91	0.96	81157.43
18	9.12	5.37	50.05	1.90	18.33	10.20	0.95	79400.13
19	10.23	7.17	51.32	1.84	18.43	10.01	0.94	79037.52
20	8.83	5.68	44.77	2.51	16.68	10.18	0.94	80159.62
21	9.53	9.18	53.51	2.91	16.26	10.39	0.94	80538.04
22	8.20	11.07	60.58	3.26	15.07	11.00	0.94	78911.87
23	9.17	5.82	53.35	2.35	15.98	11.21	0.95	79605.84
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.28	7.65	55.91	2.72	16.76	10.96	0.96	80003.55
最 大 值	11.52	13.10	65.04	3.85	18.43	12.61	0.99	84276.39
發生時間	9	0	9	14	19	15		4
最 小 值	1.37	5.35	44.77	1.84	14.03	10.01	0.93	73433.90
發生時間	6	7	20	19	15	19		14
零點偏移(率)	-0.09 %	-0.10 %	-0.02 %	-0.05 %		-0.06		-0.10 %
全幅偏移(率)	0.14 %	0.02 %	0.14 %	0.11 %		-0.01		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月06日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	4.25	10.77	69.20	2.16	18.14	9.90	1.43	74585.67
1	2.68	10.98	60.26	2.19	19.98	9.95	1.43	77476.77
2	3.72	10.64	55.44	2.41	17.65	10.11	1.40	75264.54
3	7.97	10.67	60.07	3.51	17.15	9.77	1.39	77669.87
4	11.44	9.90	55.92	3.32	16.91	9.77	1.39	76114.11
5	12.29	10.94	57.42	4.72	16.16	9.87	1.38	72673.08
6	1.69	6.06	55.50	1.96	15.85	9.86	1.38	71948.55
7	0.75	5.84	52.68	1.77	16.38	9.95	1.42	72073.94
8	5.16	6.80	55.79	1.79	17.31	9.25	1.41	74358.93
9	9.42	5.79	55.93	1.56	16.66	9.62	1.42	74163.50
10	8.20	6.52	53.85	1.94	16.72	9.50	1.38	74678.45
11	11.04	6.29	53.76	3.60	16.27	9.56	1.39	73857.52
12	3.35	8.04	54.29	1.51	15.29	9.84	1.42	71764.19
13	1.85	7.80	52.78	2.33	16.07	9.85	1.43	71967.69
14	0.83	10.24	61.19	2.60	14.76	11.66	1.39	65216.58
15	0.88	7.45	62.91	2.92	14.34	11.96	1.38	66086.40
16	1.20	5.73	53.25	1.96	16.50	9.44	1.40	76247.54
17	1.48	5.44	59.04	2.04	18.13	9.08	1.43	77322.47
18	5.41	7.58	58.97	2.96	18.93	8.77	1.43	79637.00
19	12.47	5.92	53.25	4.08	17.06	9.27	1.43	75461.36
20	2.23	6.62	57.08	3.23	18.68	8.71	1.43	77059.19
21	4.52	6.33	52.54	2.71	18.76	9.03	1.43	76081.06
22	13.93	13.13	49.60	3.74	17.55	8.99	1.43	75524.73
23	3.87	10.79	58.29	1.49	17.67	9.46	1.41	74396.83
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	5.44	8.18	56.63	2.60	17.04	9.72	1.41	74234.58
最 大 值	13.93	13.13	69.20	4.72	19.98	11.96	1.45	79637.00
發生時間	22	22	0	5	1	15		18
最 小 值	0.75	5.44	49.60	1.49	14.34	8.71	1.34	65216.58
發生時間	7	17	22	23	15	20		14
零點偏移(率)	-0.12 %	-0.00 %	-0.13 %	0.00 %		-0.18		-0.10 %
全幅偏移(率)	0.02 %	-0.03 %	-0.12 %	0.09 %		0.21		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								