

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月10日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.25	12.64	49.78	3.46	14.18	11.98	1.34	79371.13
1	7.72	12.07	46.94	3.56	14.82	11.65	1.34	81019.77
2	6.38	12.27	53.41	3.72	13.94	12.03	1.34	78644.79
3	3.20	12.44	46.08	2.86	14.15	12.21	1.31	76956.47
4	4.80	12.02	50.34	3.21	14.41	11.90	1.31	79640.78
5	10.71	13.10	62.37	3.03	14.73	11.84	1.31	78329.39
6	10.70	12.39	43.16	1.92	15.38	11.24	1.33	83322.84
7	9.23	13.06	55.46	1.77	15.15	11.78	1.34	80028.03
8	9.26	13.32	55.90	1.88	14.95	11.99	1.36	78148.42
9	9.94	12.58	48.28	2.32	14.65	11.41	1.33	83261.74
10	8.68	13.47	48.61	2.28	14.84	12.04	1.32	77537.40
11	10.27	12.61	49.94	2.21	14.76	11.45	1.32	82568.33
12	9.19	13.15	60.58	2.21	14.17	11.93	1.31	78738.11
13	11.12	13.58	57.13	2.81	14.07	11.53	1.34	82190.85
14	12.02	14.09	62.80	2.39	13.42	12.37	1.34	75561.64
15	12.18	13.34	60.66	1.32	14.99	11.98	1.34	77861.60
16	9.57	13.06	48.93	2.34	15.41	11.25	1.34	83262.95
17	10.33	14.02	47.82	2.69	13.95	11.88	1.34	79155.82
18	8.73	12.87	45.61	3.46	13.25	11.91	1.34	79099.74
19	10.02	12.69	54.77	2.80	13.84	12.33	1.32	75800.48
20	9.81	12.22	58.28	2.44	14.53	11.99	1.29	77974.05
21	12.90	12.22	48.23	2.14	14.99	11.59	1.31	80806.29
22	8.97	12.46	51.78	2.62	14.10	11.89	1.34	79407.33
23	9.56	13.75	53.35	3.24	13.82	12.90	1.34	71057.52
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.40	12.89	52.51	2.61	14.44	11.88	1.33	79156.06
最大值	12.90	14.09	62.80	3.72	15.41	12.90	1.36	83322.84
發生時間	21	14	14	2	16	23		6
最小值	3.20	12.02	43.16	1.32	13.25	11.24	1.29	71057.52
發生時間	3	4	6	15	18	6		23
零點偏移(率)	-0.26 %	-0.06 %	-0.02 %	-0.01 %		-0.33	-0.01	0.30 %
全幅偏移(率)	-0.52 %	0.54 %	0.74 %	0.25 %		0.08	0.04	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月10日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.33	11.66	39.43	1.44	15.42	10.46	1.01	74683.00
1	1.19	11.50	41.82	1.59	15.90	10.30	0.99	74553.84
2	1.09	11.80	46.54	1.91	15.45	10.71	0.99	73074.88
3	1.34	11.76	44.86	1.45	15.75	10.50	0.99	74652.59
4	1.19	11.60	41.79	1.62	16.02	10.45	1.00	75974.52
5	1.15	13.55	46.02	1.66	16.16	10.52	1.02	75516.82
6	1.35	11.53	45.59	1.61	14.88	10.83	1.06	77023.69
7	0.87	12.01	48.25	1.47	14.69	11.09	1.06	75275.30
8	0.71	11.75	46.30	1.78	14.71	10.88	1.06	74888.33
9	3.12	12.85	44.49	2.46	14.68	10.77	1.03	75380.69
10	7.06	11.99	51.92	1.83	15.17	10.78	1.05	76110.81
11	7.42	11.82	55.71	1.40	16.09	10.77	1.05	76699.35
12	8.05	12.00	55.09	1.97	14.63	10.83	1.05	77379.64
13	9.45	12.35	54.43	2.50	13.52	10.94	1.05	74225.96
14	9.52	12.46	50.14	2.55	14.13	10.73	1.04	75982.59
15	6.32	12.16	59.53	1.29	16.96	10.72	1.04	72976.05
16	9.42	11.67	44.22	1.28	15.83	10.47	1.04	80523.87
17	9.83	12.14	49.52	1.35	14.93	11.01	1.06	77388.12
18	12.25	12.01	48.71	1.66	14.99	10.87	1.05	77787.47
19	11.02	12.10	51.21	1.44	15.56	10.93	1.02	78202.73
20	13.17	12.25	47.92	2.40	15.13	10.65	1.04	80574.73
21	12.43	11.96	45.76	2.22	14.82	10.82	1.06	77305.12
22	11.73	12.35	51.44	1.68	15.11	11.18	1.06	78092.16
23	11.33	11.83	47.40	1.65	17.19	10.38	1.05	74679.01
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.35	12.05	48.25	1.76	15.32	10.73	1.04	76206.30
最大值	13.17	13.55	59.53	2.55	17.19	11.18	1.07	80574.73
發生時間	20	5	15	14	23	22		20
最小值	0.71	11.50	39.43	1.28	13.52	10.30	0.98	72976.05
發生時間	8	1	0	16	13	1		15
零點偏移(率)	-0.07 %	-0.03 %	-0.06 %	-0.01 %		-0.08	-0.01	0.10 %
全幅偏移(率)	-2.00 %	-0.11 %	0.17 %	-0.44 %		-0.14	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月10日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.92	11.45	51.33	1.87	15.84	10.38	1.48	74653.23
1	8.53	11.53	52.32	1.96	15.86	10.43	1.48	73873.30
2	8.90	11.55	55.17	2.43	16.40	10.39	1.48	74065.91
3	4.61	11.51	54.73	1.81	15.86	10.46	1.48	73321.73
4	9.01	11.46	52.17	2.12	15.58	10.45	1.48	74438.55
5	8.81	13.52	53.54	2.31	15.13	10.62	1.48	74012.70
6	8.61	13.89	52.31	2.20	15.42	10.55	1.48	74664.80
7	5.12	12.12	57.08	2.71	15.18	11.01	1.45	75300.95
8	9.28	11.55	54.78	2.73	15.60	10.51	1.46	75836.22
9	11.31	11.74	56.71	3.34	14.42	10.84	1.48	73232.08
10	7.91	12.41	46.79	2.88	16.01	9.93	1.47	74677.69
11	10.23	11.62	49.92	3.00	14.63	10.02	1.46	72137.52
12	9.91	11.33	49.50	2.55	15.09	9.89	1.44	71952.47
13	9.41	11.22	46.47	2.35	15.37	9.71	1.45	72789.03
14	10.53	11.49	50.04	2.65	15.81	9.84	1.45	71631.18
15	9.21	11.27	47.75	2.73	15.70	9.77	1.44	71183.76
16	8.98	11.42	55.74	2.38	16.98	9.43	1.46	76749.22
17	9.03	11.17	58.22	2.19	15.88	10.07	1.47	74510.61
18	10.35	11.57	58.01	2.36	15.93	10.31	1.44	74052.60
19	9.59	11.85	48.15	2.66	15.56	9.91	1.43	76606.24
20	9.09	11.36	53.22	2.33	16.10	10.11	1.45	75302.00
21	10.25	11.32	52.11	2.44	16.27	9.90	1.44	77870.17
22	9.16	12.07	60.79	2.77	15.05	10.82	1.46	75096.31
23	8.59	11.68	49.85	2.11	16.77	10.20	1.44	74158.45
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.93	11.75	52.78	2.45	15.68	10.23	1.46	74254.86
最大值	11.31	13.89	60.79	3.34	16.98	11.01	1.49	77870.17
發生時間	9	6	22	9	16	7		21
最小值	4.61	11.17	46.47	1.81	14.42	9.43	1.43	71183.76
發生時間	3	17	13	3	9	16		15
零點偏移(率)	-0.14 %	-0.12 %	-0.08 %	-0.01 %		-0.05	-0.01	-0.10 %
全幅偏移(率)	-1.23 %	-1.50 %	-0.02 %	0.06 %		0.04	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								