

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年12月02日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.29	2.98	35.36	0.84	16.82	10.09	1.64	74197.30
1	10.29	3.51	40.40	1.36	18.09	9.88	1.64	75009.25
2	8.78	3.93	40.57	1.57	16.47	10.10	1.63	71817.86
3	12.35	1.84	47.38	2.38	15.52	10.43	1.62	72042.98
4	8.98	2.46	44.95	1.26	16.95	9.98	1.64	73298.44
5	11.46	3.12	48.15	1.99	15.10	10.47	1.64	73688.00
6	9.32	3.55	53.29	2.72	15.08	10.67	1.63	74261.02
7	6.39	2.29	61.85	2.32	12.98	11.23	1.68	71269.94
8	10.84	8.92	44.92	2.43	14.21	10.47	1.69	69813.77
9	8.15	9.79	28.33	2.18	15.33	9.50	1.69	68647.21
10	14.79	1.62	42.64	3.47	16.57	9.74	1.69	72748.63
11	9.01	3.60	41.00	1.63	15.45	9.93	1.68	71191.92
12	7.51	3.87	37.27	1.26	15.76	9.73	1.68	72213.07
13	7.51	3.84	39.78	1.35	16.50	9.56	1.65	73177.25
14	11.00	7.34	34.36	1.98	16.43	9.34	1.64	73329.38
15	9.85	1.79	42.75	1.08	17.48	9.22	1.64	70913.27
16	10.00	1.39	50.08	0.47	18.63	8.97	1.65	76490.92
17	10.12	1.83	51.08	0.64	18.99	9.04	1.67	80759.01
18	10.28	3.59	38.51	0.79	16.48	9.51	1.67	82735.31
19	11.94	5.21	33.46	1.80	14.99	9.89	1.68	75660.51
20	11.07	4.74	42.75	2.04	15.12	9.93	1.69	73994.41
21	10.26	1.42	51.51	1.62	14.84	10.42	1.69	74949.47
22	9.95	1.89	53.29	1.11	15.10	10.35	1.69	75065.82
23	9.91	2.17	58.01	0.88	16.50	10.04	1.68	77224.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.92	3.61	44.24	1.63	16.06	9.94	1.66	73937.48
最 大 值	14.79	9.79	61.85	3.47	18.99	11.23	1.70	82735.31
發生時間	10	9	7	10	17	7		18
最 小 值	6.39	1.39	28.33	0.47	12.98	8.97	1.62	68647.21
發生時間	7	16	9	16	7	16		9
零點偏移(率)	-0.06 %	-0.01 %	-0.03 %	0.00 %		-0.01		0.00 %
全幅偏移(率)	0.02 %	0.31 %	0.17 %	0.26 %		0.05		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								