

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月19日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.04	9.32	61.03	1.70	16.92	11.77	1.23	69620.24
1	3.37	9.66	53.88	1.87	16.27	11.79	1.23	70248.15
2	8.30	10.54	63.21	2.42	15.31	11.86	1.23	70325.02
3	7.10	10.25	52.27	2.69	14.62	11.95	1.24	70271.32
4	5.39	9.50	58.27	2.62	14.68	11.79	1.25	70940.82
5	2.88	8.48	56.91	2.37	15.53	11.62	1.26	70828.92
6	6.42	8.41	60.33	2.78	14.39	11.94	1.25	70416.07
7	7.36	8.52	55.26	2.89	14.34	12.02	1.25	69500.17
8	8.97	8.50	59.23	2.62	14.71	12.00	1.25	68837.93
9	5.61	8.46	62.61	2.39	14.83	11.92	1.25	69474.19
10	9.27	8.47	55.41	2.70	14.49	11.89	1.25	69896.49
11	7.36	8.55	65.40	2.76	14.43	12.05	1.25	68663.09
12	7.41	9.75	58.40	3.06	13.88	12.09	1.25	69155.83
13	6.84	8.49	63.56	2.90	14.69	12.00	1.25	69522.85
14	8.50	8.75	58.65	3.03	14.43	11.98	1.25	69053.54
15	5.11	8.83	55.44	2.98	13.60	12.14	1.25	68154.47
16	4.73	8.91	54.48	2.82	14.00	11.87	1.25	70087.37
17	7.32	8.31	60.21	2.79	16.12	11.46	1.25	71792.18
18	8.86	8.31	57.85	2.46	16.25	11.45	1.25	71655.32
19	9.10	8.39	57.06	2.74	15.20	11.37	1.25	72597.07
20	4.56	8.83	62.78	3.36	12.26	12.22	1.24	69053.38
21	11.59	10.15	58.56	3.19	15.08	11.82	1.24	69410.52
22	5.84	8.97	66.25	2.07	15.96	12.00	1.25	68153.18
23	7.03	9.32	58.98	2.35	15.28	12.20	1.25	67339.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.83	8.99	59.00	2.65	14.89	11.88	1.25	69791.57
最 大 值	11.59	10.54	66.25	3.36	16.92	12.22	1.27	72597.07
發生時間	21	2	22	20	0	20		19
最 小 值	2.88	8.31	52.27	1.70	12.26	11.37	1.22	67339.55
發生時間	5	17	3	0	20	19		23
零點偏移(率)	-0.01 %	-0.00 %	-0.05 %	0.00 %		-0.02		0.20 %
全幅偏移(率)	0.88 %	-0.13 %	-0.24 %	-0.01 %		0.39		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月19日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.71	8.64	55.72	1.42	17.05	11.53	1.08	76361.94
1	2.19	7.89	48.64	2.72	18.24	10.53	1.07	79322.40
2	5.34	9.06	61.67	2.42	16.20	10.96	1.06	77363.79
3	4.12	10.46	58.89	2.11	16.95	10.88	1.06	78667.61
4	7.36	9.58	53.87	2.60	16.55	10.81	1.06	79387.28
5	7.62	7.65	59.60	1.77	15.95	11.27	1.07	79837.20
6	4.74	6.99	61.13	1.81	15.68	11.31	1.06	77238.47
7	10.53	6.99	58.41	3.23	15.92	11.22	1.06	79588.92
8	4.33	7.43	60.41	3.22	15.31	11.46	1.06	79875.97
9	12.21	9.79	63.39	2.87	15.75	11.57	1.06	78696.44
10	2.54	9.49	60.87	3.32	15.22	11.78	1.06	76612.23
11	2.73	9.28	62.63	2.76	15.69	11.58	1.06	76133.86
12	0.96	10.17	62.01	3.26	15.08	11.40	1.05	77904.02
13	10.84	8.21	56.00	1.97	14.76	11.58	1.06	78364.94
14	14.88	9.75	67.42	2.30	14.03	11.65	1.05	78460.17
15	8.16	7.98	60.30	2.01	15.24	11.52	1.05	78551.76
16	5.26	7.66	45.79	1.62	15.94	11.09	1.06	79253.37
17	3.10	8.72	56.07	1.70	15.83	11.13	1.05	80698.31
18	7.13	7.94	55.46	1.89	15.57	11.05	1.06	81056.51
19	11.81	8.55	60.32	2.45	14.35	11.17	1.06	79992.60
20	10.38	9.50	59.63	1.60	14.07	11.59	1.06	79623.47
21	9.81	7.68	57.12	1.43	16.43	11.10	1.06	81603.48
22	8.43	8.00	59.19	1.99	16.70	11.15	1.06	79369.63
23	6.76	8.79	64.51	2.75	16.28	11.65	1.06	75236.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.83	8.59	58.71	2.30	15.78	11.29	1.06	78716.71
最 大 值	14.88	10.46	67.42	3.32	18.24	11.78	1.09	81603.48
發生時間	14	3	14	10	1	10		21
最 小 值	0.96	6.99	45.79	1.42	14.03	10.53	1.05	75236.73
發生時間	12	6	16	0	14	1		23
零點偏移(率)	-0.13 %	-0.00 %	-0.03 %	-0.04 %		-0.08		-0.20 %
全幅偏移(率)	0.74 %	0.17 %	0.11 %	0.33 %		0.14		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月19日

[illegible]