

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年09月14日

報表日期: 115年09月14日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	8.28	12.76	61.93	2.18	18.14	11.20	1.14	73766.69
1	11.60	12.46	58.68	2.53	19.48	10.46	1.14	78196.55
2	8.71	12.25	55.85	2.84	17.63	10.83	1.14	76964.79
3	6.11	12.81	56.35	2.39	17.00	11.35	1.13	73922.52
4	9.99	12.76	53.20	2.36	17.90	11.08	1.14	75175.00
5	3.56	12.90	54.40	2.32	16.76	11.51	1.13	77834.83
6	9.30	12.66	63.87	2.05	18.35	11.03	1.13	74472.68
7	10.92	12.42	50.95	2.67	17.88	10.82	1.13	76435.63
8	9.33	12.87	52.88	2.46	17.56	11.12	1.13	74118.64
9	10.67	12.56	62.74	2.88	17.83	10.92	1.13	75594.68
10	9.03	12.62	64.67	2.07	17.60	11.04	1.13	74689.67
11	10.04	13.33	40.82	2.76	16.34	11.79	1.13	70300.48
12	7.74	13.51	44.83	2.34	18.06	11.51	1.13	70732.91
13	10.42	12.98	52.07	2.40	17.88	11.37	1.13	72500.89
14	9.31	13.39	52.24	3.07	15.97	11.85	1.13	69943.51
15	7.50	13.09	53.27	2.92	15.37	12.11	1.13	69146.00
16	6.26	11.99	55.91	2.41	17.16	11.63	1.13	70979.93
17	10.29	13.14	50.48	3.94	15.01	11.62	1.11	72163.11
18	5.75	13.78	49.32	4.60	13.96	12.20	1.10	67997.88
19	10.15	12.25	53.09	3.54	15.77	11.93	1.11	70549.30
20	7.49	12.78	54.30	3.62	15.60	12.13	1.13	68849.23
21	5.63	12.61	63.08	2.89	16.73	12.07	1.13	68349.54
22	10.02	11.63	55.30	2.07	18.09	11.24	1.13	73224.86
23	10.80	11.80	47.71	2.73	17.54	11.14	1.13	74494.28
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.70	12.72	54.50	2.75	17.07	11.41	1.13	72933.48
最 大 值	11.60	13.78	64.67	4.60	19.48	12.20	1.15	78196.55
發生時間	1	18	10	18	1	18		1
最 小 值	3.56	11.63	40.82	2.05	13.96	10.46	1.09	67997.88
發生時間	5	22	11	6	18	1		18
零點偏移(率)	-0.03 %	-0.02 %	-0.02 %	-0.01 %		0.03	-0.01	0.20 %
全幅偏移(率)	-0.64 %	-0.11 %	0.45 %	-0.08 %		-0.04	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 115年09月14日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO ₂ _C	#2-H ₂ O	#2-O ₂ _C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.77	12.77	54.01	0.84	18.81	10.91	0.96	82788.51
1	0.40	12.21	57.05	0.81	19.29	10.45	0.94	86483.46
2	0.67	12.28	73.58	0.68	17.61	10.97	0.96	83941.68
3	0.66	12.44	57.28	0.75	18.56	10.97	0.96	83238.39
4	0.20	13.96	61.83	0.77	17.43	12.13	1.00	74582.03
5	0.20	13.16	43.34	0.65	18.79	11.44	0.99	78910.68
6	1.39	11.71	51.39	1.07	17.49	10.70	0.97	89764.99
7	2.05	12.01	57.00	1.21	17.53	10.57	1.00	87031.84
8	2.04	12.38	48.12	1.04	18.05	10.97	0.98	83159.35
9	1.70	12.22	47.01	0.72	18.25	10.81	0.97	84472.60
10	2.24	12.36	45.21	0.75	18.38	10.92	0.96	82754.07
11	1.01	12.39	61.43	0.80	18.38	10.95	0.95	82907.75
12	0.72	12.33	49.34	0.69	17.40	11.02	0.95	83466.95
13	0.49	13.21	64.56	1.51	16.39	11.71	0.96	78531.26
14	0.42	12.94	55.29	0.78	16.74	11.54	0.95	80028.71
15	0.39	12.48	55.85	1.29	16.33	11.27	0.94	82141.49
16	0.36	12.62	60.11	1.99	15.48	11.45	0.94	81347.73
17	0.91	12.55	60.96	1.36	16.81	11.27	0.94	82609.35
18	0.70	12.79	54.79	1.00	17.11	11.39	0.94	80182.20
19	1.24	13.03	55.51	1.55	16.77	11.03	0.94	84006.46
20	1.21	12.60	60.70	0.62	18.45	11.08	0.95	81626.35
21	1.72	12.47	47.67	1.36	18.13	10.53	0.94	86545.64
22	1.83	12.81	55.03	1.69	16.91	11.06	0.94	83400.88
23	0.69	13.10	60.60	1.58	17.13	11.60	0.94	78820.13
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	1.00	12.62	55.74	1.06	17.59	11.11	0.96	82614.27
最 大 值	2.24	13.96	73.58	1.99	19.29	12.13	1.09	89764.99
發生時間	10	4	2	16	1	4		6
最 小 值	0.20	11.71	43.34	0.62	15.48	10.45	0.94	74582.03
發生時間	4	6	5	20	16	1		4
零點偏移(率)	-0.14 %	-0.06 %	-0.07 %	-0.02 %		0.02	-0.01	-0.20 %
全幅偏移(率)	-1.35 %	-1.06 %	0.17 %	-0.13 %		0.11	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 115年09月14日

報表日期: 115年09月14日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	6.51	11.52	61.09	2.90	19.38	9.97	1.23	76444.39
1	10.30	11.42	60.21	2.87	20.27	9.75	1.23	76232.99
2	8.96	11.11	62.92	3.08	18.77	9.67	1.23	75164.50
3	9.83	11.46	61.13	3.15	18.48	10.06	1.24	76833.35
4	9.46	11.81	60.51	2.90	18.48	10.18	1.25	75427.66
5	10.53	11.58	64.93	3.14	17.58	10.28	1.27	76290.08
6	9.02	11.38	63.36	3.03	17.91	10.02	1.26	76161.62
7	9.93	11.29	50.30	2.97	18.99	9.79	1.26	76047.49
8	10.05	11.34	47.69	1.58	18.67	9.85	1.28	76660.12
9	8.88	11.37	48.53	1.65	16.71	10.10	1.25	75239.03
10	10.72	11.36	58.07	1.62	18.79	9.88	1.25	74248.31
11	9.36	11.35	47.98	1.51	17.85	9.99	1.27	73486.89
12	8.32	11.73	54.04	1.51	17.34	10.25	1.28	73475.76
13	9.76	12.46	52.65	1.55	17.66	10.22	1.27	74314.16
14	10.24	12.83	55.44	1.55	16.31	10.54	1.27	74652.54
15	8.01	12.61	55.35	2.57	15.11	10.64	1.27	73137.16
16	10.20	12.21	54.23	3.26	15.81	10.42	1.26	74693.66
17	9.10	11.51	56.19	2.99	16.16	10.36	1.24	73273.34
18	7.72	11.83	59.62	3.02	15.61	10.54	1.26	73365.00
19	10.93	11.41	57.56	3.12	17.21	10.14	1.24	76590.25
20	9.29	11.57	57.68	2.97	17.20	10.14	1.27	76630.91
21	9.41	11.10	60.41	3.38	19.23	9.41	1.29	81152.59
22	9.55	11.70	59.04	3.08	17.40	10.35	1.28	75509.97
23	8.60	11.94	54.14	3.05	18.25	10.43	1.27	74797.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.36	11.66	56.79	2.60	17.72	10.12	1.26	75409.56
最 大 值	10.93	12.83	64.93	3.38	20.27	10.64	1.30	81152.59
發生時間	19	14	5	21	1	15		21
最 小 值	6.51	11.10	47.69	1.51	15.11	9.41	1.23	73137.16
發生時間	0	21	8	11	15	21		15
零點偏移(率)	-0.05 %	0.00 %	-0.03 %	-0.01 %		0.01	-0.01	-0.10 %
全幅偏移(率)	0.41 %	0.58 %	-0.20 %	-0.05 %		0.25	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								