

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月27日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	15.11	12.39	55.29	2.62	19.30	10.42	1.24	78876.39
1	14.70	13.10	48.56	3.14	17.24	11.47	1.25	71786.18
2	6.80	12.90	62.23	1.97	19.18	11.13	1.25	73775.45
3	5.18	10.85	59.30	2.11	18.67	10.29	1.24	79109.49
4	7.12	12.83	59.31	3.19	14.86	11.66	1.23	72248.51
5	7.22	15.51	41.75	3.66	16.08	11.51	1.19	70201.97
6	11.34	12.94	55.34	3.67	15.68	11.67	1.18	72775.40
7	9.59	12.95	57.11	3.48	15.95	11.65	1.22	72422.07
8	9.52	12.56	61.43	2.11	16.53	11.35	1.25	74024.49
9	10.65	12.69	50.40	2.33	15.59	11.57	1.24	72929.01
10	6.38	12.55	63.74	1.70	16.43	11.35	1.23	72289.37
11	7.66	13.16	47.87	2.53	14.91	11.78	1.22	68529.99
12	6.98	13.81	63.57	0.99	17.29	12.14	1.24	66877.68
13	6.49	12.86	46.64	1.08	16.99	11.50	1.23	72289.60
14	6.57	13.04	53.78	0.77	18.28	11.45	1.23	71615.44
15	6.34	11.81	51.98	1.91	16.55	11.35	1.22	73884.52
16	6.33	11.67	55.12	1.76	16.88	11.27	1.20	74420.43
17	6.33	12.28	51.60	1.63	17.77	11.17	1.21	73654.88
18	6.54	12.32	55.18	2.38	15.97	11.60	1.22	70448.04
19	7.20	12.22	54.40	1.91	18.09	10.99	1.23	74759.23
20	7.12	11.59	53.64	1.72	17.74	11.22	1.23	73250.11
21	6.83	11.78	62.32	1.97	17.46	11.42	1.20	72010.71
22	6.88	11.32	57.66	1.34	19.19	10.75	1.19	75991.42
23	9.85	11.55	47.62	1.76	19.17	10.65	1.20	76131.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.11	12.53	54.83	2.16	17.16	11.31	1.22	73095.93
最大值	15.11	15.51	63.74	3.67	19.30	12.14	1.25	79109.49
發生時間	0	5	10	6	0	12		3
最小值	5.18	10.85	41.75	0.77	14.86	10.29	1.18	66877.68
發生時間	3	3	5	14	4	3		12
零點偏移(率)	-0.16 %	-4.92 %	-0.01 %	-0.01 %		-0.07	-0.01	0.30 %
全幅偏移(率)	-1.66 %	-0.47 %	0.12 %	-0.08 %		-0.02	0.10	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月27日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.29	11.68	62.27	1.39	18.85	9.82	0.98	82038.37
1	7.53	12.07	66.11	1.97	18.09	10.18	0.97	77592.99
2	10.47	13.31	50.39	1.93	18.44	10.17	0.97	82519.55
3	8.84	11.65	60.28	2.21	17.30	10.21	0.98	80172.15
4	11.93	11.62	54.75	2.11	17.82	9.96	0.99	79377.15
5	11.67	11.58	43.03	3.03	16.97	9.91	0.99	77957.77
6	13.63	10.52	53.71	3.03	17.87	9.73	1.02	77605.66
7	6.72	11.04	45.99	2.65	16.74	9.92	1.02	77775.13
8	11.49	11.45	59.19	2.56	16.82	10.35	1.02	80387.95
9	13.29	11.70	53.31	2.86	16.12	10.68	1.04	78738.06
10	7.74	11.38	60.70	2.48	16.65	10.33	1.04	78853.46
11	8.70	11.44	44.09	2.06	16.54	10.36	1.04	75611.83
12	10.72	10.94	47.75	2.14	18.24	9.53	1.04	79594.49
13	8.89	11.34	51.36	1.50	17.20	10.24	1.04	75191.69
14	7.09	11.06	55.98	1.44	17.74	9.91	1.04	77682.63
15	8.00	12.20	49.60	1.73	16.80	10.95	1.03	70461.90
16	2.36	12.49	46.53	1.26	16.90	10.79	1.03	75137.99
17	3.90	11.51	54.62	1.46	18.40	10.10	1.04	84519.29
18	5.52	11.40	54.79	0.87	18.95	9.97	1.03	79749.08
19	5.92	11.76	41.35	1.40	19.11	9.39	1.02	85419.59
20	5.95	12.30	51.65	2.69	17.14	10.14	1.02	82531.31
21	7.64	11.77	51.78	2.23	17.02	10.55	1.03	79992.99
22	6.78	11.68	53.05	1.49	18.62	10.12	1.04	81788.91
23	7.40	13.41	57.68	2.05	17.76	10.40	1.04	83128.46
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.35	11.72	52.91	2.02	17.59	10.15	1.02	79326.18
最大值	13.63	13.41	66.11	3.03	19.11	10.95	1.06	85419.59
發生時間	6	23	1	5	19	15		19
最小值	2.36	10.52	41.35	0.87	16.12	9.39	0.97	70461.90
發生時間	16	6	19	18	9	19		15
零點偏移(率)	-0.10 %	-0.01 %	-0.02 %	-0.01 %		-0.08	-0.01	0.10 %
全幅偏移(率)	0.61 %	-0.79 %	0.64 %	-0.17 %		0.06	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年04月27日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.34	11.88	38.44	2.48	18.49	9.28	1.31	74834.76
1	5.46	11.23	42.77	2.81	19.60	9.24	1.31	73442.23
2	5.39	12.21	37.66	2.59	20.11	8.85	1.32	74882.47
3	6.77	11.54	50.47	2.82	19.47	8.90	1.31	75695.61
4	8.37	12.23	50.79	3.24	18.07	8.91	1.31	75056.37
5	8.88	12.34	46.85	3.47	17.60	8.96	1.31	75192.21
6	7.05	14.86	37.40	1.38	19.74	7.91	1.31	74637.92
7	3.32	12.33	35.06	3.01	16.60	9.34	1.31	87667.77
8	0.40	11.74	61.16	1.74	12.82	10.95	1.30	72591.07
9	4.00	11.22	61.29	1.56	15.99	10.23	1.30	77460.07
10	8.12	11.19	58.10	1.76	16.58	10.15	1.32	77551.28
11	9.43	11.47	62.61	2.12	16.87	10.33	1.32	76968.10
12	9.04	11.41	61.28	1.88	16.16	10.26	1.28	77379.72
13	4.06	11.29	60.12	1.34	15.73	10.37	1.27	75372.06
14	5.16	11.35	53.50	1.24	17.59	10.15	1.27	72766.49
15	6.86	11.20	44.39	2.55	18.51	9.66	1.29	73970.92
16	6.48	10.89	42.42	2.77	16.95	9.71	1.31	76391.39
17	5.54	11.10	49.39	2.57	17.54	9.64	1.28	73454.64
18	4.44	10.73	45.72	2.57	16.52	9.36	1.27	72007.00
19	3.32	10.94	49.92	2.36	18.94	9.36	1.27	74178.43
20	5.95	11.15	43.63	2.40	17.98	9.77	1.30	73885.09
21	4.53	11.08	47.27	2.34	17.81	9.86	1.31	74919.54
22	4.65	11.23	48.53	2.43	18.20	9.86	1.29	73208.42
23	4.29	11.27	51.64	2.47	18.70	9.85	1.28	73002.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.70	11.58	49.18	2.33	17.61	9.62	1.30	75271.49
最大值	9.43	14.86	62.61	3.47	20.11	10.95	1.35	87667.77
發生時間	11	6	11	5	2	8		7
最小值	0.40	10.73	35.06	1.24	12.82	7.91	1.27	72007.00
發生時間	8	18	7	14	8	6		18
零點偏移(率)	-0.01 %	-0.24 %	-0.15 %	0.00 %		-0.10	-0.01	0.10 %
全幅偏移(率)	1.79 %	0.67 %	0.50 %	0.07 %		0.12	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								